

**MADALPINGELISED ELEKTRIPAIGALDISED. OSA 7-729:
NÕUDED ERIPAIGALDISTELE JA -PAIKADELE.
TEENINDUS- JA HOOLDUSKÄIGUD**

**Low-voltage electrical installations - Part 7-729:
Requirements for special installations or locations -
Operating or maintenance gangways**

EESTI STANDARDI EESSÕNA**NATIONAL FOREWORD**

See Eesti standard EVS-HD 60364-7-729:2009+A11:2017 sisaldab Euroopa standardi HD 60364-7-729:2009 ja selle muudatuse A11:2017 ingliskeelset teksti.	This Estonian standard EVS-HD 60364-7-729:2009+A11:2017 consists of the English text of the European standard HD 60364-7-729:2009 and its amendment A11:2017.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 28.08.2009, muudatuse A11 11.08.2017.	Date of Availability of the European standard is 28.08.2009, for amendment A11 11.08.2017
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 91.140.50

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:
Koduleht www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:

Homepage www.evs.ee; phone +372 605 5050; e-mail info@evs.ee

**Low-voltage electrical installations -
Part 7-729: Requirements for special installations or locations -
Operating or maintenance gangways
(IEC 60364-7-729:2007, modified)**

Installations électriques à basse tension -
Partie 7-729: Règles pour les installations
et emplacements spéciaux -
Passages d'entretien ou de service
(CEI 60364-7-729:2007, modifiée)

Errichten von Niederspannungsanlagen -
Teil 7-729: Anforderungen
für Betriebsstätten, Räume
und Anlagen besonderer Art -
Bedienungsgänge und Wartungsgänge
(IEC 60364-7-729:2007, modifiziert)

This Harmonization Document was approved by CENELEC on 2009-04-22. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for implementation of this Harmonization Document at national level.

Up-to-date lists and bibliographical references concerning such national implementations may be obtained on application to the Central Secretariat or to any CENELEC member.

This Harmonization Document exists in three official versions (English, French, German).

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: Avenue Marnix 17, B - 1000 Brussels

Foreword

The text of document 64/1595/FDIS, future edition 1 of IEC 60364-7-729, prepared by IEC TC 64, Electrical installations and protection against electric shock, was submitted to the IEC-CENELEC parallel vote.

A draft amendment, prepared by the former SC 64A, Protection against electric shock, of Technical Committee CENELEC TC 64, Electrical installations and protection against electric shock, was submitted to the formal vote.

The combined texts were approved by CENELEC as HD 60364-7-729 on 2009-04-22.

The following dates were fixed:

- | | | |
|--|-------|------------|
| - latest date by which the existence of the HD has to be announced at national level | (doa) | 2009-11-01 |
| - latest date by which the HD has to be implemented at national level by publication of a harmonized national standard or by endorsement | (dop) | 2010-05-01 |
| - latest date by which the national standards conflicting with the HD have to be withdrawn | (dow) | 2012-05-01 |

In this document, the common modifications to the International Standard are indicated by a vertical line in the left margin of the text.

For this Harmonization Document, the informative Annex B of IEC 60364-7-729:2007 shall be disregarded and has been replaced by the normative Annex ZA, *Special national conditions*, and the informative Annex ZB, *A-deviations*.

Annexes ZA and ZB have been added by CENELEC.

729 Introduction

The requirements of this part of HD 60364 supplement, modify or replace certain of the general requirements of the other parts of HD 60364.

The clause numbering of Part 7-729 follows the pattern and corresponding references of HD 60364. The numbers following the particular number of Part 7-729 are those of the corresponding parts or clauses of HD 60364.

The absence of reference to a part, clause or subclause means that the corresponding general requirements are applicable.

729.1 Scope

The requirements of this part of HD 60364 apply to basic protection and other aspects in restricted access areas with switchgear and controlgear assemblies, including requirements for operating or maintenance gangways.

729.2 Normative references

The following normative documents contain provisions which through reference in this text, constitute provisions of this part of HD 60364. For dated references, subsequent amendments to, or revisions of any of these publications do not apply.

HD 60364-1:2008, *Low-voltage electrical installations – Part 1: Fundamental principles, assessment of general characteristics, definitions* (IEC 60364-1:2005, mod.)

HD 60364-4-41, *Low-voltage electrical installations – Part 4-41: Protection for safety – Protection against electric shock* (IEC 60364-4-41, mod.)

729.30 Assessment of general characteristics

Add the following requirements:

For restricted access areas the following apply:

- restricted access areas shall be clearly and visibly marked by appropriate signs;
- unauthorised persons shall not have access to restricted access areas;
- door(s) provided for closed restricted access areas shall allow easy evacuation to the outside by opening without the use of a key, tool or any other device which not part of the opening mechanism.

729.410.3.7

Replace the paragraph with the following requirements:

In restricted access areas where it is not reasonably practicable to provide protective measures for basic protection (protection against direct contact) in accordance with HD 60364-4-41, minimum distances are required.

NOTE 1 See HD 60364-1, Clause 30 for assessment of general characteristics when deciding to use this method of protection.

NOTE 2 In cases of protective device with high rating, such as large circuit-breakers, greater distances may be necessary for the withdrawing of the device.