

**Elektriliste ja kiudoptiliste kaablite katsetamine  
tuleoludes. Osa 3-10: Püstselt kimpudena paigaldatud  
juhtmete või kaablite katsetamine püstleegi levikule.  
Aparatuur**

Tests on electric and optical fibre cables under fire  
conditions - Part 3-10: Test for vertical flame spread of  
vertically-mounted bunched wires or cables - Apparatus

## EESTI STANDARDI EESSÕNA

## NATIONAL FOREWORD

Käesolev Eesti standard EVS-EN 60332-3-10:2009 sisaldab Euroopa standardi EN 60332-3-10:2009 ingliskeelset teksti.

Standard on kinnitatud Eesti Standardikeskuse 30.11.2009 käskkirjaga ja jõustub sellekohase teate avaldamisel EVS Teatajas.

Euroopa standardimisorganisatsioonide poolt rahvuslikele liikmetele Euroopa standardi teksti kättesaadavaks tegemise kuupäev on 07.10.2009.

Standard on kättesaadav Eesti standardiorganisatsioonist.

This Estonian standard EVS-EN 60332-3-10:2009 consists of the English text of the European standard EN 60332-3-10:2009.

This standard is ratified with the order of Estonian Centre for Standardisation dated 30.11.2009 and is endorsed with the notification published in the official bulletin of the Estonian national standardisation organisation.

Date of Availability of the European standard text 07.10.2009.

The standard is available from Estonian standardisation organisation.

ICS 13.220.40, 29.020, 29.060.20

### Standardite reprodutseerimis- ja levitamiseõigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonilisse süsteemi või edastamine ükskõik millises vormis või millisel teel on keelatud ilma Eesti Standardikeskuse poolt antud kirjaliku loata.

Kui Teil on küsimusi standardite autorikaitse kohta, palun võtke ühendust Eesti Standardikeskusega:  
Aru 10 Tallinn 10317 Eesti; [www.evs.ee](http://www.evs.ee); Telefon: 605 5050; E-post: [info@evs.ee](mailto:info@evs.ee)

### Right to reproduce and distribute Estonian Standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without permission in writing from Estonian Centre for Standardisation.

If you have any questions about standards copyright, please contact Estonian Centre for Standardisation:  
Aru str 10 Tallinn 10317 Estonia; [www.evs.ee](http://www.evs.ee); Phone: +372 605 5050; E-mail: [info@evs.ee](mailto:info@evs.ee)

English version

**Tests on electric and optical fibre cables under fire conditions -  
Part 3-10: Test for vertical flame spread  
of vertically-mounted bunched wires or cables -  
Apparatus  
(IEC 60332-3-10:2000 + A1:2008)**

Essais des câbles électriques  
et des câbles à fibres optiques  
soumis au feu -  
Partie 3-10: Essai de propagation verticale  
de la flamme des fils ou câbles  
montés en nappes en position verticale -  
Appareillage  
(CEI 60332-3-10:2000 + A1:2008)

Prüfungen an Kabeln, isolierten Leitungen  
und Glasfaserkabeln im Brandfall -  
Teil 3-10: Prüfung der vertikalen  
Flammenausbreitung von vertikal  
angeordneten Bündeln von Kabeln  
und isolierten Leitungen -  
Prüfvorrichtung  
(IEC 60332-3-10:2000 + A1:2008)

This European Standard was approved by CENELEC on 2009-08-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

**CENELEC**

European Committee for Electrotechnical Standardization  
Comité Européen de Normalisation Electrotechnique  
Europäisches Komitee für Elektrotechnische Normung

**Central Secretariat: Avenue Marnix 17, B - 1000 Brussels**

## Foreword

The text of the International Standard IEC 60332-3-10:2000 and its amendment A1:2008, prepared by IEC TC 20, Electric cables, was submitted to the Unique Acceptance Procedure and was approved by CENELEC as EN 60332-3-10 on 2009-08-01 without any modification.

This European Standard supersedes EN 50266-1:2001 + corrigendum March 2002.

The following dates were fixed:

- |  |       |            |
|--|-------|------------|
| – latest date by which the EN has to be implemented at national level by publication of an identical national standard or by endorsement | (dop) | 2010-08-01 |
| – latest date by which the national standards conflicting with the EN have to be withdrawn   | (dow) | 2012-08-01 |

Annex ZA has been added by CENELEC.

---

## Endorsement notice

The text of the International Standard IEC 60332-3-10:2000 and its amendment A1:2008 was approved by CENELEC as a European Standard without any modification.

---

## Annex ZA (normative)

### Normative references to international publications with their corresponding European publications

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE Where an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60695-4	- <sup>1)</sup>	Fire hazard testing - Part 4: Terminology concerning fire tests	EN 60695-4	2006 <sup>2)</sup>
IEC Guide 104	- <sup>1)</sup>	The preparation of safety publications and the use of basic safety publications and group safety publications	-	-

---

<sup>1)</sup> Undated reference.

<sup>2)</sup> Valid edition at date of issue.

## CONTENTS

FOREWORD.....	3
INTRODUCTION.....	5
1 Scope.....	6
2 Normative references.....	6
3 Definitions .....	6
4 Test environment.....	6
5 Test apparatus .....	7
5.1 Test chamber.....	7
5.2 Air supply .....	7
5.3 Ladder types.....	7
5.4 Effluent cleaning attachment.....	7
6 Ignition source .....	8
6.1 Type.....	8
6.2 Positioning.....	9
Annex A (informative) Details of recommended burner .....	18
Annex B (informative) Flowmeter calibration correction factors .....	19
Figure 1 – Test chamber .....	11
Figure 2 – Thermal insulation of back and sides of the test chamber.....	12
Figure 3 – Positioning of burner and typical arrangement of test sample on ladder.....	13
Figure 4 – Tubular steel ladders for cable test .....	14
Figure 5 – Burner configurations.....	15
Figure 6 – Arrangement of holes for burners.....	16
Figure 7 – Schematic diagram of an example of a burner control system using rotameters.....	17

## INTRODUCTION

Parts 1 and 2 of IEC 60332 specify methods of test for flame spread characteristics for a single vertical insulated wire or cable. It cannot be assumed that, because a wire or cable meets the requirements of parts 1 and 2, a vertical bunch of similar cables or wires will behave in a similar manner. This is because flame spread along a vertical bunch of cables depends on a number of features, such as

- a) the volume of combustible material exposed to the fire and to any flame which may be produced by the combustion of the cables;
- b) the geometrical configuration of the cables and their relationship to an enclosure;
- c) the temperature at which it is possible to ignite the gases emitted from the cables;
- d) the quantity of combustible gas released from the cables for a given temperature rise;
- e) the volume of air passing through the cable installation;
- f) the construction of the cable, for example armoured or unarmoured, multi- or single-core.

All of the foregoing assume that the cables are able to be ignited when involved in an external fire.

Part 3 of IEC 60332 gives details of a test where a number of cables are bunched together to form various test sample installations. For easier use and differentiation of various test categories, the parts are designated as follows:

Part 3-10: Apparatus

Part 3-21: Category A F/R

Part 3-22: Category A

Part 3-23: Category B

Part 3-24: Category C

Part 3-25: Category D

Parts from 3-21 onwards define the various categories and the relevant procedures. The categories are distinguished by test duration, the volume of non-metallic material of the test sample and the method of mounting the sample for the test. In all categories, cables having at least one conductor of cross-sectional area greater than  $35 \text{ mm}^2$  are tested in a spaced configuration, whereas cables of conductor cross-sectional area of  $35 \text{ mm}^2$  or smaller are tested in a touching configuration.

The categories are not necessarily related to different safety levels in actual cable installations. The actual installed configuration of the cables may be a major determinant in the level of flame spread occurring in an actual fire.

The method of mounting described in category A F/R (part 3-21) is intended for special cable designs used in particular installations.

Categories A, B, C and D (parts 3-22 to 3-25 respectively) are for general use where different non-metallic volumes are applicable.

## TESTS ON ELECTRIC AND OPTICAL FIBRE CABLES UNDER FIRE CONDITIONS –

### Part 3-10: Test for vertical flame spread of vertically-mounted bunched wires or cables – Apparatus

#### 1 Scope

The series of International Standards covered by Parts 3-10, 3-21, 3-22, 3-23, 3-24 and 3-25 of IEC 60332 specifies methods of test for the assessment of vertical flame spread of vertically-mounted bunched wires or cables, electrical or optical, under defined conditions.

NOTE For the purpose of this standard the term “electric wire or cable” covers all insulated metallic conductor cables used for the conveyance of energy or signals.

This part of IEC 60332 details the apparatus and its arrangement and calibration.

#### 2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60695-4, *Fire hazard testing – Part 4: Terminology concerning fire tests*

IEC Guide 104, *The preparation of safety publications and the use of basic safety publications and group safety publications*

#### 3 Definitions

For the purpose of this part of IEC 60332 the following definition applies. The definition is taken from IEC 60695-4.

##### 3.1

##### **ignition source**

source of energy that initiates combustion

#### 4 Test environment

The test shall not be carried out if the external wind speed, measured by an anemometer fitted on the top of the test rig, is greater than 8 m/s and shall not be carried out if the temperature of the inside walls is below 5 °C or above 40 °C measured at a point approximately 1 500 mm above floor level, 50 mm from a side wall, and 1 000 mm from the door. The enclosure door shall be closed throughout the test.