

---

---

**Hydrometry — Liquid flow  
measurement using end depth method  
in channels with a free overfall**

*Hydrométrie — Mesure du débit liquide dans les chenaux à déversoir  
sans pelle*



This document is a preview generated by EBS



**COPYRIGHT PROTECTED DOCUMENT**

© ISO 2017, Published in Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office  
Ch. de Blandonnet 8 • CP 401  
CH-1214 Vernier, Geneva, Switzerland  
Tel. +41 22 749 01 11  
Fax +41 22 749 09 47  
[copyright@iso.org](mailto:copyright@iso.org)  
[www.iso.org](http://www.iso.org)

# Contents

	Page
Foreword.....	v
<b>1 Scope.....</b>	<b>1</b>
<b>2 Normative references.....</b>	<b>1</b>
<b>3 Terms and definitions.....</b>	<b>1</b>
<b>4 Symbols and abbreviated terms.....</b>	<b>2</b>
<b>5 Principle.....</b>	<b>2</b>
<b>6 Installation.....</b>	<b>2</b>
6.1 General.....	2
6.2 Selection of site.....	2
<b>7 Measurement of end depth.....</b>	<b>3</b>
7.1 General.....	3
7.2 Head measuring devices.....	3
7.3 Gauge datum.....	3
<b>8 Maintenance.....</b>	<b>3</b>
8.1 General.....	3
8.2 Types.....	4
8.3 Specifications for the drop structure.....	5
8.4 Specifications for installation.....	6
8.5 Determination of gauge zero.....	6
8.6 Discharge relationship.....	6
8.7 Coefficient of discharge.....	6
8.7.1 Confined nappe.....	6
8.7.2 Unconfined nappe.....	6
8.8 Practical limitations.....	6
8.9 Uncertainty of measurement.....	7
<b>9 Triangular channel drop structure.....</b>	<b>7</b>
9.1 Specifications for the drop structure.....	7
9.2 Specifications for installation.....	7
9.3 Specifications for head measurement.....	7
9.3.1 General.....	7
9.3.2 Determination of channel angle.....	7
9.3.3 Determination of gauge zero.....	8
9.4 Discharge formula — Unconfined.....	8
9.5 Practical limitations.....	8
9.6 Uncertainty of measurement.....	8
<b>10 Trapezoidal channel drop structure.....</b>	<b>9</b>
10.1 Specifications for the drop structure.....	9
10.2 Specifications for head measurement.....	9
10.2.1 General.....	9
10.2.2 Determination of gauge zero.....	9
10.3 Discharge formula — Unconfined.....	9
10.4 Practical limitations.....	10
10.5 Uncertainty of measurement.....	10
<b>11 Circular channel drop structure.....</b>	<b>11</b>
11.1 Specifications for the drop structure.....	11
11.2 Specifications for head measurement.....	11
11.2.1 General.....	11
11.2.2 Determination of gauge zero.....	11
11.3 Discharge formula — Unconfined.....	11
11.4 Practical limitations.....	13

11.5	Uncertainty of measurement.....	13
<b>12</b>	<b>Parabolic channel drop structure.....</b>	<b>14</b>
12.1	Specifications for the drop structure.....	14
12.2	Specifications for head measurement.....	14
12.2.1	General.....	14
12.2.2	Geometry.....	14
12.2.3	Determination of gauge zero.....	14
12.3	Discharge formula — Unconfined.....	15
12.4	Practical limitations.....	15
<b>13</b>	<b>Uncertainties of flow measurement.....</b>	<b>15</b>
13.1	General.....	15
13.2	Sources of error.....	15
13.3	Kinds of error.....	16
13.4	Uncertainties in coefficient values.....	16
13.5	Uncertainties in measurements made by the user.....	17
13.6	Combination of uncertainties to give total uncertainty on discharge.....	17
13.7	Example.....	17
	<b>Bibliography.....</b>	<b>20</b>

## Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see [www.iso.org/directives](http://www.iso.org/directives)).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see [www.iso.org/patents](http://www.iso.org/patents)).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see the following URL: [www.iso.org/iso/foreword.html](http://www.iso.org/iso/foreword.html).

This document was prepared by Technical Committee ISO/TC 113, *Hydrometry*, Subcommittee SC 2, *Flow measurement structures*.

This first edition of ISO 18481 cancels and replaces ISO 3847:1977 and ISO 4371:1984, which have been merged and technically revised.



# Hydrometry — Liquid flow measurement using end depth method in channels with a free overfall

## 1 Scope

This document specifies a method for the estimation of the sub-critical flow of clear water in a smooth, essentially horizontal channel (or a gently sloping channel), abruptly discontinued at bottom by a hydraulic structure, with a vertical drop and discharging freely. Such an overfall forms a control section and offers a means for the estimation of flow using the end depth measurement method. A wide variety of channel cross-sections with overfall have been studied, but only those which have received general acceptance after adequate research and testing, and therefore do not require in situ calibration, are considered. This document covers channels with the following types of cross-sections:

- a) rectangular with confined and unconfined nappe;
- b) trapezoidal;
- c) triangular;
- d) circular;
- e) parabolic.

The flow at the brink is curvilinear; therefore, the measured depth at the drop is not equal to the critical depth as computed by the principle based on assumption of parallel flow. However, the end depth and the critical depth (as in the case of the assumption of parallel flow) have unique relation, which is used to estimate the flow through these structures.

## 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 772, *Hydrometry — Vocabulary and symbols*

## 3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 772 apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <https://www.iso.org/obp>