
ICS 97.120

English Version

**Automatic electrical controls - Part 2-13: Particular requirements
for humidity sensing controls
(IEC 60730-2-13:2017/COR1:2018)**

Dispositifs de commande électrique automatiques à usage
domestique et analogue - Partie 2-13: Règles particulières
pour les dispositifs de commande sensibles à l'humidité
(IEC 60730-2-13:2017/COR1:2018)

Automatische elektrische Regel- und Steuergeräte für den
Hausgebrauch und ähnliche Anwendungen - Teil 2-13:
Besondere Anforderungen an feuchtigkeitsempfindliche
Regel- und Steuergeräte
(IEC 60730-2-13:2017/COR1:2018)

This corrigendum becomes effective on 13 April 2018 for incorporation in the English language version of the EN.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Endorsement notice

The text of the corrigendum IEC 60730-2-13:2017/COR1:2018 was approved by CENELEC as EN IEC 60730-2-13:2018/AC:2018-04 without any modification.

INTERNATIONAL ELECTROTECHNICAL COMMISSION

IEC 60730-2-13
Edition 3.0 2017-10

AUTOMATIC ELECTRICAL CONTROLS –

Part 2-13: Particular requirements for humidity sensing controls

CORRIGENDUM 1

Annex BB

Table BB.2

Replace the existing Table BB.2 with the following new table:

	Humidification		Dehumidification	
	Type 1	Type 2	Type 1	Type 2
Self-resetting action	6 000	100 000	30 000	100 000
Non-self-resetting action	6 000	6 000	6 000	6 000
		1 000		1 000
		5 000 a		5 000 a
a Tested without current, cycle rate may be at any convenient speed.				

Annex CC

CC.1.1

Replace, in Note 4, "Annex ZC" with "Annex CC".