EUROPEAN STANDARD

NORME EUROPÉENNE

EUROPÄISCHE NORM

EN IEC 60068-3-3:2019/AC:2021-10

October 2021

ICS 19.040

English Version

Environmental testing - Part 3-3: Supporting documentation and guidance - Seismic test methods for equipment (IEC 60068-3-3:2019/COR1:2021)

Essais d'environnement - Partie 3-3: Documentation d'accompagnement et recommandations - Méthodes d'essais sismiques applicables aux matériels (IEC 60068-3-3:2019/COR1:2021)

Umgebungseinflüsse - Teil 3-3: Unterstützende Dokumentation und Leitfaden - Seismische Prüfverfahren für Geräte (IEC 60068-3-3:2019/COR1:2021)

This corrigendum becomes effective on 15 October 2021 for incorporation in the English language version of the EN.

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Endorsement notice

The text of the corrigendum IEC 60068-3-3:2019/COR1:2021 was approved by CENELEC as EN IEC 60068-3-3:2019/AC:2021-10 without any modification.

INTERNATIONAL ELECTROTECHNICAL COMMISSION

COMMISSION ÉLECTROTECHNIQUE INTERNATIONALE

_____

IEC 60068-3-3
Edition 2.0 2019-08

ENVIRONMENTAL TESTING –

Part 3-3: Supporting documentation and guidance – Seismic test methods for equipment

IEC 60068-3-3
Édition 2.0 2019-08

ESSAIS D'ENVIRONNEMENT –

Partie 3-3: Documentation d'accompagnement et recommandations – Méthodes d'essais sismiques applicables aux matériels

CORRIGENDUM 1

Corrections to the French version appear after the English text.

Les corrections à la version française sont données après le texte anglais.

12.2.5 Ground acceleration (a_g)

In the dashed list items of the second paragraph, replace the existing peak velocity values of 0,01 m/s (zone 1), 0,02 m/s (zone 2), 0,03 m/s (zone 3) *and* 0,05 m/s (zone 4) *with the new values of* 0,1 m/s (zone 1), 0,2 m/s (zone 2), 0,3 m/s (zone 3) *and* 0,5 m/s (zone 4), *as follows*:

– peak velocity = 0,1 m/s for 0,8 ≤ f ≤ 1,6 Hz;
– peak velocity = 0,2 m/s for 0,8 ≤ f ≤ 1,6 Hz;
– peak velocity = 0,3 m/s for 0,8 ≤ f ≤ 1,6 Hz;
– peak velocity = 0,5 m/s for 0,8 ≤ f ≤ 1,6 Hz;

IEC 60068-3-3:2019-08/COR1:2021-09(en-fr)