


Corrigendum to EN 50388:2012

English version

Corrigendum to EN 50388:2012 published 2012-08-24

## 1 Modification to Figure 1

Replace Figure 1 by the following new figure:



- A** No traction
- B** Current level exceeded
- C** Allowable current levels

Corrigendum to EN 50388:2012 published 2013-04-26

## 2 Modification to 12.1.1

In the first bullet, **delete** "in the conditions described in 11.4".

Corrigendum to EN 50388:2012 published 2013-08-30

## 3 Modification to Table F.1

In Table F.1, Column: SK and Row: d.c. 3000 V, **replace** "1000 for single track line" by "1400 for single track line".