

**Elektrijuhistike torusüsteemid. Osa 25: Erinõuded.
Torukinnitid**

**Conduit systems for cable management - Part 25:
Particular requirements - Conduit fixing devices**

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 61386-25:2011 sisaldab Euroopa standardi EN 61386-25:2011 ingliskeelset teksti.	This Estonian standard EVS-EN 61386-25:2011 consists of the English text of the European standard EN 61386-25:2011.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 18.11.2011.	Date of Availability of the European standard is 18.11.2011.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 29.120.10

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:
Aru 10, 10317 Tallinn, Eesti; www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:
Aru 10, 10317 Tallinn, Estonia; www.evs.ee; phone 605 5050; e-mail info@evs.ee

**Conduit systems for cable management -
Part 25: Particular requirements -
Conduit fixing devices
(IEC 61386-25:2011)**

Systèmes de conduits pour la gestion du câblage -
Partie 25: Exigences particulières -
Dispositifs de fixation de conduit
(CEI 61386-25:2011)

Elektroinstallationsrohrsysteme für elektrische Energie und für Informationen -
Teil 25: Besondere Anforderungen für Rohrhalter
(IEC 61386-25:2011)

This European Standard was approved by CENELEC on 2011-10-27. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Management Centre: Avenue Marnix 17, B - 1000 Brussels

Foreword

The text of document 23A/635/FDIS, future edition 1 of IEC 61386-25, prepared by SC 23A, Cable management systems, of IEC TC 23, Electrical accessories was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 61386-25:2011.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2012-07-27
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2014-10-27

This standard is to be used in conjunction with EN 61386-1:2008.

The clauses of the particular requirements of this Part 25 add to or modify the corresponding clauses in Part 1. Where the text of Part 25 indicates an "addition" to or a "deletion" or a "replacement" of the relevant requirement, test specification or explanation of Part 1, these changes are made to the relevant text of Part 1, which then becomes part of the standard. Where no change is necessary, the words "This clause of Part 1 is applicable" are used in Part 25. Subclauses or figures that are additional to those in Part 1 are numbered starting from 101.

NOTE The following print types are used:

- requirements: in roman type;
- *test specifications: in italic type;*
- notes: in small roman type.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard IEC 61386-25:2011 was approved by CENELEC as a European Standard without any modification.

Annex ZA
(normative)

**Normative references to international publications
with their corresponding European publications**

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

Addition to Annex ZA of EN 61386-1:2008:

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
ISO 4287	-	Geometrical Product Specifications (GPS) - Surface texture: Profile method - Terms, definitions and surface texture parameters	EN ISO 4287	-

This document is a preview generated by EVS

CONTENTS

FOREWORD.....	3
1 Scope.....	5
2 Normative references	5
3 Terms and definitions	5
4 General requirements.....	6
5 General conditions for tests.....	6
6 Classification.....	6
7 Marking and documentation.....	7
8 Dimensions	8
9 Construction.....	8
10 Mechanical properties	8
11 Electrical properties.....	11
12 Thermal properties	11
13 Fire hazard.....	11
14 External influences	11
15 Electromagnetic compatibility	12
Annex A (normative) Classification coding for conduit fixing devices.....	16
Figure 101 – Arrangement for lateral load test with mandrel	13
Figure 102 – Arrangement for lateral load test with conduit.....	14
Figure 103 – Arrangement for axial load test.....	15
Table 2 – Upper temperature range	7
Table 101 – Lateral load for test	10

This document is a preview generated by EVS

CONDUIT SYSTEMS FOR CABLE MANAGEMENT –

Part 25: Particular requirements – Conduit fixing devices

1 Scope

This clause of Part 1 is applicable except as follows:

Replacement in the first paragraph of the words “conduit fittings” by “conduit fittings and conduit fixing devices”.

Addition at the end of the clause:

This part of IEC 61386 specifies requirements and tests for conduit fixing devices used for support and/or retention of conduit for cable management.

2 Normative references

This clause of Part 1 is applicable with the following exception:

Addition:

ISO 4287, *Geometrical Product Specifications (GPS) – Surface texture: Profile method – Terms, definitions and surface texture parameters*

3 Terms and definitions

This clause of Part 1 is applicable, except as follows:

Addition:

3.101 conduit fixing device

device designed to provide retention of conduit(s) when installed at intervals along the length of the conduit. A conduit fixing device is designed so that it can be securely fixed to a mounting surface.

3.102 metallic conduit fixing device

fixing device consisting of metal only

3.103 non-metallic conduit fixing device

fixing device consisting of non-metallic material only

3.104 composite conduit fixing device

fixing device comprising both metal and non-metallic materials