

# INTERNATIONAL STANDARD

# NORME INTERNATIONALE



**Protection against lightning –  
Part 2: Risk management**

**Protection contre la foudre –  
Partie 2: Evaluation des risques**



## THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2010 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office  
3, rue de Varembe  
CH-1211 Geneva 20  
Switzerland  
Email: [inmail@iec.ch](mailto:inmail@iec.ch)  
Web: [www.iec.ch](http://www.iec.ch)

### About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

### About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: [www.iec.ch/searchpub](http://www.iec.ch/searchpub)

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: [www.iec.ch/online\\_news/justpub](http://www.iec.ch/online_news/justpub)

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: [www.electropedia.org](http://www.electropedia.org)

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: [www.iec.ch/webstore/custserv](http://www.iec.ch/webstore/custserv)

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: [csc@iec.ch](mailto:csc@iec.ch)  
Tel.: +41 22 919 02 11  
Fax: +41 22 919 03 00

### A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

### A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

- Catalogue des publications de la CEI: [www.iec.ch/searchpub/cur\\_fut-f.htm](http://www.iec.ch/searchpub/cur_fut-f.htm)

Le Catalogue en-ligne de la CEI vous permet d'effectuer des recherches en utilisant différents critères (numéro de référence, texte, comité d'études,...). Il donne aussi des informations sur les projets et les publications retirées ou remplacées.

- Just Published CEI: [www.iec.ch/online\\_news/justpub](http://www.iec.ch/online_news/justpub)

Restez informé sur les nouvelles publications de la CEI. Just Published détaille deux fois par mois les nouvelles publications parues. Disponible en-ligne et aussi par email.

- Electropedia: [www.electropedia.org](http://www.electropedia.org)

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International en ligne.

- Service Clients: [www.iec.ch/webstore/custserv/custserv\\_entry-f.htm](http://www.iec.ch/webstore/custserv/custserv_entry-f.htm)

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions, visitez le FAQ du Service clients ou contactez-nous:

Email: [csc@iec.ch](mailto:csc@iec.ch)  
Tél.: +41 22 919 02 11  
Fax: +41 22 919 03 00



IEC 62305-2

Edition 2.0 2010-12

# INTERNATIONAL STANDARD

# NORME INTERNATIONALE



**Protection against lightning –  
Part 2: Risk management**

**Protection contre la foudre –  
Partie 2: Evaluation des risques**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

COMMISSION  
ELECTROTECHNIQUE  
INTERNATIONALE

PRICE CODE  
CODE PRIX

**XC**

ICS 29.020; 91.120.40

ISBN 978-2-88912-794-8

## CONTENTS

FOREWORD.....	6
INTRODUCTION.....	8
1 Scope.....	10
2 Normative references.....	10
3 Terms, definitions, symbols and abbreviations.....	10
3.1 Terms and definitions.....	10
3.2 Symbols and abbreviations.....	16
4 Explanation of terms.....	19
4.1 Damage and loss.....	19
4.1.1 Source of damage.....	19
4.1.2 Types of damage.....	19
4.1.3 Types of loss.....	19
4.2 Risk and risk components.....	20
4.2.1 Risk.....	20
4.2.2 Risk components for a structure due to flashes to the structure.....	21
4.2.3 Risk component for a structure due to flashes near the structure.....	21
4.2.4 Risk components for a structure due to flashes to a line connected to the structure.....	21
4.2.5 Risk component for a structure due to flashes near a line connected to the structure.....	21
4.3 Composition of risk components.....	22
5 Risk management.....	23
5.1 Basic procedure.....	23
5.2 Structure to be considered for risk assessment.....	23
5.3 Tolerable risk $R_T$ .....	24
5.4 Specific procedure to evaluate the need of protection.....	24
5.5 Procedure to evaluate the cost effectiveness of protection.....	25
5.6 Protection measures.....	27
5.7 Selection of protection measures.....	28
6 Assessment of risk components.....	28
6.1 Basic equation.....	28
6.2 Assessment of risk components due to flashes to the structure (S1).....	28
6.3 Assessment of the risk component due to flashes near the structure (S2).....	29
6.4 Assessment of risk components due to flashes to a line connected to the structure (S3).....	29
6.5 Assessment of risk component due to flashes near a line connected to the structure (S4).....	30
6.6 Summary of risk components.....	31
6.7 Partitioning of a structure in zones $Z_S$ .....	31
6.8 Partitioning of a line into sections $S_L$ .....	31
6.9 Assessment of risk components in a structure with zones $Z_S$ .....	32
6.9.1 General criteria.....	32
6.9.2 Single zone structure.....	32
6.9.3 Multi-zone structure.....	32
6.10 Cost-benefit analysis for economic loss (L4).....	33
Annex A (informative) Assessment of annual number $N$ of dangerous events.....	34
Annex B (informative) Assessment of probability $P_X$ of damage.....	42

Annex C (informative) Assessment of amount of loss $L_X$ .....	50
Annex D (informative) Evaluation of costs of loss.....	57
Annex E (informative) Case study.....	58
Bibliography.....	85
Figure 1 – Procedure for deciding the need of protection and for selecting protection measures.....	26
Figure 2 – Procedure for evaluating the cost-effectiveness of protection measures.....	27
Figure A.1 – Collection area $A_D$ of an isolated structure.....	35
Figure A.2 – Complex shaped structure.....	36
Figure A.3 – Different methods to determine the collection area for the given structure.....	37
Figure A.4 – Structure to be considered for evaluation of collection area $A_D$ .....	38
Figure A.5 – Collection areas ( $A_D$ , $A_M$ , $A_I$ , $A_L$ ).....	41
Figure E.1 – Country house.....	58
Figure E.2 – Office building.....	63
Figure E.3 – Hospital.....	70
Figure E.4 – Apartment block.....	81
Table 1 – Sources of damage, types of damage and types of loss according to the point of strike.....	20
Table 2 – Risk components to be considered for each type of loss in a structure.....	22
Table 3 – Factors influencing the risk components.....	23
Table 4 – Typical values of tolerable risk $R_T$ .....	24
Table 5 – Parameters relevant to the assessment of risk components.....	30
Table 6 – Risk components for different types of damage and source of damage.....	31
Table A.1 – Structure location factor $C_D$ .....	39
Table A.2 – Line installation factor $C_I$ .....	40
Table A.3 – Line type factor $C_T$ .....	40
Table A.4 – Line environmental factor $C_E$ .....	40
Table B.1 – Values of probability $P_{TA}$ that a flash to a structure will cause shock to living beings due to dangerous touch and step voltages.....	42
Table B.2 – Values of probability $P_B$ depending on the protection measures to reduce physical damage.....	43
Table B.3 – Value of the probability $P_{SPD}$ as a function of LPL for which SPDs are designed.....	44
Table B.4 – Values of factors $C_{LD}$ and $C_{LI}$ depending on shielding, grounding and isolation conditions.....	44
Table B.5 – Value of factor $K_{S3}$ depending on internal wiring.....	46
Table B.6 – Values of probability $P_{TU}$ that a flash to an entering line will cause shock to living beings due to dangerous touch voltages.....	47
Table B.7 – Value of the probability $P_{EB}$ as a function of LPL for which SPDs are designed.....	47
Table B.8 – Values of the probability $P_{LD}$ depending on the resistance $R_S$ of the cable screen and the impulse withstand voltage $U_W$ of the equipment.....	47
Table B.9 – Values of the probability $P_{LI}$ depending on the line type and the impulse withstand voltage $U_W$ of the equipment.....	49

Table C.1 – Type of loss L1: Loss values for each zone.....	51
Table C.2 – Type of loss L1: Typical mean values of $L_T$ , $L_F$ and $L_O$ .....	51
Table C.3 – Reduction factor $r_t$ as a function of the type of surface of soil or floor .....	52
Table C.4 – Reduction factor $r_p$ as a function of provisions taken to reduce the consequences of fire.....	52
Table C.5 – Reduction factor $r_f$ as a function of risk of fire or explosion of structure .....	52
Table C.6 – Factor $h_z$ increasing the relative amount of loss in presence of a special hazard .....	53
Table C.7 – Type of loss L2: Loss values for each zone.....	53
Table C.8 – Type of loss L2: Typical mean values of $L_F$ and $L_O$ .....	54
Table C.9 – Type of loss L3: Loss values for each zone.....	54
Table C.10 – Type of loss L3: Typical mean value of $L_F$ .....	54
Table C.11 – Type of loss L4: Loss values for each zone.....	55
Table C.12 – Type of loss L4: Typical mean values of $L_T$ , $L_F$ and $L_O$ .....	56
Table E.1 – Country house: Environment and structure characteristics .....	59
Table E.2 – Country house: Power line .....	59
Table E.3 – Country house: Telecom line (TLC).....	59
Table E.4 – Country house: Factors valid for zone $Z_2$ (inside the building).....	60
Table E.5 – Country house: Collection areas of structure and lines.....	61
Table E.6 – Country house: Expected annual number of dangerous events .....	61
Table E.7 – Country house: Risk $R_1$ for the unprotected structure (values $\times 10^{-5}$ ) .....	62
Table E.8 – Country house: Risk components relevant to risk $R_1$ for protected structure.....	62
Table E.9 – Office building: Environment and structure characteristics .....	63
Table E.10 – Office building: Power line.....	64
Table E.11 – Office building: Telecom line .....	64
Table E.12 – Office building: Distribution of persons into zones .....	65
Table E.13 – Office building: Factors valid for zone $Z_1$ (entrance area outside).....	66
Table E.14 – Office building: Factors valid for zone $Z_2$ (garden outside) .....	66
Table E.15 – Office building: Factors valid for zone $Z_3$ (archive).....	67
Table E.16 – Office building: Factors valid for zone $Z_4$ (offices) .....	67
Table E.17 – Office building: Factors valid for zone $Z_5$ (computer centre) .....	67
Table E.18 – Office building: Collection areas of structure and lines .....	68
Table E.19 – Office building: Expected annual number of dangerous events.....	68
Table E.20 – Office building: Risk $R_1$ for the unprotected structure (values $\times 10^{-5}$ ).....	69
Table E.21 – Office building: Risk $R_1$ for the protected structure (values $\times 10^{-5}$ ).....	70
Table E.22 – Hospital: Environment and global structure characteristics.....	70
Table E.23 – Hospital: Power line .....	71
Table E.24 – Hospital: Telecom line.....	71
Table E.25 – Hospital: Distribution of persons and of economic values into zones .....	72
Table E.26 – Hospital: Factors valid for zone $Z_1$ (outside the building).....	73
Table E.27 – Hospital: Factors valid for zone $Z_2$ (rooms block) .....	73
Table E.28 – Hospital: Factors valid for zone $Z_3$ (operating block) .....	74
Table E.29 – Hospital: Factors valid for zone $Z_4$ (intensive care unit).....	75
Table E.30 – Hospital: Collection areas of structure and lines .....	75

Table E.31 – Hospital: Expected annual number of dangerous events .....	76
Table E.32 – Hospital: Risk $R_1$ – Values of probability $P$ for the unprotected structure .....	76
Table E.33 – Hospital: Risk $R_1$ for the unprotected structure (values $\times 10^{-5}$ ) .....	77
Table E.34 – Hospital: Risk $R_1$ for the protected structure according to solution a) (values $\times 10^{-5}$ ) .....	78
Table E.35 – Hospital: Risk $R_1$ for the protected structure according to solution b) (values $\times 10^{-5}$ ) .....	78
Table E.36 – Hospital: Risk $R_1$ for the protected structure according to solution c) (values $\times 10^{-5}$ ) .....	79
Table E.37 – Hospital: Cost of loss $C_L$ (unprotected) and $C_{RL}$ (protected).....	79
Table E.38 – Hospital: Rates relevant to the protection measures.....	80
Table E.39 – Hospital: Cost $C_P$ and $C_{PM}$ of protection measures (values in \$) .....	80
Table E.40 – Hospital: Annual saving of money (values in \$) .....	80
Table E.41 – Apartment block: Environment and global structure characteristics .....	81
Table E.42 – Apartment block: Power line.....	81
Table E.43 – Apartment block: Telecom line .....	82
Table E.44 – Apartment block: Factors valid for zone $Z_2$ (inside the building) .....	83
Table E.45 – Apartment block: Risk $R_1$ for the apartment block depending on protection measures .....	84

preview generated by EVS

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

**PROTECTION AGAINST LIGHTNING –****Part 2: Risk management**

## FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62305-2 has been prepared by IEC technical committee 81: Lightning protection.

This second edition cancels and replaces the first edition, published in 2006, and constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- 1) Risk assessment for services connected to structures is excluded from the scope.
- 2) Injuries of living beings caused by electric shock inside the structure are considered.
- 3) Tolerable risk of loss of cultural heritage is lowered from  $10^{-3}$  to  $10^{-4}$ . The value of tolerable risk of loss of economic value ( $R_T = 10^{-3}$ ) is introduced, to be used when data for cost/benefit analysis are not available.
- 4) Extended damage to surroundings structures or to the environment is considered.
- 5) Improved equations are provided for evaluation of

- collection areas relevant to flashes nearby a structure,
- collection areas relevant to flashes to and nearby a line,
- probabilities that a flash can cause damage,
- loss factors even in structures with risk of explosion,
- risk relevant to a zone of a structure,
- cost of loss.

6) Tables are provided to select the relative amount of loss in all cases.

7) Impulse withstand voltage level of equipments was extended down to 1 kV.

This bilingual version corresponds to the monolingual English version, published in 2010-12.

The text of this standard is based on the following documents:

FDIS	Report on voting
81/371/FDIS	81/381/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

The French version of this standard has not been voted upon.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all the parts in the IEC 62305 series, under the general title *Protection against lightning*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

**IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.**

## INTRODUCTION

Lightning flashes to earth may be hazardous to structures and to lines.

The hazard to a structure can result in

- damage to the structure and to its contents,
- failure of associated electrical and electronic systems,
- injury to living beings in or close to the structure.

Consequential effects of the damage and failures may be extended to the surroundings of the structure or may involve its environment.

To reduce the loss due to lightning, protection measures may be required. Whether they are needed, and to what extent, should be determined by risk assessment.

The risk, defined in this part of IEC 62305 as the probable average annual loss in a structure due to lightning flashes, depends on:

- the annual number of lightning flashes influencing the structure;
- the probability of damage by one of the influencing lightning flashes;
- the mean amount of consequential loss.

Lightning flashes influencing the structure may be divided into

- flashes terminating on the structure,
- flashes terminating near the structure, direct to connected lines (power, telecommunication lines,) or near the lines.

Flashes to the structure or a connected line may cause physical damage and life hazards. Flashes near the structure or line as well as flashes to the structure or line may cause failure of electrical and electronic systems due to overvoltages resulting from resistive and inductive coupling of these systems with the lightning current.

Moreover, failures caused by lightning overvoltages in users' installations and in power supply lines may also generate switching type overvoltages in the installations.

NOTE Malfunctioning of electrical and electronic systems is not covered by the IEC 62305 series. Reference should be made to IEC 61000-4-5<sup>[1]</sup>.

The number of lightning flashes influencing the structure depends on the dimensions and the characteristics of the structure and of the connected lines, on the environmental characteristics of the structure and the lines, as well as on lightning ground flash density in the region where the structure and the lines are located.

The probability of lightning damage depends on the structure, the connected lines and the lightning current characteristics, as well as on the type and efficiency of applied protection measures.

The annual mean amount of the consequential loss depends on the extent of damage and the consequential effects which may occur as a result of a lightning flash.

The effect of protection measures results from the features of each protection measure and may reduce the damage probabilities or the amount of consequential loss.

---

<sup>1</sup> Figures in square brackets refer to the bibliography.

The decision to provide lightning protection may be taken regardless of the outcome of risk assessment where there is a desire that there be no avoidable risk.

This document is a preview generated by EVS

## PROTECTION AGAINST LIGHTNING –

### Part 2: Risk management

#### 1 Scope

This part of IEC 62305 is applicable to risk assessment for a structure due to lightning flashes to earth.

Its purpose is to provide a procedure for the evaluation of such a risk. Once an upper tolerable limit for the risk has been selected, this procedure allows the selection of appropriate protection measures to be adopted to reduce the risk to or below the tolerable limit.

#### 2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 62305-1:2010, *Protection against lightning – Part 1: General principles*

IEC 62305-3:2010, *Protection against lightning – Part 3: Physical damage to structures and life hazard*

IEC 62305-4:2010, *Protection against lightning – Part 4: Electrical and electronic systems within structures*

#### 3 Terms, definitions, symbols and abbreviations

For the purposes of this document, the following terms, definitions, symbols and abbreviations, some of which have already been cited in Part 1 but are repeated here for ease of reading, as well as those given in other parts of IEC 62305, apply.

##### 3.1 Terms and definitions

###### 3.1.1

###### **structure to be protected**

structure for which protection is required against the effects of lightning in accordance with this standard

NOTE A structure to be protected may be part of a larger structure.

###### 3.1.2

###### **structures with risk of explosion**

structures containing solid explosives materials or hazardous zones as determined in accordance with IEC 60079-10-1<sup>[2]</sup> and IEC 60079-10-2<sup>[3]</sup>

###### 3.1.3

###### **structures dangerous to the environment**

structures which may cause biological, chemical or radioactive emission as a consequence of lightning (such as chemical, petrochemical, nuclear plants, etc.)