

CONSOLIDATED VERSION

VERSION CONSOLIDÉE



INTERNATIONAL SPECIAL COMMITTEE ON RADIO INTERFERENCE
COMITÉ INTERNATIONAL SPÉCIAL DES PERTURBATIONS RADIOÉLECTRIQUES

Industrial, scientific and medical equipment – Radio-frequency disturbance characteristics – Limits and methods of measurement

Appareils industriels, scientifiques et médicaux – Caractéristiques de perturbations radioélectriques – Limites et méthodes de mesure



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2019 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 000 terminological entries in English and French, with equivalent terms in 16 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

67 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Recherche de publications IEC - webstore.iec.ch/advsearchform

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et une fois par mois par email.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: sales@iec.ch.

Electropedia - www.electropedia.org

Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22 000 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 16 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Glossaire IEC - std.iec.ch/glossary

67 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.

CONSOLIDATED VERSION

VERSION CONSOLIDÉE



INTERNATIONAL SPECIAL COMMITTEE ON RADIO INTERFERENCE
COMITÉ INTERNATIONAL SPÉCIAL DES PERTURBATIONS RADIOÉLECTRIQUES

Industrial, scientific and medical equipment – Radio-frequency disturbance characteristics – Limits and methods of measurement

Appareils industriels, scientifiques et médicaux – Caractéristiques de perturbations radioélectriques – Limites et méthodes de mesure

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 33.100.10

ISBN 978-2-8322-6461-4

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

REDLINE VERSION

VERSION REDLINE



INTERNATIONAL SPECIAL COMMITTEE ON RADIO INTERFERENCE
COMITÉ INTERNATIONAL SPÉCIAL DES PERTURBATIONS RADIOÉLECTRIQUES

Industrial, scientific and medical equipment – Radio-frequency disturbance characteristics – Limits and methods of measurement

Appareils industriels, scientifiques et médicaux – Caractéristiques de perturbations radioélectriques – Limites et méthodes de mesure

CONTENTS

FOREWORD.....	8
INTRODUCTION.....	11
Introduction to Amendment 1	12
Introduction to the Amendment 2	12
1 Scope.....	15
2 Normative references	15
3 Terms and definitions	16
4 Frequencies designated for ISM use.....	19
5 Classification of equipment.....	20
5.1 Separation into groups.....	20
5.2 Division into classes	20
5.3 Documentation for the user	21
6 Limits of electromagnetic disturbances	21
6.1 General.....	21
6.2 Group 1 equipment measured on a test site	22
6.2.1 Limits for conducted disturbances.....	22
6.2.2 Limits of electromagnetic radiation disturbance.....	25
6.3 Group 2 equipment measured on a test site	28
6.3.1 Limits for conducted disturbances.....	28
6.3.2 Limits of electromagnetic radiation disturbance.....	29
6.4 Group 1 and group 2 class A equipment measured in situ	36
6.4.1 Limits for conducted disturbances.....	36
6.4.2 Limits of electromagnetic radiation disturbance.....	36
7 Measurement requirements	39
7.1 General.....	39
7.2 Ambient noise	39
7.3 Measuring equipment.....	40
7.3.1 Measuring instruments.....	40
7.3.2 Artificial network (AN)	40
7.3.3 Voltage probe	41
7.3.4 Antennas	41
7.3.5 Artificial hand	42
7.4 Frequency measurement.....	43
7.5 Configuration of equipment under test.....	43
7.5.1 General	43
7.5.2 Interconnecting cables.....	47
7.5.3 Connection to the electricity supply network on a test site	48
7.6 Load conditions of equipment under test.....	50
7.6.1 General	50
7.6.2 Medical equipment.....	50
7.6.3 Industrial equipment	52
7.6.4 Scientific, laboratory and measuring equipment.....	52
7.6.5 Microwave cooking appliances.....	52
7.6.6 Other equipment in the frequency range 1 GHz to 18 GHz.....	52
7.6.7 Electric welding equipment	53

7.6.8	ISM RF lighting equipment.....	53
7.6.9	Medium voltage (MV) and high voltage (HV) switchgear	53
7.6.10	Grid connected power converters	53
7.7	Recording of test-site measurement results	54
7.7.1	General	54
7.7.2	Conducted emissions.....	54
7.7.3	Radiated emissions	54
8	Special provisions for test site measurements (9 kHz to 1 GHz)	54
8.1	Ground planes	54
8.2	Measurement of conducted disturbances	55
8.2.1	General	55
8.2.2	Measurements on grid connected power converters.....	55
8.2.3	Handheld equipment which are normally operated without an earth connection	60
8.3	Radiation test sites for OATS and SAC for measurements in the range 9 kHz to 1 GHz	60
8.3.1	General	60
8.3.2	Validation of the radiation test site (9 kHz to 1 GHz).....	61
8.3.3	Disposition of equipment under test (9 kHz to 1 GHz).....	61
8.3.4	Radiation measurements (9 kHz to 1 GHz)	62
8.4	Alternative radiation test sites for the frequency range 30 MHz to 1 GHz	62
8.5	FAR for measurements in the range 30 MHz to 1 GHz	62
9	Radiation measurements: 1 GHz to 18 GHz.....	63
9.1	Test arrangement.....	63
9.2	Receiving antenna	63
9.3	Validation and calibration of test site.....	63
9.4	Measuring procedure	63
9.4.1	General	63
9.4.2	Operating conditions of the EUT	64
9.4.3	Preliminary Peak measurements.....	65
9.4.4	Final Weighted measurements.....	66
10	Measurement <i>in situ</i>	69
11	Safety precautions for emission measurements on ISM RF equipment	69
12	Measurement uncertainty	69
	Annex A (informative) Examples of equipment classification	71
	Annex B (informative) Precautions to be taken in the use of a spectrum analyzer (see 7.3.1).....	73
	Annex C (normative) Measurement of electromagnetic radiation disturbance in the presence of signals from radio transmitters.....	74
	Annex D (informative) Propagation of interference from industrial radio-frequency equipment at frequencies between 30 MHz and 300 MHz	75
	Annex E (informative) Recommendations of CISPR for protection of certain radio services in particular areas	76
E.1	General.....	76
E.2	Recommendations for protection of safety-related radio services	76
E.3	Recommendations for protection of specific sensitive radio services	76
	Annex F (informative) Frequency bands allocated for safety-related radio services.....	77
	Annex G (informative) Frequency bands allocated for sensitive radio services.....	78

Annex H (informative) Statistical assessment of series produced equipment against the requirements of CISPR standards	80
H.1 Significance of a CISPR limit	80
H.2 Type tests	80
H.3 Statistical assessment of series produced equipment.....	80
H.3.1 Assessment based on a general margin to the limit	80
H.3.2 Assessment based on the non-central <i>t</i> -distribution	81
H.3.3 Assessment based on the binomial distribution.....	83
H.3.4 Equipment produced on an individual basis	84
Annex I (normative) Artificial Network (AN) for the assessment of disturbance voltages at d.c. power ports of semiconductor power converters	85
I.1 General information and purpose	85
I.2 Structures for a DC-AN	85
I.2.1 AN suitable for measurement of unsymmetrical mode (UM) disturbances	85
I.2.2 AN suitable for measurement of common mode (CM) and differential mode (DM) disturbances.....	85
I.2.3 AN suitable for measurement of UM, CM and DM disturbances	86
I.3 Employment of DC-ANs for compliance measurements	86
I.3.1 General	86
I.3.2 Pseudo V-AN.....	86
I.3.3 Delta-AN.....	86
I.4 Normative technical requirements for the DC-AN	87
I.4.1 Parameters and associated tolerances in the range 150 kHz to 30 MHz	87
I.4.2 Parameters and associated tolerances in the range 9 kHz to 150 kHz	88
I.5 Examples of practical implementations of DC-ANs	88
Annex J (informative) Measurements on Grid Connected Power Converters (GCPC) – Setups for an effective test site configuration.....	91
J.1 General information and purpose	91
J.2 Setup of the test site	91
J.2.1 Block diagram of test site	91
J.2.2 DC power supply	92
J.2.3 AC power source	92
J.2.4 Other components	93
J.3 Other test setups	93
J.3.1 Configuration comprising laboratory AC power source and resistive load.....	93
J.3.2 Configuration in case of reverse power flow to the AC mains	94
Annex K (informative) Test site configuration and instrumentation – Guidance on prevention of saturation effects in mitigation filters of transformer-less power converters during type tests according to this standard.....	96
K.1 General information and purpose	96
K.2 Recommendations for avoidance of saturation effects in the range 9 kHz to 150 kHz	97
K.3 Detailed advice	97
K.3.1 General	97
K.3.2 Insert of series inductors (or common mode chokes) in the laboratory's d.c. power supply chain	98
K.3.3 Employment of additional common mode decoupling capacitors at the interface between the AE port of the DC-AN and the laboratory d.c. power supply port allocated in the test environment.....	99

K.4	Background information	100
	Bibliography.....	102
	Figure 1 – Circuit for disturbance voltage measurements on mains supply.....	41
	Figure 2 – Artificial hand, RC element.....	43
	Figure 3 – Example for a typical cable arrangement for measurements of radiated disturbances in 3 m separation distance, Table-top EUT.....	45
	Figure 4 – Example for a typical test set up for measurement of conducted and/or radiated disturbances from a floor standing EUT, 3D view	46
	Figure 5 – Disposition of medical (capacitive type) and dummy load	51
	Figure 6 – Typical arrangement for measurement of conducted disturbances at LV d.c. power ports with the DC-AN used as termination and decoupling unit to the laboratory d.c. power source	57
	Figure 7 – Typical arrangement for measurement of conducted disturbances at LV d.c. power ports with the DC-AN used as termination and voltage probe	58
	Figure 8 – Typical arrangement for measurement of conducted disturbances at LV d.c. power ports with the DC-AN used as voltage probe and with a current probe – 2D diagram	59
	Figure 9 – Typical arrangement for measurement of conducted disturbances at LV d.c. power ports with a DC-AN used as voltage probe and with a current probe – 3D diagram	59
	Figure 10 – Test site	61
	Figure 11 – Minimum size of metal ground plane	61
	Figure 12 – Decision tree for the measurement of emissions from 1 GHz to 18 GHz of group 2 equipment operating at frequencies above 400 MHz	64
	Figure H.1 – An example of possible difficulties	83
	Figure I.1 – Practical implementation of a 150 Ω DC-AN suitable for measurement of UM disturbances (Example)	88
	Figure I.2 – Practical implementation of a 150 Ω DC-AN suitable for measurement of CM and DM disturbances (Example, see also Figure A.2 in CISPR 16-1-2:2014).....	89
	Figure I.3 – Practical implementation of a 150 Ω DC-AN suitable for measurement of UM, or CM and DM disturbances (Example 1).....	89
	Figure I.4 – Practical implementation of a 150 Ω DC-AN suitable for measurement of UM, or CM and DM disturbances (Example 2).....	90
	Figure I.5 – Practical implementation of a 150 Ω DC-AN suitable for measurement of UM, or CM and DM disturbances (Example 3).....	90
	Figure J.1 – Setup of the test site (Case 1) – 2D diagram	91
	Figure J.2 – Setup of the test site (Case 1) – 3D diagram	92
	Figure J.3 – Setup of the test site (Case 2) – 2D diagram	93
	Figure J.4 – Setup of the test site (Case 2) – 3D diagram	94
	Figure J.5 – Setup of the test site (Case 3) – 2D diagram	95
	Figure J.6 – Setup of the test site (Case 3) – 3D diagram	95
	Figure K.1 – Flow of the common mode RF current at test site configuration level	98
	Figure K.2 – Blocking of flow of common mode RF current by insert of series inductors.....	99
	Figure K.3 – Blocking of flow of common mode RF current by employment of additional CM decoupling capacitors.....	99
	Figure K.4 – CM termination impedance at the EUT port of a DC-AN – Magnitude-versus-frequency characteristic in the range 3 kHz to 30 MHz, Example	100

Figure K.5 – Prevention of saturation of mitigation filters by use of additional decoupling capacitors	101
Figure K.6 – Change in the resonant frequency caused by the increase and decrease in the decoupling capacitor's capacitance	101
Figure K.7 – DC-AN circuit example where capacitance of blocking capacitors of the LC decoupling circuit can be increased or decreased.....	101
Table 1 – Frequencies in the radio-frequency (RF) range designated by ITU for use as fundamental ISM frequencies.....	20
Table 2 – Disturbance voltage limits for class A group 1 equipment measured on a test site (a.c. mains power port).....	23
Table 3 – Limits for conducted disturbances of class A group 1 equipment measured on a test site (d.c. power port)	24
Table 4 – Disturbance voltage limits for class B group 1 equipment measured on a test site (a.c. mains power port).....	24
Table 5 – Disturbance voltage limits for class B group 1 equipment measured on a test site (d.c. power port).....	25
Table 6 – Electromagnetic radiation disturbance limits for class A group 1 equipment measured on a test site.....	27
Table 7 – Electromagnetic radiation disturbance limits for class B group 1 equipment measured on a test site.....	27
Table 8 – Disturbance voltage limits for class A group 2 equipment measured on a test site (a.c. mains power port).....	29
Table 9 – Disturbance voltage limits for class B group 2 equipment measured on a test site (a.c. mains power port).....	29
Table 10 – Electromagnetic radiation disturbance limits for class A group 2 equipment measured on a test site.....	31
Table 11 – Electromagnetic radiation disturbance limits for class A EDM and arc welding equipment measured on a test site.....	32
Table 12 – Electromagnetic radiation disturbance limits for class B group 2 equipment measured on a test site.....	33
Table 13 – Electromagnetic radiation disturbance peak limits for group 2 equipment operating at frequencies above 400 MHz	34
Table 14 – Electromagnetic radiation disturbance weighted limits for group 2 equipment operating at frequencies above 400 MHz	35
Table 15 – Electromagnetic radiation disturbance APD level corresponding to 10^{-1} limits for class B group 2 equipment operating at frequencies above 400 MHz.....	36
Table 16 – Electromagnetic radiation disturbance limits for class A group 1 equipment measured <i>in situ</i>	37
Table 17 – Electromagnetic radiation disturbance limits for class A group 2 equipment measured <i>in situ</i>	38
Table 18 – Frequency sub-ranges to be used for weighted measurements.....
Table 19 – Applicability of measurements at d.c. power ports	25
Table 20 – Frequency sub-ranges to be used for weighted measurements.....	68
Table E.1 – Limits for electromagnetic radiation disturbances for <i>in situ</i> measurements to protect specific safety-related radio services in particular areas.....	76
Table H.1 – General margin to the limit for statistical evaluation	81
Table H.2 – The non-central <i>t</i> -distribution factor <i>k</i> as a function of the sample size <i>n</i>	82
Table H.3 – Application of the binomial distribution	84

Table I.1 – Parameters and associated tolerances in the range 150 kHz to 30 MHz 87
Table I.2 – Parameters and associated tolerances in the range 9 kHz to 150 kHz 88

This document is a preview generated by EVS

INTERNATIONAL ELECTROTECHNICAL COMMISSION

INTERNATIONAL SPECIAL COMMITTEE ON RADIO INTERFERENCE

INDUSTRIAL, SCIENTIFIC AND MEDICAL EQUIPMENT – RADIO-FREQUENCY DISTURBANCE CHARACTERISTICS – LIMITS AND METHODS OF MEASUREMENT

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

DISCLAIMER

This Consolidated version is not an official IEC Standard and has been prepared for user convenience. Only the current versions of the standard and its amendment(s) are to be considered the official documents.

This Consolidated version of CISPR 11 bears the edition number 6.2. It consists of the sixth edition (2015-06) [documents CISPR/B/628/FDIS and CISPR/B/631/RVD], its amendment 1 (2016-06) [documents CISPR/B/627/CDV and CISPR/B/639A/RVC] and its amendment 2 (2019-01) [documents CIS/B/715A/FDIS and CIS/B/719/RVD]. The technical content is identical to the base edition and its amendments.

In this Redline version, a vertical line in the margin shows where the technical content is modified by amendments 1 and 2. Additions are in green text, deletions are in strikethrough red text. A separate Final version with all changes accepted is available in this publication.

International Standard CISPR 11 has been prepared by CISPR Subcommittee B: Interference relating to industrial, scientific and medical radio-frequency apparatus, to other (heavy) industrial equipment, to overhead power lines, to high voltage equipment and to electric traction.

This sixth edition introduces and permits type testing on components of power electronic equipment, systems and installations. Its emission limits apply now to low voltage (LV) a.c. and d.c. power ports, irrespective of the direction of power transmission. Several limits were adapted to the practical test conditions found at test sites. They are also applicable now to power electronic ISM RF equipment used for wireless power transfer (WPT), for instant power supply and charging purposes. The limits in the range 1 GHz to 18 GHz apply now to CW-type disturbances and to fluctuating disturbances in a similar, uniform and technology-neutral way. For these measurements, two alternative methods of measurement are available, the traditional log-AV method and the new APD method.

For measurements at LV d.c. power ports of power electronic equipment, a modern implementation of the 150 Ω Delta-network specified in CISPR 16-1-2 has been made available.

This International Standard CISPR 11 has the status of a Product Family EMC standard in accordance with IEC Guide 107, *Electromagnetic compatibility – Guide to the drafting of electromagnetic compatibility publications (2014)*.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of the base publication and its amendments will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

The main content of this standard is based on CISPR Recommendation No. 39/2 given below:

RECOMMENDATION No. 39/2

Limits and methods of measurement of electromagnetic disturbance characteristics of industrial, scientific and medical (ISM) radio-frequency equipment

The CISPR

CONSIDERING

- a) that ISM RF equipment is an important source of disturbance;
- b) that methods of measuring such disturbances have been prescribed by the CISPR;
- c) that certain frequencies are designated by the International Telecommunication Union (ITU) for unrestricted radiation from ISM equipment,

RECOMMENDS

that the latest edition of CISPR 11 be used for the application of limits and methods of measurement of ISM equipment.

This document is a preview generated by EVS

INTRODUCTION

This CISPR publication contains, amongst common requirements for the control of RF disturbances from equipment intended for use in industrial, scientific, and medical electrical applications, specific requirements for the control of RF disturbances caused by ISM RF applications in the meaning of the definition of the International Telecommunication Union (ITU), see also Definition 3.13 in this International Standard. CISPR and ITU share their responsibility for the protection of radio services in respect of the use of ISM RF applications.

The CISPR is concerned with the control of RF disturbances from ISM RF applications by means of an assessment of these disturbances either at a standardised test site or, for an individual ISM RF application which cannot be tested at such a site, at its place of operation. Consequently, this CISPR Publication covers requirements for conformity assessment of both, equipment assessed by means of type tests at standardised test sites or of individual equipment under in situ conditions.

The ITU is concerned with the control of RF disturbances from ISM RF applications during normal operation and use of the respective equipment at its place of operation (see Definition 1.15 in the ITU Radio Regulations). There, use of radio-frequency energy decoupled from the ISM RF application by radiation, induction or capacitive coupling is restricted to the location of that individual application.

This CISPR publication contains, in 6.3, the essential emission requirements for an assessment of RF disturbances from ISM RF applications at standardised test sites. These requirements allow for type testing of ISM RF applications operated at frequencies up to 18 GHz. It further contains, in 6.4, the essential emission requirements for an in situ assessment of RF disturbances from individual ISM RF applications in the frequency range up to 1 GHz. All requirements were established in close collaboration with the ITU and enjoy approval of the ITU.

However, for operation and use of several types of ISM RF applications the manufacturer, installer and/or customer should be aware of additional national provisions regarding possible licensing and particular protection needs of local radio services and applications. Depending on the country concerned, such additional provisions may apply to individual ISM RF applications operated at frequencies outside designated ISM bands (see Table 1). They also may apply to ISM RF applications operated at frequencies above 18 GHz. For the latter type of applications, local protection of radio services and appliances requires an accomplishment of the conformity assessment by application of the relevant national provisions in the frequency range above 18 GHz in accordance with vested interests of the ITU and national administrations. These additional national provisions may apply to spurious emissions, emissions appearing at harmonics of the operation frequency, and to wanted emissions at the operation frequency allocated outside a designated ISM band in the frequency range above 18 GHz.

Recommendations of CISPR for the protection of radio services in particular areas are found in Annex E of this International Standard.

Definition 1.15 of the ITU Radio Regulations reads as follows:

1.15 *industrial, scientific and medical (ISM) applications (of radio frequency energy):* Operation of equipment or appliances designed to generate and use locally radio frequency energy for industrial, scientific, medical, domestic or similar purposes, excluding applications in the field of telecommunications.

[ITU Radio Regulations Volume 1: 2012 – Chapter I, Definition 1.15]

Introduction to Amendment 1

This Amendment introduces the fully-anechoic room (FAR) for measurements of the disturbance field strength in the range 30 MHz to 1 GHz on equipment in the scope of CISPR 11.

It contains the complete set of requirements for measurement of radiated disturbances from equipment fitting into the validated test volume of a given FAR. It specifies a separation distance of 3 m and restricts use of the FAR to measurements on table-top equipment.

At the moment the FAR can be used:

- for measurements on table-top equipment fitting into the validated test volume of the given FAR,
- for a separation distance of 3 m only, and
- if the FAR was validated according to CISPR 16-1-4.

The limits for class A and class B group 1 equipment in this CDV base on the limits in the generic emission standards IEC 61000-6-3:2006/AMD 1 (2010) and IEC 61000-6-4:2006/AMD 1 (2010). The limits for class A and class B group 2 equipment were derived using the same approximation formula as used when deriving the limits for the generic emission standards in mid of the years 2000 to 2010. CISPR/H/104/INF, published in 2005, gives detailed explanations how these limits for the FAR were derived.

More detailed background information is still found in CISPR/B/627/CDV.

CISPR/B WG1 in October 2015

Introduction to the Amendment 2

This AMD 2 combines the contents of two fragments which have been circulated as CIS/B/688/CDV (f2) and CIS/B/697/CDV (f3).

Fragment 2: Requirements for semiconductor power converters (SPC)

CISPR 11 Ed. 6.1 needs to be supplemented with further information for full inclusion of type test requirements for SPCs specified hereafter. These requirements apply only to the following types of equipment:

- a) power conversion equipment intended for assembly into photovoltaic power generating systems, such as grid connected power converters (GCPCs) and d.c. to d.c. converters,
- b) GCPCs intended for assembly into energy storage systems.

Fragment 3: Improvement of repeatability for measurements in the frequency range 1-18 GHz

Based on the comments from the National Committees on CIS/B/662/DC, CIS/B/WG1 decided on its meeting in Hangzhou 2016 to amend the test procedure for group 2 equipment in the frequency range 1 to 18 GHz for the following reasons:

- a) CISPR 11 allows final measurements on group 2 equipment operating at frequencies above 400 MHz with two different weighting functions, the traditional "LogAV detector" with a video bandwidth of 10 Hz and the new APD method, where the Amplitude Probability Distribution is evaluated.

With the alignment of emission requirements for sources of fluctuating emissions with those generating CW-type emissions (Fraction 4 of the last general maintenance of CISPR 11) for

most of the frequency range 1 to 18 GHz the peak detector is used mostly for preliminary measurements, while the number of final measurements with the LogAV detector has been increased from 2 frequencies to max. 7 frequencies.

In parallel, with fraction 3, the APD detector has been introduced, but only with the traditional 2 final frequencies (one in the range 1 GHz to 2.4 GHz and one in the range 2,5 GHz to 18 GHz).

The number of final frequencies to be measured should be aligned for both weighting functions.

- b) During practical measurements cases have been observed, where the critical frequency changed between preliminary and final measurement by more than 5 MHz. The range of 10 MHz for weighted measurements (± 5 MHz from highest peak emission) seems therefore not always to be sufficient.

An extension of this frequency range seems advisable and could increase the repeatability.

In the range 11,7 to 12,7 GHz, an EUT fails immediately if one peak exceeds the limit of 73 dB[μ V/m]. Observations on a big number of different microwave ovens have shown that during the final measurement (at least 2 min) such peaks may occur very seldom, and with a very short duration, and an estimated overall duration of less than 1 % of the measuring time.

A state-of-the-art digital communication service should be able to tolerate such peaks. Meanwhile, in countries where broadcasting systems, which are already standardized and widely spread and is difficult to avoid disturbance by such peaks, are under operation, additional limits could be separately introduced as necessary.

- c) The repeatability of the peak measurement on microwave ovens is poor. Moreover, the sheer height of the highest peak emission, without information on its duration and repetition rate, provides very limited information on the real disturbance potential.

Measurements with both of the weighting methods have a significantly better repeatability and should, by their physical nature, give a better judgement for the disturbing potential of the EUT on digital radio services.

- d) The conditions for preliminary and final measurements became ambiguous in Edition 6.0 (CISPR 11:2015), particularly regarding the required test time. Furthermore, it has been found that, in some cases, a duration of 20 s for the preliminary peak measurement may not be enough. To further increase the repeatability, WG1 decided not to divide the peak measurements anymore into preliminary and final measurements, but to require a 2-minute max hold peak measurement at every azimuth.

CISPR SC/B WG1 agreed to present the following proposals to the National Committees:

- 1) Define the same 7 final frequency ranges for the APD method as already defined for the LogAV method (detector).
- 2) Extend the frequency range for the final weighted measurement to 20 MHz.

For the APD method this would mean to measure on 5 final frequencies, the critical frequency itself, ± 5 MHz and ± 10 MHz.

For the LogAV detector, the requirement remains to perform for the final measurements at least 5 consecutive sweeps in max hold mode. The test time increases accordingly, and coverage of the fluctuations is the same as before.

- 3) Change the peak limit in Table 13 to a constant value of 70 dB[μ V/m] throughout the frequency range and replace the requirement of a final peak measurement in the range 11,7 GHz to 12,7 GHz by a requirement of an additional weighted measurement at the frequency of the highest peak emission in this range. This may lead to a maximum of 8 final weighted measurements.

- 4) Discard the distinction between preliminary and final peak measurements and make instead the peak measurements on all azimuths for 2 minutes.

This document is a preview generated by EVS

INDUSTRIAL, SCIENTIFIC AND MEDICAL EQUIPMENT – RADIO-FREQUENCY DISTURBANCE CHARACTERISTICS – LIMITS AND METHODS OF MEASUREMENT

1 Scope

This International Standard applies to industrial, scientific and medical electrical equipment operating in the frequency range 0 Hz to 400 GHz and to domestic and similar appliances designed to generate and/or use locally radio-frequency energy.

This standard covers emission requirements related to radio-frequency (RF) disturbances in the frequency range of 9 kHz to 400 GHz. Measurements need only be performed in frequency ranges where limits are specified in Clause 6.

For ISM RF applications in the meaning of the definition found in the ITU Radio Regulations (see Definition 3.13), this standard covers emission requirements related to radio-frequency disturbances in the frequency range of 9 kHz to 18 GHz.

NOTE Emission requirements for induction cooking appliances are specified in CISPR 14-1 [1]¹.

Requirements for ISM RF lighting equipment and UV irradiators operating at frequencies within the ISM frequency bands defined by the ITU Radio Regulations are contained in this standard.

Equipment covered by other CISPR product and product family emission standards are excluded from the scope of this standard.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

CISPR 16-1-1:2010, *Specification for radio disturbance and immunity measuring apparatus and methods – Part 1-1: Radio disturbance and immunity measuring apparatus – Measuring apparatus*

CISPR 16-1-1:2010/AMD 1:2010

CISPR 16-1-1:2010/AMD 2:2014

CISPR 16-1-2:2014, *Specification for radio disturbance and immunity measuring apparatus and methods – Part 1-2: Radio disturbance and immunity measuring apparatus – Coupling devices for conducted disturbance measurements*

CISPR 16-1-4:2010, *Specification for radio disturbance and immunity measuring apparatus and methods – Part 1-4: Radio disturbance and immunity measuring apparatus – Antennas and test sites for radiated disturbance measurements*

CISPR 16-1-4:2010/AMD 1:2012

¹ Figures in square brackets refer to the Bibliography.

CISPR 16-2-1:2014, *Specification for radio disturbance and immunity measuring apparatus and methods – Part 2-1: Methods of measurement of disturbances and immunity – Conducted disturbance measurements*

CISPR 16-2-3:2010, *Specification for radio disturbance and immunity measuring apparatus and methods – Part 2-3: Methods of measurement of disturbances and immunity – Radiated disturbance measurements*

CISPR 16-2-3:2010/AMD 1:2010

CISPR 16-2-3:2010/AMD 2:2014

CISPR 16-4-2:2011, *Specification for radio disturbance and immunity measuring apparatus and methods – Part 4-2: Uncertainties, statistics and limit modelling – Measuring instrumentation uncertainty*

CISPR 16-4-2:2011/AMD 1:2014

IEC 60050-161:1990, *International Electrotechnical Vocabulary (IEV) – Chapter 161: Electromagnetic compatibility*

IEC 60601-1-2:2014, *Medical electrical equipment – Part 1-2: General requirements for basic safety and essential performance – Collateral standard: Electromagnetic disturbances – Requirements and tests*

IEC 60601-2-2:2009, *Medical electrical equipment – Part 2-2: Particular requirements for the basic safety and essential performance of high frequency surgical equipment and high frequency surgical accessories*

IEC 60974-10:2014, *Arc welding equipment – Part 10: Electromagnetic compatibility (EMC) requirements*

IEC 61307:2011, *Industrial microwave heating installations – Test methods for the determination of power output*

IEC 62135-2:2007, *Resistance welding equipment – Part 2: Electromagnetic compatibility (EMC) requirements*

ITU Radio Regulations (2012), *Radio regulations, Volume 3 – Resolutions and recommendations, Resolution no. 63* (available at <http://www.itu.int/pub/R-REG-RR-2012>)

3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 60050-161, as well as the following, apply.

3.1

a.c. mains power port

port used to connect to a public low voltage a.c. mains power distribution network or other low voltage a.c. mains installation

3.2

arc welding equipment

equipment for applying current and voltage and having the required characteristics suitable for arc welding and allied processes