

**Test method for quantitative determination of corrosive sulfur compounds in unused and used insulating liquids  
- Part 1: Test method for quantitative determination of dibenzylidissulfide (DBDS)**

## EESTI STANDARDI EESSÕNA

## NATIONAL FOREWORD

See Eesti standard EVS-EN 62697-1:2012 sisaldab Euroopa standardi EN 62697-1:2012 ingliskeelset teksti.	This Estonian standard EVS-EN 62697-1:2012 consists of the English text of the European standard EN 62697-1:2012.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 02.11.2012.	Date of Availability of the European standard is 02.11.2012.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile [standardiosakond@evs.ee](mailto:standardiosakond@evs.ee).

ICS 29.040

### Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:  
Aru 10, 10317 Tallinn, Eesti; [www.evs.ee](http://www.evs.ee); telefon 605 5050; e-post [info@evs.ee](mailto:info@evs.ee)

### The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:  
Aru 10, 10317 Tallinn, Estonia; [www.evs.ee](http://www.evs.ee); phone 605 5050; e-mail [info@evs.ee](mailto:info@evs.ee)

**Test methods for quantitative determination of corrosive sulfur compounds in unused and used insulating liquids -  
Part 1: Test method for quantitative determination of dibenzyl disulfide (DBDS)  
(IEC 62697-1:2012)**

Méthodes d'essai pour la détermination quantitative des composés de soufre corrosif dans les liquides isolants usagés et neufs -  
Partie 1: Méthode d'essai pour la détermination quantitative du disulfure de dibenzyle (DBDS)  
(CEI 62697-1:2012)

Prüfverfahren zur quantitativen Bestimmung von Verbindungen korrosiven Schwefels in neuen und gebrauchten Isolierflüssigkeiten -  
Teil 1: Prüfverfahren zur quantitativen Bestimmung von Dibenzyl disulfid (DBDS)  
(IEC 62697-1:2012)

This European Standard was approved by CENELEC on 2012-09-28. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

**CENELEC**

European Committee for Electrotechnical Standardization  
Comité Européen de Normalisation Electrotechnique  
Europäisches Komitee für Elektrotechnische Normung

**Management Centre: Avenue Marnix 17, B - 1000 Brussels**

## Foreword

The text of document 10/887/FDIS, future edition 1 of IEC 62697-1, prepared by IEC/TC 10 "Fluids for electrotechnical applications" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 62697-1:2012.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2013-06-28
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2015-09-28

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

## Endorsement notice

The text of the International Standard IEC 62697-1:2012 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 60296	NOTE	Harmonised as EN 60296.
IEC 60422	NOTE	Harmonised as EN 60422.
IEC 60567	NOTE	Harmonised as EN 60567.

**Annex ZA**  
(normative)

**Normative references to international publications  
with their corresponding European publications**

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60475	-	Method of sampling insulating liquids	EN 60475	-
IEC 62535	2008	Insulating liquids - Test method for detection of potentially corrosive sulphur in used and unused insulating oil	EN 62535	2009

## CONTENTS

FOREWORD.....	5
INTRODUCTION.....	7
1 Scope.....	9
2 Normative references .....	9
3 Terms, definitions and abbreviations .....	9
3.1 Terms and definitions .....	9
3.2 Abbreviations .....	13
4 Sampling.....	13
5 Procedure .....	13
5.1 Principle.....	13
5.2 Significance and use .....	13
5.3 Interferences .....	14
5.3.1 Co-eluting compounds.....	14
5.3.2 Electron capture detector (ECD).....	14
5.3.3 Atomic emission detector (AED) .....	14
5.3.4 Mass spectrometer (MS).....	14
5.3.5 MS/MS .....	14
5.3.6 Interference from the matrix.....	14
5.4 Apparatus.....	15
5.4.1 Balance .....	15
5.4.2 Gas chromatography system .....	15
5.4.3 Data system .....	16
5.5 Reagents and materials.....	16
5.5.1 Purity of reagents .....	16
5.5.2 Gases.....	16
5.5.3 Solvents .....	16
5.6 Standard materials .....	16
5.6.1 Dibenzyl disulfide (DBDS) .....	16
5.6.2 Diphenyl disulfide (DPDS) .....	16
5.6.3 Blank oil .....	16
5.7 Standard solutions .....	17
5.7.1 Stock solution.....	17
5.7.2 Internal standard (IS) solution.....	17
6 Instrument set-up .....	17
6.1 Gas chromatograph.....	17
6.1.1 General .....	17
6.1.2 Carrier gas .....	17
6.1.3 Injector .....	17
6.1.4 Separation parameters .....	17
6.1.5 ECD detection .....	18
6.1.6 AED detection .....	18
6.1.7 MS detection .....	18
6.1.8 MS/MS detection .....	18
6.2 Calibration.....	19
6.2.1 General .....	19
6.2.2 Calibration procedure .....	19

6.2.3	Response factor determination (ECD and AED).....	19
6.2.4	Response factor determination (MS).....	19
6.2.5	Response factor determination (MS/MS).....	20
6.3	Analysis .....	20
6.3.1	Sample pre-treatment.....	20
6.3.2	Sample injection .....	20
6.3.3	Chromatographic run .....	20
6.3.4	Peak integration .....	20
6.4	Calculations .....	21
6.4.1	ECD and AED.....	21
6.4.2	Mass spectrometer (MS).....	21
6.4.3	MS/MS .....	21
6.5	Results.....	21
7	Precision data .....	21
7.1	Detection limit .....	21
7.2	Repeatability .....	22
7.3	Reproducibility .....	22
8	Report.....	22
	Annex A (informative) Figures with typical chromatograms and results .....	23
	Annex B (informative) Operating parameters for other suitable detectors .....	30
	Bibliography.....	31
	Figure A.1 – GC-ECD chromatogram of 2 mg kg <sup>-1</sup> DBDS and DPDS (IS) in white mineral oil.....	23
	Figure A.2 – GC-ECD chromatogram of 200 mg kg <sup>-1</sup> DBDS and DPDS (IS) in white mineral oil.....	24
	Figure A.3 – GC-ECD chromatogram of commercial mineral insulating oil with a known DBDS contamination.....	24
	Figure A.4 – GC-ECD chromatogram of commercial mineral insulating oil with no known DBDS contamination.....	25
	Figure A.5 – GC-ECD chromatogram of commercial mineral insulating oil with known DBDS contamination fortified with a commercial polychlorinated biphenyls (PCBs) formulation.....	25
	Figure A.6 – Carbon and sulfur (C-S) oil finger prints of a commercial mineral insulating oil with known DBDS contamination obtained with GC-AED .....	26
	Figure A.7 – C-S oil fingerprints of a commercial mineral insulating oil with no known DBDS contamination obtained with GC-AED .....	26
	Figure A.8 – C-S oil fingerprints of a commercial mineral insulating oil with known DBDS contamination obtained with GC-AED .....	27
	Figure A.9 – Extracted ion chromatograms of DPDS (IS) molecular ion m/z 218 and DBDS molecular ion m/z 246 in white mineral fortified with DBDS, concentration 4 mg kg <sup>-1</sup> .....	27
	Figure A.10 – Extracted ion chromatograms DPDS (IS) molecular ion m/z 218 and DBDS molecular ion m/z 246 in commercial mineral insulating oil with known DBDS contamination .....	28
	Figure A.11 – Extracted ion chromatograms m/z 109 derived from CID of DPDS (IS) molecular ion m/z 218 and m/z 91 derived from CID of DBDS molecular ion m/z 246 in white mineral fortified with DBDS (4 mg/kg) .....	28

Figure A.12 – Extracted ion chromatograms m/z 109 derived from CID of DPDS (IS) molecular ion m/z 218 and m/z 91 derived from CID of DBDS molecular ion m/z 246 in a commercial mineral oil with known DBDS contamination ..... 29

Table 1 – Column oven temperature programming parameters ..... 18

Table 2 – Mass spectrometer parameters ..... 18

Table 3 – Repeatability limit..... 22

Table 4 – Reproducibility limit..... 22

This document is a preview generated by EVS

## INTRODUCTION

Sulfur can be present in insulating liquids in various forms, including elemental sulfur, inorganic sulfur compounds and organic sulfur compounds. The number of diverse sulfur species comprised of different isomers and homologous can run into hundreds. The total sulfur (TS) concentration in insulating liquids depends on the origin of the liquid, refining processes and the degree of refining and formulation including addition of additives to the base oils. Base oils include mineral based paraffinic and naphthenic oils, synthetic iso-paraffins obtained through gas to liquid conversion process (GTL-Fischer-Tropsch), esters, poly alpha olefins, poly alkylene glycols, etc. Additives can be comprised of electrostatic discharge depressants, metal deactivators, metal passivators, phenolic and sulfur containing antioxidants such as the polysulfides, disulfides, dibenzyl disulfide (DBDS), etc.

Certain sulfur compounds present in the insulating liquids exhibit antioxidant and metal deactivating properties without being corrosive, whereas other sulfur compounds have been known to react with metal surfaces. Specifically, sulfur compounds such as mercaptans are very corrosive to metallic components of electrical devices. Presence of these corrosive sulfur species has been linked to failures of electrical equipment used in generation, transmission and distribution of electrical energy for several decades. Therefore, the IEC standard for mineral insulating oils states that corrosive sulfur compounds shall not be present in unused and used insulating liquids (see IEC 60296) [5]<sup>1</sup>.

Recently, the serious detrimental impact of corrosive sulfur has been linked to the presence of a specific highly corrosive sulfur compound, DBDS. This compound has been found in certain mineral insulating oils [1, 14, 15, 16]; presence of this compound has been shown to result in copper sulfide formation on the surfaces of copper conductors under normal operating conditions of transformers [2].

Current standard test methods for detection of corrosive sulfur (ASTM D1275, methods A and B, and DIN 51353) and potentially corrosive sulfur in used and unused insulating oil (IEC 62535) are empirical and qualitative. These methods rely on visual and subjective perception of colour profiles. The methods do not yield quantitative results in regard to the concentration of DBDS or other corrosive sulfur compounds present in insulating liquids.

Furthermore, methods for corrosive sulfur and potentially corrosive sulfur in insulating liquids (ASTM D1275, method B and IEC 62535) are applicable only to mineral insulating oils that do not contain a metal passivator additive, the methods otherwise can yield negative results even when corrosive sulfur compounds are present in the insulating liquids – thus providing a false negative test result. On the other hand, the test method when used with aged insulating oils (e.g. those with relative high acidity), may give ambiguous results and lead to a false positive test result. Further analysis of insulating liquids is stipulated, e.g. IEC 62535 specifies that if there are any doubts in the interpretation of the results of inspection of paper, the composition of precipitate should be analyzed by other methods (for example by SEM-EDX).

For this reason, IEC TC 10 WG 37 was set up to prepare test methods for the unambiguous quantitative determination of corrosive sulfur compounds in unused and used insulating liquids. Because of the complexity of such determinations, the test methods are divided into three parts:

Part 1 – Test method for quantitative determination of dibenzyl disulfide (DBDS).

Part 2 – Test methods for quantitative determination of total corrosive sulfur (TCS).

Part 3 – Test methods for quantitative determination of total mercaptans and disulfides (TMD) and other targeted corrosive sulfur species.

---

<sup>1</sup> Figures in square brackets refer to the bibliography.

### **Health and safety**

This part of IEC 62697 does not purport to address all the safety problems associated with its use. It is the responsibility of the user of the standard to establish appropriate health and safety practices and determine the applicability of regulatory limitations prior to use.

The insulating liquids which are the subject of this standard should be handled with due regard to personal hygiene. Direct contact with eyes may cause slight irritation. In the case of eye contact, irrigation with copious quantities of clean running water should be carried out and medical advice sought.

Some of the tests specified in this standard involve the use of processes that could lead to a hazardous situation. Attention is drawn to the relevant standard for guidance.

### **Environment**

This standard involves mineral insulating oils, natural ester insulating liquids, chemicals and used sample containers. The disposal of these items should be carried out in accordance with current national legislation with regard to the impact on the environment. Every precaution should be taken to prevent the release of chemicals used during the test into the environment.

This document is a preview generated by EVS

# TEST METHODS FOR QUANTITATIVE DETERMINATION OF CORROSIVE SULFUR COMPOUNDS IN UNUSED AND USED INSULATING LIQUIDS –

## Part 1: Test method for quantitative determination of dibenzyl disulfide (DBDS)

### 1 Scope

This part of IEC 62697 specifies a test method for the quantitative determination of corrosive sulfur compounds-dibenzyl disulfide (DBDS) in used and unused insulating liquids over a 5 – 600 mg kg<sup>-1</sup> concentration range.

### 2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60475, *Method of sampling liquid dielectrics*

IEC 62535:2008, *Insulating liquids – Test method for detection of potentially corrosive sulfur in used and unused insulating oil*

### 3 Terms, definitions and abbreviations

For the purposes of this document, the following terms, definitions and abbreviations apply.

#### 3.1 Terms and definitions

##### 3.1.1

##### **accuracy**

closeness of agreement between test result and the accepted reference value

##### 3.1.2

##### **additive**

a suitable chemical substance that is deliberately added to insulating liquid in order to improve certain characteristics

Note 1 to entry: Examples include antioxidants, pour-point depressants, electrostatic charging tendency depressant such as benzotriazol (BTA) metal passivator or deactivators, antifoam agent, refining process improver, etc.

##### 3.1.3

##### **atomic emission detector**

AED

simultaneously monitors emissions of radiation resulting from atomic species excited in a microwave-induced plasma and permits quantitative determination of selected heteroatoms in compounds that elute from a GC column

Note 1 to entry: AED thus provides heteroatom profiles, i.e. “fingerprints” of complex samples such as insulating liquids.