

**ELEKTRIMÕÕTESEADMED VAHELDUVVOOLULE. OSA 3:
ERINÕUDED. STAATILISED AKTIIVENERGIA ARVESTID
(KLASS A, B JA C)**

**Electricity metering equipment (a.c.) - Part 3: Particular
requirements - Static meters for active energy (class
indexes A, B and C)**

EESTI STANDARDI EESSÕNA**NATIONAL FOREWORD**

See Eesti standard EVS-EN 50470-3:2007+A1:2019 sisaldab Euroopa standardi EN 50470-3:2006 ingliskeelset teksti ja selle muudatuse A1:2018 ingliskeelset teksti.	This Estonian standard EVS-EN 50470-3:2007+A1:2019 consists of the English text of the European standard EN 50470-3:2006 and its amendment A1:2018.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas. Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 27.10.2006, muudatus A1 07.12.2018.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation. Date of Availability of the European standard is 27.10.2006, for A1 07.12.2018.
Sellesse standardisse on muudatus A1 sisse viidud ja tehtud muudatused tähistatud püstkriipsuga lehe välisveerisel. Standard on kättesaadav Eesti Standardikeskusest.	The amendment A1 has been incorporated into this standard and changes have been marked by a vertical line on the outer row of the page. The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 91.140.50

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega: Koduleht www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:

Homepage www.evs.ee; phone +372 605 5050; e-mail info@evs.ee

English Version

Electricity metering equipment (a.c.) - Part 3: Particular requirements - Static meters for active energy (class indexes A, B and C)

Équipement de comptage d'électricité (c.a.) - Partie 3:
Prescriptions particulières - Compteurs statiques d'énergie
active (classes de précision A, B et C)

Wechselstrom-Elektrizitätszähler - Teil 3: Besondere
Anforderungen - Elektronische Wirkverbrauchszähler der
Genauigkeitsklassen A, B und C

This European Standard was approved by CENELEC on 2006-05-01. Amendment A1 was approved by CENELEC on 2018-08-27. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard and its Amendment A1 exist in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Foreword

This European Standard was prepared by the Technical Committee CENELEC TC 13, Equipment for electrical energy measurement and load control.

The text of the draft was submitted to the Unique Acceptance Procedure and was approved by CENELEC as EN 50470-3 on 2006-05-01.

The following dates were fixed:

- latest date by which the EN has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2007-05-01
- latest date by which the national standards conflicting with the EN have to be withdrawn (dow) 2009-05-01

This EN 50470-3 is related to:

- EN 62053-21:2003, *Electricity metering equipment (a.c.) – Particular requirements – Part 21: Static meters for active energy (classes 1 and 2)* and
- EN 62053-22:2003, *Electricity metering equipment (a.c.) – Particular requirements – Part 22: Static meters for active energy (classes 0,2 S and 0,5 S)*.

The structure of the standards is similar, modifications in this European Standard are provided in the perspective of compliance with the Essential Requirements of the Directive 2004/22/EC on Measuring Instruments (MID).

This standard is to be used with EN 50470-1:2006, *Electricity metering equipment (a.c.) – Part 1: General requirements, tests and test conditions – Metering equipment (class indexes A, B and C)*.

This European Standard has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association and covers essential requirements of EC Directive 2004/22/EC. See Annex ZZ.

EN 50470-3:2006+A1:2018 foreword

This document (EN 50470-3:2006/A1:2018) has been prepared by CLC/TC 13 “Electrical energy measurement and control”.

The following dates are fixed:

- latest date by which this document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2019-08-27
- latest date by which the national standards conflicting with this document have to be withdrawn (dow) 2021-08-27

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directive(s).

For the relationship with EU Directive(s) see informative Annex ZZ, which is an integral part of this document.

This document is a preview generated by EVS

EN 50470-3:2006+A1:2018 introduction

The purpose of this amendment is to identify and remove all safety related requirements and tests of EN 50470-3:2006 that are replaced and extended by the complete set of requirements and tests in EN 62052-31:2016.

This document is a preview generated by EVS

Contents

1	Scope.....	7
2	Normative references	7
3	Terms, definitions and abbreviations	8
4	Standard electrical values	8
5	Mechanical requirements.....	8
6	Climatic conditions	8
7	Electrical requirements	8
	7.1 Power consumption	8
	7.1.1 Measurement method	8
	7.1.2 Voltage circuits.....	8
	7.1.3 Current circuits	8
	7.2 AC voltage test.....	9
8	Accuracy requirements and tests	9
	8.1 Limits of percentage error due to variation of the load	9
	8.2 Repeatability	9
	8.3 Limits of additional percentage error due to influence quantities	10
	8.4 Maximum permissible error (MPE).....	11
	8.5 Effect of disturbances of long duration.....	12
	8.6 Short time overcurrents	14
	8.7 Performing the tests	14
	8.7.1 Accuracy test conditions	14
	8.7.2 Accuracy tests at reference conditions	15
	8.7.3 Interpretation of accuracy test results	16
	8.7.4 Repeatability	16
	8.7.5 Test of effects of influence quantities.....	16
	8.7.6 Calculation of the composite error	17
	8.7.7 Test of effects of disturbances of long duration.....	17
	8.7.8 Short time overcurrents	20
	8.7.9 Test of starting and no-load condition	21
	8.7.10 Meter constant.....	22
9	Durability.....	22
10	Reliability	22
11	Requirements concerning the software and protection against corruption	23
	11.1 General.....	23
	11.2 Identification of functions implemented in software	23
	11.3 Identification and protection of software	23
	11.4 Identification and protection of metrologically relevant parameters	23
	11.5 Setting of parameters	24
	11.6 Protection of measurement data	24
	11.7 Protection against inadmissible influence by metrologically non-relevant software	24
	11.8 Protection against inadmissible influence by connecting another device	24
	Annex A (informative) Calculation of the composite error	25
	Annex B (normative) Test circuit diagram for the test of immunity to earth fault	26

Annex C (normative) Test circuit diagram for d.c., even harmonics, odd harmonics and sub-harmonics	27
Annex ZZ (informative) Relationship between this European standard and the essential requirements of directive 2014/32/EU aimed to be covered	32
Bibliography.....	33

Figures

Figure B.1 – Circuit to simulate earth fault condition in phase 1	26
Figure B.2 – Voltages at the meter under test	26
Figure C.1 – Test circuit diagram for half-wave rectification	27
Figure C.2 – Half-wave rectified waveform	28
Figure C.3 – Informative distribution of half-wave harmonic content (the Fourier analysis is not complete)	28
Figure C.4 – Test circuit diagram (informative).....	29
Figure C.5 – Phase fired waveform	30
Figure C.6 – Informative distribution of harmonic content of phase fired waveform (the Fourier analysis is not complete)	30
Figure C.7 – Burst fired waveform.....	31
Figure C.8 – Informative distribution of harmonic content of burst fired waveform (the Fourier analysis is not complete)	31

Tables

Table 1 – Power consumption in voltage circuits	8
Table 2 – Power consumption in current circuits	9
Table 4 – Percentage error limits at reference conditions (single-phase meters and polyphase meters with balanced loads)	9
Table 5 – Percentage error limits at reference conditions (polyphase meters carrying a single-phase load, but with balanced polyphase voltages applied to voltage circuits)	9
Table 6 – Limits of additional percentage error due to influence quantities (single-phase meters and polyphase meters with balanced loads).....	10
Table 7 – Limits of additional percentage error due to influence quantities (polyphase meters carrying a single phase load, but with balanced polyphase voltages applied to voltage circuits)	11
Table 8 – Maximum permissible error (MPE).....	12
Table 9 – Effect of disturbances of long duration – Critical change values	13
Table 10 – Effect of short time overcurrents – Critical change value	14
Table 11 – Voltage and current balance.....	14
Table 12 – Reference conditions.....	15
Table 13 – Test points determining the intrinsic error and the additional percentage error due to influence quantities	16
Table 14 – Interpretation of test results.....	16
Table 15 – Starting current	21

1 Scope

This European Standard applies to newly manufactured static watt-hour meters intended for residential, commercial and light industrial use, of class indexes A, B and C, for the measurement of alternating current electrical active energy in 50 Hz networks. It specifies particular requirements and type test methods.

It applies to static watt-hour meters for indoor and outdoor application, consisting of a measuring element and register(s) enclosed together in a meter case. It also applies to operation indicator(s) and test output(s).

If the meter has (a) measuring element(s) for more than one type of energy (multi-energy meters), or when other functional elements, like maximum demand indicators, electronic tariff registers, time switches, ripple control receivers, data communication interfaces etc. are enclosed in the meter case (multi-function meters) then this standard applies only for the active energy metering part.

This standard distinguishes between:

- meters of class indexes A, B and C;
- direct connected and transformer operated meters;
- meters for use in networks equipped with or without earth fault neutralizers.

It does not apply to:

- watt-hour meters where the voltage across the connection terminals exceeds 600 V (line-to-line voltage for meters for polyphase systems);
- portable meters;
- reference meters.

The safety aspect is covered by EN 62052 31:2016.

Regarding acceptance tests see EN 62058 11:2010 and EN 62058 31:2010.

The dependability aspect is covered by the documents of the IEC 62059 series.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

Publication	Year	Title
EN 50470-1 + A1	2006 2018	<i>Electricity metering equipment (a.c.) – Part 1: General requirements, tests and test conditions – Metering equipment (class indexes A, B and C)</i>
EN 62052-31	2016	<i>Electricity metering equipment (AC) – General requirements, tests and test conditions – Part 31: Product safety requirements and tests (IEC 62052-31:2015)</i>
EN 62059-41	2006	<i>Electricity metering equipment – Dependability – Part 41: Reliability prediction (IEC 62059-41:2006)</i>