

INTERNATIONAL STANDARD

Mobile and fixed offshore units – Electrical installations –
Part 2: System design

This document is a preview generated by EVS



THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2012 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.
If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

Useful links:

IEC publications search - www.iec.ch/searchpub

The advanced search enables you to find IEC publications by a variety of criteria (reference number, text, technical committee,...).

It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available on-line and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 30 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary (IEV) on-line.

Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

Document is a preview generated by EVS



IEC 61892-2

Edition 2.0 2012-03

INTERNATIONAL STANDARD

Mobile and fixed offshore units – Electrical installations –
Part 2: System design

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

PRICE CODE

ICS 47.020.60

ISBN 978-2-88912-993-5

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	7
INTRODUCTION.....	9
1 Scope.....	10
2 Normative references.....	10
3 Terms and definitions.....	11
4 Sources of electrical power.....	16
4.1 General.....	16
4.2 Main source of electrical power.....	17
4.3 Emergency source of electrical power.....	18
4.4 Starting arrangements for emergency generators.....	21
4.5 Additional requirements for periodically unattended machinery spaces.....	22
4.6 General requirements for renewable sources of electrical power.....	22
4.6.1 Photovoltaic system.....	22
4.6.2 Eolic system.....	23
5 System earthing.....	23
5.1 General.....	23
5.2 General requirements.....	23
5.3 Neutral earthing methods.....	24
5.4 Neutral earthing for systems up to and including 1 000 V a.c.....	24
5.5 Neutral earthing for systems above 1 000 V.....	25
5.6 Generators operated in parallel with source transformers.....	25
5.7 Earthing resistors, connection to hull/structure.....	25
6 Distribution systems.....	27
6.1 DC distribution systems.....	27
6.1.1 Types of distribution systems.....	27
6.1.2 TN d.c. systems.....	28
6.1.3 IT d.c. systems.....	31
6.1.4 DC voltages.....	31
6.2 AC distribution systems.....	32
6.2.1 Primary a.c. distribution systems.....	32
6.2.2 Secondary a.c. distribution systems.....	32
6.2.3 TN a.c. systems.....	32
6.2.4 IT a.c. systems.....	34
6.2.5 AC voltages and frequencies.....	34
6.2.6 Control voltage.....	36
7 Distribution system requirements.....	37
7.1 Earthed distribution systems.....	37
7.2 Methods of distribution.....	37
7.3 Balance of loads.....	37
7.3.1 Balance of load on three-wire d.c. systems.....	37
7.3.2 Balance of loads in three- or four-wire a.c. systems.....	37
7.4 Final circuits.....	37
7.4.1 General.....	37
7.4.2 Final circuits for lighting.....	37
7.4.3 Final circuit for lighting in accommodation spaces.....	38

7.4.4	Final circuits in offices and workshops	38
7.4.5	Final circuits for heating	38
7.5	Control circuits	38
7.5.1	Supply systems and nominal voltages	38
7.5.2	Circuit design	38
7.5.3	Motor control	38
7.5.4	Protection	38
7.5.5	Arrangement of circuits	39
7.6	Socket-outlets	39
7.7	Shore connections for mobile units	39
7.8	Motor circuits	39
7.8.1	Starting of motors	39
7.8.2	Means of disconnection	40
7.8.3	Starters remote from motors	40
7.8.4	Master-starter system	40
8	Diversity (demand) factors	40
8.1	Final circuits	40
8.2	Circuits other than final circuits	40
8.3	Application of diversity (demand) factors	40
8.4	Motive power circuits – General	40
9	System study and calculations	41
9.1	General	41
9.2	Electrical load study	42
9.3	Load flow calculations	42
9.4	Short-circuit calculations	43
9.5	Protection and discrimination study	44
9.6	Power system dynamic calculations	45
9.7	Calculation of harmonic currents and voltages	47
10	Protection	47
10.1	General	47
10.2	Characteristic and choice of protective devices with reference to short-circuit rating	48
10.2.1	General	48
10.2.2	Protective devices	48
10.2.3	Backup protection	48
10.2.4	Rated short-circuit breaking capacity	49
10.2.5	Rated short-circuit making capacity	49
10.2.6	Co-ordinated choice of protective devices with regard to discrimination requirements	49
10.3	Choice of protective devices with reference to overload	49
10.3.1	Mechanical switching devices	49
10.3.2	Fuses for overload protection	49
10.4	Choice of protective devices with regard to their application	50
10.4.1	General	50
10.4.2	Generator protection	50
10.4.3	Protection of essential services	51
10.4.4	Protection of transformers	51
10.4.5	Circuit protection	51
10.4.6	Motor protection	51

10.4.7	Protection of lighting circuits	52
10.4.8	Protection of power from external sources	52
10.4.9	Secondary cells and battery protection	52
10.4.10	Protection of meters, pilot lamps and control circuits	52
10.4.11	Protection of static or solid state devices	52
10.4.12	Protection for heat tracing systems	53
10.5	Undervoltage protection	53
10.5.1	Generators	53
10.5.2	AC and DC motors	53
10.6	Overvoltage protection	53
10.6.1	General	53
10.6.2	AC machines	53
10.6.3	DC networks	54
11	Lighting	54
11.1	General	54
11.2	General lighting system	54
11.3	Emergency lighting system	55
11.4	Escape lighting system	56
11.5	Lighting circuits in machinery spaces, accommodation spaces, open deck spaces, etc.	57
11.6	Navigation and obstruction signals and lights	58
11.7	Luminaires	58
11.7.1	Discharge lamp luminaires of voltages above 250 V	58
11.7.2	Searchlights	58
12	Control and instrumentation	58
12.1	Safeguarding	58
12.2	Supply arrangement	58
12.3	Dependability	58
12.4	Safety	59
12.5	Segregation	59
12.6	Performance	59
12.7	Integration	59
12.8	Development activities	59
12.9	Electromagnetic compatibility	59
12.10	Design	59
12.10.1	Environmental and supply conditions	59
12.10.2	Circuit design	60
12.10.3	Monitoring equipment	60
12.10.4	Time delays	60
12.10.5	Closed circuits	60
12.10.6	Earth faults	60
12.11	Installation and ergonomics	60
12.11.1	General	60
12.11.2	Remote controls	60
12.12	Specific installations	61
12.12.1	Safety critical systems	61
12.12.2	Fire and gas protection control installations and other control systems	62
12.13	Automatic control installations for electrical power supply	63

12.13.1	General	63
12.13.2	Automatic starting.....	63
12.13.3	Automatic disconnection	64
12.13.4	Automatic starting installations for electrical motor-driven auxiliaries	64
12.13.5	Manual control	65
12.14	Machinery control installations.....	65
12.14.1	General	65
12.14.2	General requirement.....	65
12.15	Public address and general alarm systems	65
12.15.1	Audibility.....	65
12.15.2	Operation	65
12.15.3	Emergency broadcast	65
12.15.4	Minimum sound level	65
12.15.5	Fault tolerance.....	65
12.15.6	Redundancy	66
12.15.7	Segregation.....	66
12.15.8	Power supplies	66
12.15.9	Cabling.....	66
12.16	Computer-based systems	66
12.16.1	General	66
12.16.2	System integration.....	66
12.16.3	Power supply	66
12.16.4	Data communication links	67
12.16.5	Alarm, control and safety functions	67
12.17	Software	68
12.17.1	General	68
12.17.2	Configuration	68
12.17.3	Documentation	69
12.18	Tests	70
12.18.1	General	70
12.18.2	Hardware.....	70
12.18.3	Software	71
12.18.4	System testing.....	71
12.19	Documentation	71
12.19.1	Apparatus description	71
12.19.2	Circuit diagrams.....	71
13	Degrees of protection by enclosures.....	72
Annex A (informative)	Variable a.c. speed drives	76
Bibliography.....		77
Figure 1	– Continuity of supply/continuity of service.....	16
Figure 2	– TN-S d.c. system	28
Figure 3	– TN-C d.c. system	29
Figure 4	– TN-C-S d.c. system.....	30
Figure 5	– IT d.c. system	31
Figure 6	– TN-S a.c. system	33
Figure 7	– TN-C-S a.c. system.....	33

Figure 8 – TN-C a.c. system 34

Figure 9 – IT a.c. system 34

Figure A.1 – Typical a.c. drilling system 76

Table 1 – Recommended maximum earth fault currents 25

Table 2 – Summary of principal features of the neutral earthing methods 26

Table 3 – Voltages for d.c. systems 32

Table 4 – AC systems having a nominal voltage between 100 V and 1 000 V inclusive and related equipment 35

Table 5 – AC three-phase systems having a nominal voltage above 1 kV and not exceeding 35 kV and related equipment ^a 36

Table 6 – General lighting illumination levels 55

Table 7 – Recommended measuring points for measuring illumination in an area 55

Table 8 – Escape lighting illumination levels 56

Table 9 – Minimum requirements for the degree of protection for mobile and fixed offshore units (Degree of protection as defined in IEC 61892-1) 73

This document is a preview generated by EVS

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**MOBILE AND FIXED OFFSHORE UNITS –
ELECTRICAL INSTALLATIONS –****Part 2: System design**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61892-2 has been prepared by IEC technical committee 18: Electrical installations of ships and of mobile and fixed offshore units.

This second edition cancels and replaces the first edition published in 2005. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- the d.c. voltage given in clause 1 has been updated to 1 500 V, to ensure consistency through all parts of the IEC 61892 series;
- Clause 4 has been rewritten, such that all requirements to emergency power are now given in 4.3;
- the tables for nominal a.c. voltages have been updated in accordance with the last revision of IEC 60038;

- the requirement to cross sectional area for earthing conductors has been made dependent on the system earthing arrangement;
- requirement for emergency stop for motor-driven fuel-oil transfer and fuel-oil pressure pumps has been added.

The text of this standard is based on the following documents:

FDIS	Report on voting
18/1240/FDIS	18/1255/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all the parts in the IEC 61892 series, under the general title *Mobile and fixed offshore units – Electrical installations*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

This document is a preview generated by EVS

INTRODUCTION

IEC 61892 forms a series of International Standards intended to enable safety in the design, selection, installation, maintenance and use of electrical equipment for the generation, storage, distribution and utilisation of electrical energy for all purposes in offshore units, which are being used for the purpose of exploration or exploitation of petroleum resources.

This part of IEC 61892 also incorporates and co-ordinates, as far as possible, existing rules and forms a code of interpretation, where applicable, of the requirements of the International Maritime Organisation (IMO), a guide for future regulations which may be prepared and a statement of practice for offshore unit owners, constructors and appropriate organisations.

This standard is based on equipment and practices, which are in current use, but it is not intended in any way to impede the development of new or improved techniques.

The ultimate aim has been to produce a set of International standards exclusively for the offshore petroleum industry.

This document is a preview generated by EVS

MOBILE AND FIXED OFFSHORE UNITS – ELECTRICAL INSTALLATIONS –

Part 2: System design

1 Scope

This part of IEC 61892 contains provisions for system design of electrical installations in mobile and fixed units used in the offshore petroleum industry for drilling, production, processing and for storage purposes, including pipeline, pumping or 'pigging' stations, compressor stations and exposed location single buoy moorings.

It applies to all installations, whether permanent, temporary, transportable or hand-held, to a.c. installations up to and including 35 000 V and d.c. installations up to and including 1 500 V. (a.c. and d.c. voltages are nominal values). This standard does not apply either to fixed equipment used for medical purposes or to the electrical installations of tankers.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60038:2009, *IEC standard voltages*

IEC 60092-101:1994, *Electrical installations in ships – Part 101: Definitions and general requirements*

IEC 60092-504:2001, *Electrical installations in ships – Part 504: Special features – Control and instrumentation*

IEC 60447, *Basic and safety principles for man-machine interface, marking and identification – Actuating principles*

IEC 60533, *Electrical and electronic installations in ships – Electromagnetic compatibility*

IEC 60909-0, *Short-circuit currents in three-phase a.c. systems – Part 0: Calculation of currents*

IEC 60909-1, *Short-circuit currents in three-phase a.c. systems – Part 1: Factors for the calculation of short-circuit currents according to IEC 60909-0*

IEC 60947-2:2006, *Low-voltage switchgear and controlgear – Part 2: Circuit-breakers*

IEC 61363-1, *Electrical installations of ships and mobile and fixed offshore units – Part 1: Procedures for calculating short-circuit currents in three-phase a.c.*

IEC 61511 (all parts), *Functional safety – Safety instrumented systems for the process industry sector*

IEC 61660-1, *Short-circuit currents in d.c. auxiliary installations in power plants and substations – Part 1: Calculation of short-circuit currents*

IEC 61892-1:2010, *Mobile and fixed offshore units – Electrical installations – Part 1: General requirements and conditions*

IEC 61892-3:2007, *Mobile and fixed offshore units – Electrical installations – Part 3: Equipment*

IEC 61892-5, *Mobile and fixed offshore units – Electrical installations – Part 5: Mobile units*

IEC 61892-7:2007, *Mobile and fixed offshore units – Electrical installations – Part 7: Hazardous areas*

IEC 62271-100:2008, *High-voltage switchgear and controlgear – Part 100: Alternating-current circuit-breakers*

SOLAS, *International Convention for the Safety of Life at Sea*

IMO MODU Code, *Code for the Construction and Equipment of Mobile Offshore Drilling Units*

IMO COLREG Code:1972, *Convention on the International Regulations for Preventing Collisions at Sea*

IALA Recommendation O-1239:2008, *On The Marking of Man-Made Offshore Structures*

ICAO, *International Civil Aviation Organization, Annex 14, Aerodromes*

3 Terms and definitions

For the purposes of this document the terms and definitions given in IEC 61892-1 and the following apply.

3.1 AC systems of distribution

3.1.1

single-phase two-wire a.c. system

system comprising two conductors only, between which the load is connected

Note 1 to entry In some countries this is designated as a two-phase system.

3.1.2

three-phase three-wire a.c. system

system comprising three conductors connected to a three-phase supply

3.1.3

three-phase four-wire a.c. system

system comprising four conductors of which three are connected to a three-phase supply and the fourth to a neutral point in the source of supply

3.2

arc-flash hazard

a dangerous condition associated with the release of energy caused by an electric arc

[SOURCE: IEEE 1584:2002, 3.1]