

Acoustics - Laboratory measurement of the flanking transmission of airborne and impact sound between adjoining rooms - Part 1: Frame document

Acoustics - Laboratory measurement of the flanking transmission of airborne and impact sound between adjoining rooms - Part 1: Frame document

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

<p>Käesolev Eesti standard EVS-EN ISO 10848-1:2006 sisaldab Euroopa standardi EN ISO 10848-1:2006 ingliskeelset teksti.</p> <p>Käesolev dokument on jõustatud 29.05.2006 ja selle kohta on avaldatud teade Eesti standardiorganisatsiooni ametlikus väljaandes.</p> <p>Standard on kättesaadav Eesti standardiorganisatsioonist.</p>	<p>This Estonian standard EVS-EN ISO 10848-1:2006 consists of the English text of the European standard EN ISO 10848-1:2006.</p> <p>This document is endorsed on 29.05.2006 with the notification being published in the official publication of the Estonian national standardisation organisation.</p> <p>The standard is available from Estonian standardisation organisation.</p>
--	---

<p>Käsitlusala: ISO 10848 specifies measurement methods to be performed in a laboratory test facility in order to characterize the flanking transmission of one or several building components. The performance of the building components is expressed either as an overall quantity for the combination of elements and junction (such as $D_{n,f}$ and/or $L_{n,f}$) or as the vibration reduction index K_{ij} of a junction.</p>	<p>Scope: ISO 10848 specifies measurement methods to be performed in a laboratory test facility in order to characterize the flanking transmission of one or several building components. The performance of the building components is expressed either as an overall quantity for the combination of elements and junction (such as $D_{n,f}$ and/or $L_{n,f}$) or as the vibration reduction index K_{ij} of a junction.</p>
---	---

ICS 91.120.20

Võtmesõnad:

ICS 91.120.20

English Version

Acoustics - Laboratory measurement of the flanking transmission of airborne and impact sound between adjoining rooms - Part 1: Frame document (ISO 10848-1:2006)

Acoustique - Mesurage en laboratoire des transmissions latérales du bruit aérien et des bruits de choc entre pièces adjacentes - Partie 1: Document cadre (ISO 10848-1:2006)

Akustik - Messung der Flankenübertragung von Luftschall und Trittschall zwischen benachbarten Räumen in Prüfständen - Teil 1: Rahmendokument (ISO 10848-1:2006)

This European Standard was approved by CEN on 16 March 2006.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the Central Secretariat has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: rue de Stassart, 36 B-1050 Brussels

Foreword

This document (EN ISO 10848-1:2006) has been prepared by Technical Committee CEN/TC 126 "Acoustic properties of building elements and of buildings", the secretariat of which is held by AFNOR, in collaboration with Technical Committee ISO/TC 43 "Acoustics".

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by October 2006, and conflicting national standards shall be withdrawn at the latest by October 2006.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.

**Acoustics — Laboratory measurement of
the flanking transmission of airborne and
impact sound between adjoining
rooms —**

**Part 1:
Frame document**

*Acoustique — Mesurage en laboratoire des transmissions latérales du
bruit aérien et des bruits de choc entre des pièces adjacentes —*

Partie 1: Document cadre



PDF disclaimer

This PDF file may contain embedded typefaces. In accordance with Adobe's licensing policy, this file may be printed or viewed but shall not be edited unless the typefaces which are embedded are licensed to and installed on the computer performing the editing. In downloading this file, parties accept therein the responsibility of not infringing Adobe's licensing policy. The ISO Central Secretariat accepts no liability in this area.

Adobe is a trademark of Adobe Systems Incorporated.

Details of the software products used to create this PDF file can be found in the General Info relative to the file; the PDF-creation parameters were optimized for printing. Every care has been taken to ensure that the file is suitable for use by ISO member bodies. In the unlikely event that a problem relating to it is found, please inform the Central Secretariat at the address given below.

© ISO 2006

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Case postale 56 • CH-1211 Geneva 20
Tel. + 41 22 749 01 11
Fax + 41 22 749 09 47
E-mail copyright@iso.org
Web www.iso.org

Published in Switzerland

Contents

Page

Foreword.....	iv
1 Scope	1
2 Normative references	1
3 Terms and definitions.....	2
4 Quantities to characterize flanking transmission	6
4.1 General.....	6
4.2 Normalized flanking level difference $D_{n,f}$ and normalised flanking impact sound pressure level $L_{n,f}$	6
4.3 Vibration reduction index, K_{ij}	6
4.4 Selection of the principle of measurement	8
5 Measuring equipment.....	9
6 General requirements for test specimens and test rooms.....	9
7 Measurement methods.....	10
7.1 Measurement of $D_{n,f}$ and $L_{n,f}$	10
7.2 Measurement of the vibration reduction index with structure-borne excitation	12
7.3 Measurement of the structural reverberation time.....	15
7.4 Measurement of the vibration reduction index with airborne excitation	16
7.5 Frequency range of measurement	17
8 Influences from the structures of the test facility	17
8.1 Criterion to verify flanking transmissions through constructions of the test facility	17
8.2 Conventional limit for light elements compared with the surrounding elements of the test facility.....	18
8.3 Verification procedure for a light flanking element that is structurally independent of a separating element	18
9 Shielding.....	18
Annex A (normative) Single-number rating of the vibration reduction index.....	24
Bibliography	25

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 10848-1 was prepared by the European Committee for Standardization (CEN) Technical Committee CEN/TC 126, *Acoustic properties of building elements and of buildings*, in collaboration with Technical Committee ISO/TC 43, *Acoustics*, Subcommittee SC 2, *Building acoustics*, in accordance with the Agreement on technical cooperation between ISO and CEN (Vienna Agreement).

ISO 10848 consists of the following parts, under the general title *Acoustics — Laboratory measurement of the flanking transmission of airborne and impact sound between adjoining rooms*:

- *Part 1: Frame document*
- *Part 2: Application to light elements when the junction has a small influence*
- *Part 3: Application to light elements when the junction has a substantial influence*

The following part is under preparation:

- *Part 4: Application to all other cases*

Acoustics — Laboratory measurement of the flanking transmission of airborne and impact sound between adjoining rooms —

Part 1: Frame document

1 Scope

ISO 10848 specifies measurement methods to be performed in a laboratory test facility in order to characterize the flanking transmission of one or several building components. The performance of the building components is expressed either as an overall quantity for the combination of elements and junction (such as $D_{n,f}$ and/or $L_{n,f}$) or as the vibration reduction index K_{ij} of a junction.

This part of ISO 10848 contains definitions, general requirements for test specimens and test rooms, and measurement methods. Guidelines are given for the selection of the quantity to be measured depending on the junction and the types of building elements involved. Other parts of ISO 10848 specify the application for different types of junction and building elements.

The quantities characterizing the flanking transmission can be used to compare different products, or to express a requirement, or as input data for prediction methods, such as EN 12354-1 and EN 12354-2.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 140-1, *Acoustics — Measurement of sound insulation in buildings and of building elements — Part 1: Requirements for laboratory test facilities with suppressed flanking transmission*

ISO 140-3:1995, *Acoustics — Measurement of sound insulation in buildings and of building elements — Part 3: Laboratory measurements of airborne sound insulation of building elements*

ISO 140-6:1998, *Acoustics — Measurement of sound insulation in buildings and of building elements — Part 6: Laboratory measurements of impact sound insulation of floors*

ISO 354, *Acoustics — Measurement of sound absorption in a reverberation room*

ISO 3382, *Acoustics — Measurement of the reverberation time of rooms with reference to other acoustical parameters*

ISO 7626-1, *Vibration and shock — Experimental determination of mechanical mobility — Part 1: Basic definitions and transducers*

ISO 10848-2:2006, *Acoustics — Laboratory measurement of the flanking transmission of airborne and impact sound between adjoining rooms — Part 2: Application to light elements when the junction has a small influence*

ISO 10848-3:2006, *Acoustics — Laboratory measurement of the flanking transmission of airborne and impact sound between adjoining rooms — Part 3: Application to light elements when the junction has a substantial influence*

IEC 61260, *Electroacoustics — Octave-band and fractional-octave-band filters*

IEC 60651, *Sound level meters*

IEC 60804, *Integrating-averaging sound level meters*

IEC 60942, *Sound calibrators*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.1

average sound pressure level in a room

L

ten times the common logarithm of the ratio of the space and time average of the sound pressure squared to the square of the reference sound pressure, the space average being taken over the entire room with the exception of those parts where the direct radiation of a sound source or the near field of the boundaries (walls, etc.) is of significant influence

NOTE 1 This quantity is expressed in decibels.

NOTE 2 If a continuously moving microphone is used, L is determined by

$$L = 10 \lg \frac{\frac{1}{T_m} \int_0^{T_m} p^2(t) dt}{p_0^2} \text{ dB} \quad (1)$$

where

p is the sound pressure, in pascals;

p_0 is the reference sound pressure, in pascals; $p_0 = 20 \mu\text{Pa}$;

T_m is the integration time, in seconds.

NOTE 3 If fixed microphone positions are used, L is determined by

$$L = 10 \lg \frac{p_1^2 + p_2^2 + \dots + p_n^2}{n \cdot p_0^2} \text{ dB} \quad (2)$$

where p_1, p_2, \dots, p_n are r.m.s. (root mean square) sound pressures at n different positions in the room, in pascals.

NOTE 4 In practice usually the sound pressure levels L_i are measured. In this case L is determined by

$$L = 10 \lg \frac{1}{n} \sum_{i=1}^n 10^{L_i/10} \text{ dB} \quad (3)$$

where L_i are the sound pressure levels L_1 to L_n at n different positions in the room, in decibels.