

Industrial communication networks - Fieldbus specifications - Part 5-10: Application layer service definition - Type 10 elements

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN IEC 61158-5-10:2023 sisaldab Euroopa standardi EN IEC 61158-5-10:2023 ingliskeelset teksti.	This Estonian standard EVS-EN IEC 61158-5-10:2023 consists of the English text of the European standard EN IEC 61158-5-10:2023.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation and Accreditation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 12.05.2023.	Date of Availability of the European standard is 12.05.2023.
Standard on kättesaadav Eesti Standardimis-ja Akrediteerimiskeskusest.	The standard is available from the Estonian Centre for Standardisation and Accreditation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 25.040.40, 35.100.70, 35.110

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardimis- ja Akrediteerimiskeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardimis-ja Akrediteerimiskeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardimis-ja Akrediteerimiskeskusega: Koduleht www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation and Accreditation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation and Accreditation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation and Accreditation:

Homepage www.evs.ee; phone +372 605 5050; e-mail info@evs.ee

EUROPEAN STANDARD

EN IEC 61158-5-10

NORME EUROPÉENNE

EUROPÄISCHE NORM

May 2023

ICS 25.040.40; 35.100.70; 35.110

Supersedes EN IEC 61158-5-10:2019

English Version

**Industrial communication networks - Fieldbus specifications -
Part 5-10: Application layer service definition - Type 10 elements
(IEC 61158-5-10:2023)**

Réseaux de communication industriels - Spécifications des
bus de terrain - Partie 5-10: Définition des services de la
couche application - Eléments de type 10
(IEC 61158-5-10:2023)

Industrielle Kommunikationsnetze - Feldbusse - Teil 5-10:
Dienstfestlegungen des Application Layer
(Anwendungsschicht) - Typ 10-Elemente
(IEC 61158-5-10:2023)

This European Standard was approved by CENELEC on 2023-04-28. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

European foreword

The text of document 65C/1203/FDIS, future edition 5 of IEC 61158-5-10, prepared by SC 65C "Industrial networks" of IEC/TC 65 "Industrial-process measurement, control and automation" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 61158-5-10:2023.

The following dates are fixed:

- latest date by which the document has to be implemented at national (dop) 2024-01-28 level by publication of an identical national standard or by endorsement
- latest date by which the national standards conflicting with the (dow) 2026-04-28 document have to be withdrawn

This document supersedes EN IEC 61158-5-10:2019 and all of its amendments and corrigenda (if any).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Any feedback and questions on this document should be directed to the users' national committee. A complete listing of these bodies can be found on the CENELEC website.

Endorsement notice

The text of the International Standard IEC 61158-5-10:2023 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standard indicated:

IEC/IEEE 60802:— ¹	NOTE	Approved as EN IEC 60802:— ² (not modified)
IEC 60870-5-4	NOTE	Approved as EN 60870-5-4
IEC 61131-1	NOTE	Approved as EN 61131-1
IEC 61375-2-1	NOTE	Approved as EN 61375-2-1
IEC 61784-1 (series)	NOTE	Approved as EN IEC 61784-1 (series)
IEC 61784-2 (series)	NOTE	Approved as EN IEC 61784-2 (series)

¹ Under preparation: Stage at the time of publication: IEC/IEEE CD 60802:2022.

² Under preparation: Stage at the time of publication: prEN IEC 60802:2020.

INTERNATIONAL STANDARD



**Industrial communication networks – Fieldbus specifications –
Part 5-10: Application layer service definition – Type 10 elements**



THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2023 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Secretariat
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 300 terminological entries in English and French, with equivalent terms in 19 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

Preview generated by EVS



IEC 61158-5-10

Edition 5.0 2023-03

INTERNATIONAL STANDARD



**Industrial communication networks – Fieldbus specifications –
Part 5-10: Application layer service definition – Type 10 elements**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 25.040.40; 35.100.70; 35.110

ISBN 978-2-8322-6578-9

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	17
INTRODUCTION.....	19
1 Scope.....	20
1.1 General.....	20
1.2 Specifications	21
1.3 Conformance	21
2 Normative references	21
3 Terms, definitions, abbreviated terms, symbols and conventions	24
3.1 Referenced terms and definitions.....	24
3.1.1 ISO/IEC 7498-1 terms.....	24
3.1.2 ISO/IEC 8822 terms.....	25
3.1.3 ISO/IEC 9545 terms.....	25
3.1.4 ISO/IEC 8824-1 terms.....	25
3.2 Additional Type 10 terms and definitions.....	25
3.3 Additional Type 10 terms and definitions for media redundancy	33
3.4 Abbreviations and symbols	34
3.4.1 General	34
3.4.2 Additional Type 10 abbreviations and symbols.....	37
3.4.3 Abbreviations and symbols for services	40
3.4.4 Void.....	40
3.5 Conventions.....	40
3.5.1 Overview	40
3.5.2 General conventions.....	41
3.5.3 Conventions for class definitions	41
3.5.4 Conventions for service definitions	42
3.5.5 Conventions used in state machines.....	43
4 Concepts	43
5 Data type ASE.....	44
5.1 General.....	44
5.1.1 Overview	44
5.1.2 Date and time type specifics	44
5.1.3 Transfer of user data	44
5.1.4 Data type overview	44
5.2 Formal definition of data type objects.....	47
5.2.1 Data type class.....	47
5.3 FAL defined data types	49
5.3.1 Fixed length types	49
5.3.2 Variable Length types	71
5.4 Data type ASE service specification.....	74
6 Communication model for common services	74
6.1 Concepts	74
6.1.1 General	74
6.1.2 Structure of an end station.....	75
6.1.3 Structure of a bridged end station	76
6.1.4 Structure of a bridge	77
6.1.5 Examples of stations	78

6.1.6	Automation system	79
6.2	ASE data types	80
6.3	ASEs	80
6.3.1	Middle Layer ASEs	80
6.3.2	Remote procedure call ASE	81
6.3.3	Remote service interface ASE	90
6.3.4	Domain name system ASE	103
6.3.5	Simple network management ASE	104
6.3.6	NETCONF ASE	107
6.3.7	NETCONF event ASE	108
6.3.8	IP suite ASE	109
6.3.9	Real time cyclic ASE	113
6.3.10	Real time acyclic ASE	130
6.3.11	Discovery and basic configuration ASE	140
6.3.12	Dynamic host configuration ASE	173
6.3.13	IEEE Std 802.1AB ASE	175
6.3.14	Media redundancy ASE	189
6.3.15	Precision time control ASE	196
6.3.16	IEEE Std 802.1AS ASE	210
6.3.17	IEEE Std 802.1Q ASE	214
6.3.18	IEEE Std 802.1CB ASE	230
6.3.19	Fragmentation ASE	236
6.3.20	IEEE Std 802.3 ASE	238
6.3.21	Void	241
6.3.22	Common DL mapping ASE	241
6.4	Additional information	248
7	Communication model for distributed I/O	248
7.1	Concepts	248
7.1.1	User requirements	248
7.1.2	Features	248
7.1.3	Associations	249
7.1.4	Device types	250
7.1.5	Instance model and device addresses	260
7.1.6	Application process	260
7.1.7	Application service element	268
7.1.8	Application relationship	270
7.2	ASE data types	270
7.3	ASEs	271
7.3.1	AR ASE	271
7.3.2	Real Identification ASE	409
7.3.3	CIM ASE	502
7.3.4	Diagnosis ASE	604
7.3.5	PE ASE	652
7.3.6	LogBook ASE	662
7.3.7	RS ASE	665
7.3.8	Time ASE	690
7.3.9	NME ASE	695
7.4	Application characteristics	734
7.4.1	Device Ident Number	734

7.4.2	Network topology	735
7.5	Summary of FAL services	736
7.5.1	IO device	736
7.5.2	IO controller	737
7.5.3	IO supervisor	738
Annex A (informative)	Device instances	739
Annex B (informative)	Components of an Ethernet interface	742
Annex C (informative)	Scheme of MAC address assignment	746
Annex D (informative)	Measurement of the fast startup time	747
Annex E (informative)	Dynamic Frame Packing	748
Annex F (informative)	Precondition for Diagnosis	756
Bibliography	762
Figure 1	– Structure of an automation station	74
Figure 2	– Overall view of communication ASEs	75
Figure 3	– Structure of an end station	76
Figure 4	– Structure of a bridged end station	77
Figure 5	– IEEE Std 802 station example 1 (end station and bridge configuration portion)	78
Figure 6	– IEEE Std 802 station example 3	79
Figure 7	– IEEE Std 802 station example 4	79
Figure 8	– Automation system example	80
Figure 9	– Middle Layer ASEs communication architecture	80
Figure 10	– Sequence Chart for reading the EndPointMapper	83
Figure 11	– Media redundancy diagnosis dependencies	195
Figure 12	– PTCP applications	196
Figure 13	– Example of periods at a local port	227
Figure 14	– Example of communication between controlling devices and field devices	249
Figure 15	– Example of communication between an engineering station and several controlling and field devices	250
Figure 16	– Example of communication between field devices and a server station	250
Figure 17	– Example of communication between field devices	250
Figure 18	– Interfaces, components and ports	251
Figure 19	– Multiple interfaces, components and ports	252
Figure 20	– Multiple interfaces, one bridge component with one external port	253
Figure 21	– Multiple interfaces, multiple bridge components	253
Figure 22	– Data Objects and Diagnosis Data Model	257
Figure 23	– Example for channel modelling	258
Figure 24	– Mapping to device model	259
Figure 25	– Identification hierarchy	259
Figure 26	– Application Process with application process objects (APOs)	261
Figure 27	– Access to a remote APO	262
Figure 28	– Access to a remote APO for provider/consumer association	263
Figure 29	– Overview of application processes	264

Figure 30 – IO device with APs, slots and subslots	264
Figure 31 – Example 1 structural units for interfaces and ports within API 0.....	267
Figure 32 – Example 2 structural units for interfaces and ports within API 0.....	267
Figure 33 – FAL ASEs communication architecture.....	268
Figure 34 – Example of one AR with two AREPs.....	270
Figure 35 – Example IO application relationship (one-to-one)	273
Figure 36 – Example IO application relationship one-to-many	274
Figure 37 – Implicit application relationship	275
Figure 38 – State transition diagram DEVSM	308
Figure 39 – State transition diagram CTLSM.....	316
Figure 40 – Assignment of Communication Relationship to Application Relationship.....	321
Figure 41 – Overview Communication Relationship Class service interactions	324
Figure 42 – Example for an intersection of IO device, slot, and AR	387
Figure 43 – Substitute Value.....	417
Figure 44 – State transition diagram RSMSM.....	425
Figure 45 – Ownership handling.....	428
Figure 46 – State transition diagram OWNSM.....	431
Figure 47 – State transition diagram ASSSM	431
Figure 48 – State transition diagram PLUGSM.....	443
Figure 49 – State transition diagram PULLSM.....	446
Figure 50 – Location concepts in Asset Management.....	461
Figure 51 – Basic model for isochronous applications	476
Figure 52 – General isochronous application model (example CACF == 1)	477
Figure 53 – General isochronous application model (example CACF == 2)	478
Figure 54 – ASE relations in an IO device operating in isochronous mode for a submodule	484
Figure 55 – State transition diagram of ISOM_SYNC	486
Figure 56 – State transition diagram ISOM_OUT	489
Figure 57 – State transition diagram ISOM_IN	494
Figure 59 – CIM overview	503
Figure 60 – CIM class principle.....	504
Figure 61 – MRP interconnection	588
Figure 62 – State transition diagram SYNC_DIAG.....	599
Figure 63 – Diagnosis Base Model.....	605
Figure 64 – Filtering of diagnosis	606
Figure 65 – Filtering hierarchy	606
Figure 66 – Severity classification of fault, maintenance and qualified	607
Figure 67 – Data Base Model.....	608
Figure 68 – State transition diagram DIAG_DIAG.....	638
Figure 69 – State transition diagram DIAG_MR.....	641
Figure 70 – State transition diagram DIAG_MD.....	645
Figure 71 – State transition diagram DIAG_QUALIFIED	649
Figure 72 – Architecture.....	653

Figure 73 – State transition diagram PESM.....	661
Figure 74 – Reporting System components.....	666
Figure 75 – AR / ARSet and Reporting System.....	667
Figure 76 – Max Scan Delay.....	675
Figure 77 – RS Incident window.....	678
Figure 78 – State transition diagram RSOBS.....	683
Figure 79 – State transition diagram RSBUF.....	687
Figure 80 – State transition diagram TimeSM.....	693
Figure 81 – Layers from application to network.....	696
Figure 82 – Assumed application timing model.....	696
Figure 83 – Relations of the IO controller to the Network Management Engine.....	697
Figure 84 – Relations of the IO device to the Network Management Engine.....	698
Figure 85 – Relations of a standalone Network Management Engine.....	698
Figure 86 – Correlation of the Stream Add parameter.....	704
Figure 87 – Interaction of the NME class.....	711
Figure 88 – Interaction of the NCE class.....	714
Figure 89 – Interaction of the TDE class.....	717
Figure 90 – Interaction of the PCE class.....	724
Figure 91 – Interaction of the BNME class.....	727
Figure 92 – Interaction between NME instance and BNME instance.....	727
Figure 93 – Interaction of the NUE class.....	734
Figure 94 – Example of network topology including slower wireless segments.....	735
Figure 95 – Example of media redundancy including wireless segments.....	736
Figure A.1 – Instance model in conjunction with CLRPC.....	739
Figure A.2 – Instance model in conjunction with RSI.....	740
Figure B.1 – Scheme of an Ethernet interface.....	742
Figure B.2 – Scheme of an Ethernet interface with bridging ability.....	743
Figure B.3 – Scheme of an Ethernet interface with optical ports.....	744
Figure B.4 – Scheme of an Ethernet interface with bridging ability using radio communication.....	745
Figure B.5 – Scheme of an Ethernet interface with radio communication.....	745
Figure C.1 – Scheme of MAC address assignment.....	746
Figure D.1 – Measurement of the fast startup time.....	747
Figure E.1 – Frame Layout.....	748
Figure E.2 – Subframe Layout.....	749
Figure E.3 – End to End.....	750
Figure E.4 – Dynamic frame packing.....	750
Figure E.5 – Dynamic frame packing – Truncation of outputs.....	751
Figure E.6 – Dynamic frame packing – Outbound Pack.....	751
Figure E.7 – Dynamic frame packing – Concatenation of inputs.....	752
Figure E.8 – Dynamic frame packing – Inbound Pack.....	753
Figure E.9 – Dynamic frame packing – Distributed watchdog.....	755
Figure E.10 – Interrelation between IO CR and dynamically packed frame.....	755

Table 1 – Data type overview.....	45
Table 2 – V2 octets.....	49
Table 3 – L2 octets.....	50
Table 4 – E2 octets.....	51
Table 5 – E2 value range.....	51
Table 6 – Unipolar2.16 octets.....	51
Table 7 – Unipolar2.16 value range.....	51
Table 8 – N2 value range.....	53
Table 9 – N4 value range.....	54
Table 10 – X2 value range.....	55
Table 11 – X4 value range.....	56
Table 12 – C4 value range.....	56
Table 13 – T2 value range.....	58
Table 14 – T4 value range.....	59
Table 15 – D2 value range.....	60
Table 16 – R2 value range.....	60
Table 17 – TimeStamp status value range.....	62
Table 18 – TimeStampDifference status value range.....	63
Table 19 – F message trailer with 4 octets.....	66
Table 20 – Unsigned16_S octets.....	68
Table 21 – Unsigned16_S meaning.....	69
Table 22 – Integer16_S octets.....	69
Table 23 – Integer16_S meaning.....	69
Table 24 – Unsigned8_S octets.....	70
Table 25 – Unsigned8_S meaning.....	70
Table 26 – OctetString_S octets.....	71
Table 27 – OctetString_S status bits.....	72
Table 28 – RPC Connect.....	84
Table 29 – RPC Release.....	85
Table 30 – RPC Read.....	86
Table 31 – RPC Write.....	87
Table 32 – RPC Control.....	88
Table 33 – RPC Read Implicit.....	89
Table 34 – RSI initiator add.....	93
Table 35 – RSI responder add.....	94
Table 36 – RSI initiator remove.....	95
Table 37 – RSI responder remove.....	96
Table 38 – RSI call.....	97
Table 39 – RSI notification.....	99
Table 40 – RSI initiator abort.....	100
Table 41 – RSI responder abort.....	101
Table 42 – RSI get responder instances.....	102
Table 43 – SNMP Enable SNMP v1/v2.....	105

Table 44 – SNMP Set Community Name	106
Table 45 – Add Static ARP Cache Entry	112
Table 46 – Remove Static ARP Cache Entry	113
Table 47 – PPM Set Prov Data	119
Table 48 – PPM Set Prov Status	120
Table 49 – PPM Activate	121
Table 50 – PPM Close	123
Table 51 – PPM Start	123
Table 52 – PPM Error	124
Table 53 – Get cons data	124
Table 54 – CPM Get cons status	125
Table 55 – CPM Set RedRole	126
Table 56 – CPM Activate	127
Table 57 – CPM NoData	129
Table 58 – CPM Stop	129
Table 59 – CPM New Data Indication	130
Table 60 – APMS Activate	132
Table 61 – APMR Activate	134
Table 62 – APMS A Data	136
Table 63 – APMR A Data	137
Table 64 – APMR Ack	137
Table 65 – APMS Error	138
Table 66 – APMS Error ERRCLS/ERRCODE	138
Table 67 – APMR Error	139
Table 68 – APMR Error ERRCLS/ERRCODE	139
Table 69 – APMS_Close	139
Table 70 – APMR_Close	140
Table 71 – Get	150
Table 72 – Set	155
Table 73 – Local Get Command	161
Table 74 – Local Set Command	162
Table 75 – Identify	163
Table 76 – Hello	170
Table 77 – PN DHCP Discover	174
Table 78 – PN DHCP Offer	175
Table 79 – System capabilities	181
Table 80 – Auto negotiation support and status	183
Table 81 – MDI Power Support	183
Table 82 – Remote systems data change	188
Table 83 – Start bridge	203
Table 84 – Start slave	204
Table 85 – Start master	205
Table 86 – Stop bridge	206

Table 87 – Stop slave	207
Table 88 – Stop master	208
Table 89 – Sync state change	208
Table 90 – Line Delay change	209
Table 91 – Local Get Time	213
Table 92 – Local time state info	213
Table 93 – Traffic classes	214
Table 94 – Port state change	221
Table 95 – Set port state	222
Table 96 – Flush filtering data base	222
Table 97 – Add FDB entry	223
Table 98 – Remove FDB entry	223
Table 99 – Config Port	224
Table 100 – Stream ID Add	232
Table 101 – Stream ID Remove	233
Table 102 – Stream Identification	234
Table 103 – Stream Active Identification	235
Table 104 – Stream Send	236
Table 105 – MAU Type change	240
Table 106 – Set MAU Type	241
Table 107 – P Data	242
Table 108 – N Data	243
Table 109 – A Data	245
Table 110 – C Data	246
Table 111 – R Data	247
Table 112 – Requirements and features	249
Table 113 – Internal components and ports in the interface mounted left or up into the rack	252
Table 114 – Internal components and ports mounted interface mounted right or down into the rack	252
Table 115 – Binding application relationship services	276
Table 116 – Device Access	279
Table 117 – Companion AR	280
Table 118 – Acknowledge Companion AR	280
Table 119 – Time Aware System	280
Table 120 – Startup Mode	281
Table 121 – Pull Module Alarm Allowed	281
Table 122 – Input Valid on Backup AR	284
Table 123 – Mode	285
Table 124 – APStructureIdentifier with API := 0	285
Table 125 – APStructureIdentifier with API != 0	286
Table 126 – RS Alarm Transport Mode	286
Table 127 – Connect	289
Table 128 – Connect Device Access	294

Table 129 – Release	296
Table 130 – Prm Begin	298
Table 131 – Prm End	299
Table 132 – Application Ready	301
Table 133 – Abort	302
Table 134 – Local AR Abort	302
Table 135 – Local Set AR State	303
Table 136 – Local AR In Data	303
Table 137 – Data elements of Read AR Data	304
Table 138 – Data elements of Expected Fast Startup Data	306
Table 139 – Remote primitives issued or received by DEVSM	307
Table 140 – Local primitives issued or received by DEVSM	307
Table 141 – State table DEVSM	309
Table 142 – Functions, Macros, Timers and Variables by DEVSM	314
Table 143 – Remote primitives issued or received by CTLISM	315
Table 144 – Local primitives issued or received by CTLISM	315
Table 145 – State table CTLISM	317
Table 146 – Functions, Macros, Timers and Variables used by CTLISM	319
Table 147 – Binding communication relationship services	325
Table 148 – Traffic Classes versus RT Class	327
Table 149 – Local Set Input	336
Table 150 – Local Set Input IOCS	337
Table 151 – Local Get Input	338
Table 152 – Local Get Input IOCS	339
Table 153 – Local New Input	340
Table 154 – Local Set Output	341
Table 155 – Local Set Output IOCS	342
Table 156 – Local Get Output	343
Table 157 – Local Get Output IOCS	344
Table 158 – Local New Output	345
Table 159 – Local Set Provider State	345
Table 160 – Local Set Redundancy	346
Table 161 – Local Set State	347
Table 162 – Local Data State Changed	347
Table 163 – Binding expected identification services	354
Table 164 – Module State	356
Table 165 – AR Info	360
Table 166 – Ident Info	360
Table 167 – General Data definition for identification services	361
Table 168 – Data elements of Read Module Diff Block	363
Table 169 – Alarm type	367
Table 170 – Alarm types attached to diagnosis ASE	369
Table 171 – Alarm types attached to ownership	370

Table 172 – Alarm types attached to common profiles, profiles, and application	370
Table 173 – Binding Alarm services	370
Table 174 – Alarm Notification	374
Table 175 – Channel Diagnosis	376
Table 176 – Manufacturer Specific Diagnosis.....	376
Table 177 – Submodule Diagnosis State.....	377
Table 178 – AR Diagnosis State	377
Table 179 – User Structure Identifier	378
Table 180 – Semantics of Specifier.....	380
Table 181 – Binding Record Data services.....	388
Table 182 – Read	389
Table 183 – Read Services	391
Table 184 – Read Implicit.....	394
Table 185 – Read Query	395
Table 186 – Read Query Services.....	396
Table 187 – Write	396
Table 188 – Write Services	397
Table 189 – Data elements of Write Combined Object Container	399
Table 190 – Local Write Multiple	400
Table 191 – Local New Write Multiple	402
Table 192 – Binding real identification services.....	409
Table 193 – Local Add Submodule.....	413
Table 194 – Local Remove Submodule	414
Table 195 – Data elements of Read API Data	415
Table 196 – Data elements of Read Record Input Data Object Element.....	416
Table 197 – Data elements of Read Record Output Data Object Element	419
Table 198 – Data elements of Read Substitute Value.....	420
Table 199 – Selector for Read GSD Data.....	422
Table 200 – Data elements of Read GSD Data	422
Table 201 – Remote primitives issued or received by RSMSM	424
Table 202 – Local primitives issued or received by RSMSM.....	424
Table 203 – State table RSMSM	425
Table 204 – Functions, Macros, Timers and Variables used by RSMSM	427
Table 205 – Rules for Submodule State.Ident Info	427
Table 206 – Remote primitives issued or received by OWNSM and ASSSM.....	430
Table 207 – Local primitives issued or received by OWNSM	430
Table 208 – State table OWNSM	432
Table 209 – State table ASSSM.....	438
Table 210 – Functions, Macros, Timers and Variables used by OWNSM.....	439
Table 211 – Functions, Macros, Timers and Variables used by ASSSM	440
Table 212 – Rules for Submodule State.AR Info	440
Table 213 – Remote primitives issued or received by PLUGSM	441
Table 214 – Local primitives issued or received by PLUGSM	442

Table 215 – State table PLUGSM	444
Table 216 – Functions, Macros, Timers and Variables used by PLUGSM.....	445
Table 217 – Remote primitives issued or received by PULLSM	446
Table 218 – Local primitives issued or received by PULLSM.....	446
Table 219 – State table PULLSM	447
Table 220 – Functions, Macros, Timers and Variables used by PULLSM	448
Table 221 – Binding I&M data services	450
Table 222 – Data elements of Read I&M0 Filter Data.....	464
Table 223 – Data elements of Read I&M0 Data.....	467
Table 224 – Data elements of Write I&M1 Data.....	468
Table 225 – Data elements of Write I&M2 Data.....	469
Table 226 – Data elements of Write I&M3 Data.....	469
Table 227 – Data elements of Write I&M4 Data.....	470
Table 228 – Data elements of Read I&M5 Data.....	471
Table 229 – Data elements of Read Asset Management Data	474
Table 230 – Binding Isochronous Mode Application services.....	478
Table 231 – Data elements of Write Isochronous Mode Data	483
Table 232 – Remote primitives issued or received by ISOM_SYNC.....	485
Table 233 – Local primitives issued or received by ISOM_SYNC	485
Table 234 – State table ISOM_SYNC.....	486
Table 235 – Functions, Macros, Timers and Variables used by the ISOM_SYNC	487
Table 236 – Remote primitives issued or received for ISOM_OUT	487
Table 237 – Local primitives issued or received for ISOM_OUT	488
Table 238 – State table ISOM_OUT	490
Table 239 – Functions, Macros, Timers and Variables used by the ISOM_OUT	492
Table 240 – Remote primitives issued or received for ISOM_IN	493
Table 241 – Local primitives issued or received for ISOM_IN.....	493
Table 242 – State table ISOM_IN.....	495
Table 243 – Functions, Macros, Timers and Variables used by the ISOM_IN	496
Table 244 – Observer service binding.....	498
Table 245 – Binding Communication Interface Management services	505
Table 246 – Subslot number for interface submodules	508
Table 247 – Subslot number for port submodules	511
Table 248 – Data elements of Read PDev Data	518
Table 249 – Data elements of Read PD Real Data.....	519
Table 250 – Data elements of Read PD Expected Data.....	520
Table 251 – Data elements of Read PD Interface Data Real	522
Table 252 – Data elements of Write PD Interface Adjust.....	523
Table 253 – Data elements of Write PD Interface FSU Data Adjust.....	523
Table 254 – Data elements of Write PD NC Data Check	524
Table 255 – Data elements of Read PD Port Statistic	525
Table 256 – Data elements of Read PD Port Data Real	526
Table 257 – Data elements of Read PD Port Data Real Extended.....	527

Table 258 – Data elements of Write PD Port Data Check	529
Table 259 – Data elements of Write PD Port Data Adjust	530
Table 260 – Data elements of Read Port FO Data Real	531
Table 261 – Data elements of Write PD Port FO Data Check	532
Table 262 – Data elements of Write PD Port FO Data Adjust	532
Table 263 – Data elements of Write PD Port SFP Data Check	533
Table 264 – Data elements of Read RSI Instances	534
Table 265 – Binding IEEE Std 802.1AS services	539
Table 266 – Binding IEEE Std 802.1Q bridge services	543
Table 267 – Allowed values of Forwarding Mode	550
Table 268 – Allowed values of Fast Forwarding Multicast MAC Add	550
Table 269 – Tx Port Entry	553
Table 270 – Dependencies of RedPeriodBegin and GreenPeriodBegin	556
Table 271 – Distributed Watchdog Factor	557
Table 272 – Restart Factor For Distributed Watchdog	558
Table 273 – DFP Mode	558
Table 274 – SFIOCRProperties.DFPRedundantPathLayout	559
Table 275 – SFCRC16	559
Table 276 – Data elements of Write PD IR Data	570
Table 277 – Data elements of Write PD IR Subframe Data	572
Table 278 – Write CIM NetConf Stream Forward Data	575
Table 279 – Binding Media Redundancy services	577
Table 280 – Data elements of Read PD Interface MRP Data Real	579
Table 281 – Data elements of Write PD Interface MRP Data Check	581
Table 282 – Data elements of Write PD Interface MRP Data Adjust	582
Table 283 – Data elements of Read PD Port MRP Data Real	583
Table 284 – Data elements of Write PD Port MRP Data Adjust	584
Table 285 – Data elements of Read PD Port MRPIC Data Real	585
Table 286 – Data elements of Write PD Port MRPIC Data Check	585
Table 287 – Data elements of Write PD Port MRPIC Data Adjust	586
Table 288 – Binding PTCP services	590
Table 289 – Sync Properties Role	593
Table 290 – Sync Class	593
Table 291 – Data elements of Write PD Sync Data	594
Table 292 – Local Sync State Info	596
Table 293 – Local SYNCH Event	597
Table 294 – Remote primitives issued or received by SYNC_DIAG	598
Table 295 – Local primitives issued or received by SYNC_DIAG	598
Table 296 – State table SYNC_DIAG	599
Table 297 – Functions, Macros, Timers and Variables used by SYNC_DIAG	601
Table 298 – List of supported MIBs	601
Table 299 – Cross-referencing of MIB-II objects	602
Table 300 – Cross-referencing of LLDP-MIB objects	602

Table 301 – Cross-referencing of LLDP-EXT-PNO MIB objects	603
Table 302 – Cross-referencing of LLDP-EXT-DOT3 MIB objects	603
Table 303 – IEEE Std 802.1Q ASE related YANG modules (type definitions)	604
Table 304 – Diagnosis Records (index).....	612
Table 305 – Binding Diagnosis services.....	613
Table 306 – General Data definition for Diagnosis services.....	618
Table 307 – Local Add Diagnosis Entry.....	620
Table 308 – Local Remove Diagnosis Entry	622
Table 309 – Local Update Diagnosis Entry.....	623
Table 310 – Remote primitives issued or received by DIAG_DIAG	637
Table 311 – Local primitives issued or received by DIAG_DIAG	637
Table 312 – State table DIAG_DIAG	638
Table 313 – Functions, Macros, Timers and Variables used by DIAG_DIAG	639
Table 314 – Remote primitives issued or received by DIAG_MR	641
Table 315 – Local primitives issued or received by DIAG_MR.....	641
Table 316 – State table DIAG_MR	642
Table 317 – Functions, Macros, Timers and Variables used by DIAG_MR.....	643
Table 318 – Remote primitives issued or received by DIAG_MD	644
Table 319 – Local primitives issued or received by DIAG_MD.....	644
Table 320 – State table DIAG_MD	646
Table 321 – Functions, Macros, Timers and Variables used by the maintenance demanded entry.....	647
Table 322 – Remote primitives issued or received by DIAG_QUALIFIED	648
Table 323 – Local primitives issued or received by DIAG_QUALIFIED.....	649
Table 324 – State table DIAG_QUALIFIED	650
Table 325 – Functions, Macros, Timers and Variables used by DIAG_QUALIFIED.....	650
Table 326 – Binding PE services.....	654
Table 327 – Local Add PE Entity.....	655
Table 328 – Local Remove PE Entity	656
Table 329 – Local Update PE_OperationalMode	657
Table 330 – PE Entity Filter Data definition.....	658
Table 331 – PE Entity Filter Data definition.....	659
Table 332 – Remote primitives issued or received by PESM	660
Table 333 – Local primitives issued or received by PESM.....	661
Table 334 – State table PESM	662
Table 335 – Functions, Macros, Timers and Variables used by PESM	662
Table 336 – Binding LogBook services	663
Table 337 – Data elements of Read LogBook Data	664
Table 338 – Local Create LogBook Entry	665
Table 339 – Binding RS services	672
Table 340 – Immanent observers	674
Table 341 – Configured observers	674
Table 342 – Data elements of Local Add RS Event	680

Table 343 – Data elements of RS Get Event	680
Table 344 – Data elements of RS Ack Event	681
Table 345 – Data elements of RS Adjust Observer	682
Table 346 – Local primitives issued or received by RSOBS	683
Table 347 – State table RSOBS	685
Table 348 – Functions, Macros, Timers and Variables used by RSOBS	686
Table 349 – Remote primitives issued or received by RSBUF	686
Table 350 – Local primitives issued or received by RSBUF	687
Table 351 – State table RSBUF	688
Table 352 – Functions, Macros, Timers and Variables used by RSBUF	690
Table 353 – Binding Time services	691
Table 354 – Local Get Time	691
Table 355 – Local primitives issued or received by TimeSM	692
Table 356 – State table TimeSM	694
Table 357 – Functions, Macros, Timers and Variables used by TimeSM	694
Table 358 – NME Start	701
Table 359 – NME Stop	702
Table 360 – NME Stream Add	703
Table 361 – NME Stream Remove	707
Table 362 – NME Stream Renew	709
Table 363 – NCE Activate	712
Table 364 – NCE Deactivate	712
Table 365 – NCE NetworkConfig Changed	713
Table 366 – TDE Activate	715
Table 367 – TDE Close	716
Table 368 – TDE Topology Changed	716
Table 369 – PCE Activate	718
Table 370 – PCE Deactivate	719
Table 371 – PCE Stream Add	720
Table 372 – PCE Stream Remove	721
Table 373 – PCE Stream Renew	722
Table 374 – PCE Path Changed	723
Table 375 – BNME Activate	725
Table 376 – BNME Close	726
Table 377 – BNME Role Changed	726
Table 378 – NUE Activate	729
Table 379 – NUE Deactivate	729
Table 380 – NUE Stream Add	731
Table 381 – NUE Stream Remove	732
Table 382 – NUE Stream Renew	733
Table 383 – FAL services of the IO device	736
Table 384 – FAL services of the IO controller	737
Table F.1 – ChannelErrorType	756

Table F.2 – Preconditions ChannelErrorType 0 – 0xFF	757
Table F.3 – Preconditions for ChannelErrorType 0x0100 – 0x7FFF, 0x9000 – 0x9FFF	757
Table F.4 – Preconditions for ChannelErrorType “Data transmission impossible”	757
Table F.5 – Preconditions for ChannelErrorType “Remote mismatch”	758
Table F.6 – Preconditions for ChannelErrorType “Media redundancy mismatch – ring”	758
Table F.7 – Preconditions for ChannelErrorType “Media redundancy mismatch – interconnection”	759
Table F.8 – Preconditions for ChannelErrorType “Sync mismatch”	759
Table F.9 – Preconditions for ChannelErrorType “Isochronous mode mismatch”	759
Table F.10 – Preconditions for ChannelErrorType “Multicast CR mismatch”	759
Table F.11 – Preconditions for ChannelErrorType “Fiber optic mismatch”	760
Table F.12 – Preconditions for ChannelErrorType “Network component function mismatch”	760
Table F.13 – Preconditions for ChannelErrorType “Dynamic Frame Packing function mismatch”	760
Table F.14 – Preconditions for ChannelErrorType “Media redundancy with planned duplication mismatch”	760
Table F.15 – Preconditions for ChannelErrorType “Multiple interface mismatch”	761
Table F.16 – Preconditions for ChannelErrorType “Power failure over Single Pair Ethernet”	761

preview generated by EVS

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**INDUSTRIAL COMMUNICATION NETWORKS –
FIELD BUS SPECIFICATIONS –****Part 5-10: Application layer service definition –
Type 10 elements**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 61158-5-10 has been prepared by subcommittee 65C: Industrial networks, of IEC technical committee 65: Industrial-process measurement, control and automation. It is an International Standard.

This fifth edition cancels and replaces the fourth edition published in 2019. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) integration of system redundancy basic functionality;
- b) integration of dynamic reconfiguration basic functionality;
- c) integration of reporting system basic functionality;
- d) integration of asset management basic functionality;

e) integration of media redundancy ring interconnection basic functionality.

The text of this International Standard is based on the following documents:

Draft	Report on voting
65C/1203/FDIS	65C/1244/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts of the IEC 61158 series, published under the general title *Industrial communication networks – Fieldbus specifications*, can be found on the IEC web site.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

This part of IEC 61158 is one of a series produced to facilitate the interconnection of automation system components. It is related to other standards in the set as defined by the “three-layer” fieldbus reference model described in IEC 61158-1.

The application service is provided by the application protocol making use of the services available from the data-link or other immediately lower layer. This document defines the application service characteristics that fieldbus applications and/or system management can exploit.

Throughout the set of fieldbus standards, the term “service” refers to the abstract capability provided by one layer of the OSI Basic Reference Model to the layer immediately above. Thus, the application layer service defined in this document is a conceptual architectural service, independent of administrative and implementation divisions.

This document is a preview generated by EVS

INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

Part 5-10: Application layer service definition – Type 10 elements

1 Scope

1.1 General

The fieldbus application layer (FAL) provides user programs with a means to access the fieldbus communication environment. In this respect, the FAL can be viewed as a “window between corresponding application programs”.

This part of IEC 61158 provides common elements for basic time-critical and non-time-critical messaging communications between application programs in an automation environment and material specific to Type 10 fieldbus. The term "time-critical" is used to represent the presence of a time-window, within which one or more specified actions are required to be completed with some defined level of certainty. Failure to complete specified actions within the time window risks failure of the applications requesting the actions, with attendant risk to equipment, plant and possibly human life.

This document defines in an abstract way the externally visible service provided by the Type 10 fieldbus application layer in terms of:

- an abstract model for defining application resources (objects) capable of being manipulated by users via the use of the FAL service,
- the primitive actions and events of the service;
- the parameters associated with each primitive action and event, and the form which they take; and
- the interrelationship between these actions and events, and their valid sequences.

The purpose of this document is to define the services provided to:

- the FAL user at the boundary between the user and the application layer of the fieldbus reference model, and
- Systems Management at the boundary between the application layer and Systems Management of the fieldbus reference model.

This document specifies the structure and services of the Type 10 fieldbus application layer, in conformance with the OSI Basic Reference Model (ISO/IEC 7498-1) and the OSI application layer structure (ISO/IEC 9545).

FAL services and protocols are provided by FAL application-entities (AE) contained within the application processes. The FAL AE is composed of a set of object-oriented application service elements (ASEs) and a layer management entity (LME) that manages the AE. The ASEs provide communication services that operate on a set of related application process object (APO) classes. One of the FAL ASEs is a management ASE that provides a common set of services for the management of the instances of FAL classes.

Although these services specify, from the perspective of applications, how request and responses are issued and delivered, they do not include a specification of what the requesting and responding applications are to do with them. That is, the behavioral aspects of the applications are not specified; only a definition of what requests and responses they can send/receive is specified. This permits greater flexibility to the FAL users in standardizing such object behavior. In addition to these services, some supporting services are also defined in this document to provide access to the FAL to control certain aspects of its operation.

1.2 Specifications

The principal objective of this document is to specify the characteristics of conceptual application layer services suitable for time-critical communications, and thus supplement the OSI Basic Reference Model in guiding the development of application layer protocols for time-critical communications.

A secondary objective is to provide migration paths from previously existing industrial communications protocols. It is this latter objective which gives rise to the diversity of services standardized as the various Types of IEC 61158, and the corresponding protocols standardized in subparts of IEC 61158-6.

This document can be used as the basis for formal application programming interfaces. Nevertheless, it is not a formal programming interface, and any such interface will need to address implementation issues not covered by this specification, including

- a) the sizes and octet ordering of various multi-octet service parameters, and
- b) the correlation of paired request and confirm, or indication and response, primitives.

1.3 Conformance

This document does not specify individual implementations or products, nor does it constrain the implementations of application layer entities within industrial automation systems.

There is no conformance of equipment to this application layer service definition standard. Instead, conformance is achieved through implementation of conforming application layer protocols that fulfill the Type 10 application layer services as defined in this document.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE All parts of the IEC 61158 series, as well as the IEC 61784-1 series and the IEC 61784-2 series are maintained simultaneously. Cross-references to these documents within the text therefore refer to the editions as dated in this list of normative references.

IEC 61131-3:2013, *Programmable controllers – Part 3: Programming languages*

IEC 61158-1:2023, *Industrial communication networks – Fieldbus specifications – Part 1: Overview and guidance for the IEC 61158 and IEC 61784 series*

IEC 61158-2:2023, *Industrial communication networks – Fieldbus specifications – Part 2: Physical layer specification and service definition*

IEC 61158-5-3:2023, *Industrial communication networks – Fieldbus specifications – Part 5-3: Application layer service definition – Type 3 elements*

IEC 61158-6-3:2023, *Industrial communication networks – Fieldbus specifications – Part 6-3: Application layer protocol specification – Type 3 elements*

IEC 61158-6-10:2023, *Industrial communication networks – Fieldbus specifications – Part 6-10: Application layer protocol specification – Type 10 elements*

IEC 61784-3-3, *Industrial communication networks – Profiles – Part 3-3: Functional safety fieldbuses – Additional specifications for CPF 3*

IEC 61800-7-203:2015, *Adjustable speed electrical power drive systems – Part 7-203: Generic interface and use of profiles for power drive systems – Profile type 3 specification*

IEC 62439-2:2021, *Industrial communication networks – High availability automation networks – Part 2: Media Redundancy Protocol (MRP)*

ISO/IEC 646:1991, *Information technology – ISO 7-bit coded character set for information interchange*

ISO/IEC 7498-1, *Information technology – Open Systems Interconnection – Basic Reference Model: The Basic Model*

ISO/IEC 8822, *Information technology – Open Systems Interconnection – Presentation service definition*

ISO/IEC 8824-1, *Information technology – Abstract Syntax Notation One (ASN.1) – Part 1: Specification of basic notation*

ISO/IEC 9545, *Information technology – Open Systems Interconnection – Application Layer structure*

ISO/IEC 9834-8, *Information technology – Procedures for the operation of object identifier registration authorities – Part 8: Generation of universally unique identifiers (UUIDs) and their use in object identifiers*

ISO/IEC 10646, *Information technology – Universal coded character set (UCS)*

ISO/IEC 10731, *Information technology – Open Systems Interconnection – Basic Reference Model – Conventions for the definition of OSI services*

ISO/IEC/IEEE 60559:2020, *Information technology – Microprocessor Systems – Floating-Point arithmetic*

ISO 8601-1:2019, *Data and time – Representations for information interchange – Part 1: Basic rules*

IEEE Std 802.1AB-2016, *IEEE Standard for Local and metropolitan area networks: Station and Media Access Control Connectivity Discovery*

IEEE Std 802.1AS-2020, *IEEE Standard for Local and Metropolitan Area Networks – Timing and Synchronization for Time-Sensitive Applications*

IEEE Std 802.1CB-2017, *IEEE Standard for Local and metropolitan area networks – Frame Replication and Elimination for Reliability*

IEEE Std 802.1Q-2018, *IEEE Standard for Local and Metropolitan Area Networks – Bridges and Bridged Networks*

IEEE Std 802.3-2018, *IEEE Standard for Ethernet*

IETF RFC 768, J. Postel, "User Datagram Protocol", August 1980, available at <https://www.rfc-editor.org/info/rfc768> [viewed 2022-09-29]

IETF RFC 791, J. Postel, "Internet Protocol", September 1981, available at <https://www.rfc-editor.org/info/rfc791> [viewed 2022-09-29]

IETF RFC 792, J. Postel, "Internet Control Message Protocol", September 1981, available at <https://www.rfc-editor.org/info/rfc792> [viewed 2022-09-29]

IETF RFC 826, D. Plummer, "An Ethernet Address Resolution Protocol: Or Converting Network Protocol Addresses to 48.bit Ethernet Address for Transmission on Ethernet Hardware", November 1982, available at <https://www.rfc-editor.org/info/rfc826> [viewed 2022-09-29]

IETF RFC 894, C. Hornig, "A Standard for the Transmission of IP Datagrams over Ethernet Networks", April 1984, available at <https://www.rfc-editor.org/info/rfc894> [viewed 2022-09-29]

IETF RFC 1034, P.V. Mockapetris, "Domain names – concepts and facilities", November 1987, available at <https://www.rfc-editor.org/info/rfc1034> [viewed 2022-09-29]

IETF RFC 1112, S.E. Deering, "Host extensions for IP multicasting", August 1989, available at <https://www.rfc-editor.org/info/rfc1112> [viewed 2022-09-29]

IETF RFC 1157, J.D. Case, M. Fedor, M.L. Schoffstall, J. Davin, "Simple Network Management Protocol (SNMP)", May 1990, available at <https://www.rfc-editor.org/info/rfc1157> [viewed 2022-09-29]

IETF RFC 1213, K. McCloghrie, M. Rose, "Management Information Base for Network Management of TCP/IP-based internets: MIB-II", March 1991, available at <https://www.rfc-editor.org/info/rfc1213> [viewed 2022-09-29]

IETF RFC 2131, R. Droms, "Dynamic Host Configuration Protocol", March 1997, available at <https://www.rfc-editor.org/info/rfc2131> [viewed 2022-09-29]

IETF RFC 2132, S. Alexander, R. Droms, "DHCP Options and BOOTP Vendor Extensions", March 1997, available at <https://www.rfc-editor.org/info/rfc2132> [viewed 2022-09-29]

IETF RFC 2365, D. Meyer, "Administratively Scoped IP Multicast", July 1998, available at <https://www.rfc-editor.org/info/rfc2365> [viewed 2022-09-29]

IETF RFC 2674, E. Bell, A. Smith, P. Langille, A. Rijhsinghani, K. McCloghrie, "Definitions of Managed Objects for Bridges with Traffic Classes, Multicast Filtering and Virtual LAN Extensions", August 1999, available at <https://www.rfc-editor.org/info/rfc2674> [viewed 2022-09-29]

IETF RFC 2737, K. McCloghrie, A. Bierman, "Entity MIB (Version 2)", December 1999, available at <https://www.rfc-editor.org/info/rfc2737> [viewed 2022-09-29]

IETF RFC 2863, K. McCloghrie, F. Kastenholz, "The Interfaces Group MIB", June 2000, available at <https://www.rfc-editor.org/info/rfc2863> [viewed 2022-09-29]

IETF RFC 3418, R. Presuhn, Ed., "Management Information Base (MIB) for the Simple Network Management Protocol (SNMP)", December 2002, available at <https://www.rfc-editor.org/info/rfc3418> [viewed 2022-09-29]

IETF RFC 3490, P. Faltstrom, P. Hoffman, A. Costello, "Internationalizing Domain Names in Applications (IDNA)", March 2003, available at <https://www.rfc-editor.org/info/rfc3490> [viewed 2022-09-29]

IETF RFC 3621, A. Berger, D. Romascanu, "Power Ethernet MIB", December 2003, available at <https://www.rfc-editor.org/info/rfc3621> [viewed 2022-09-29]

IETF RFC 4836, E. Beili, "Definitions of Managed Objects for IEEE 802.3 Medium Attachment Units (MAUs)", April 2007, available at <https://www.rfc-editor.org/info/rfc4836> [viewed 2022-09-29]

IETF RFC 5905, D. Mills, J. Martin, Ed., J. Burbank, W. Kasch, "Network Time Protocol Version 4: Protocol and Algorithms Specification", June 2010, available at <https://www.rfc-editor.org/info/rfc5905> [viewed 2022-09-29]

IETF RFC 6020, M. Bjorklund, Ed., "YANG – A Data Modeling Language for the Network Configuration Protocol (NETCONF)", October 2010, available at <https://www.rfc-editor.org/info/rfc6020> [viewed 2022-09-29]

IETF RFC 6241, R. Enns, Ed., M. Bjorklund, Ed., J. Schoenwaelder, Ed., A. Bierman, Ed., "Network Configuration Protocol (NETCONF)", June 2011, available at <https://www.rfc-editor.org/info/rfc6241> [viewed 2022-09-29]

IETF RFC 6890, M. Cotton, L. Vegoda, R. Bonica, Ed., B. Haberman, "Special-Purpose IP Address Registries", April 2013, available at <https://www.rfc-editor.org/info/rfc6890> [viewed 2022-09-29]

The Open Group – Publication C706, *Technical standard DCE1.1: Remote Procedure Call*; available at www.opengroup.org/onlinepubs/9629399/toc.htm [viewed 2022-09-29]

Metro Ethernet Forum – MEF 10.4:2018, Subscriber Ethernet Service Attributes, available at <https://www.mef.net/resources/mef-10-4-subscriber-ethernet-services-attributes> [viewed 2022-09-29]

3 Terms, definitions, abbreviated terms, symbols and conventions

For the purposes of this document, the following terms, definitions, symbols, abbreviated terms and conventions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

3.1 Referenced terms and definitions

3.1.1 ISO/IEC 7498-1 terms

For the purposes of this document, the following terms as defined in ISO/IEC 7498-1 apply:

- a) application entity
- b) application process
- c) application protocol data unit
- d) application service element
- e) application entity invocation