

# INTERNATIONAL STANDARD



**Power cables with extruded insulation and their accessories for rated voltages from 1 kV ( $U_m = 1,2$  kV) up to 30 kV ( $U_m = 36$  kV) –  
Part 2: Cables for rated voltages from 6 kV ( $U_m = 7,2$  kV) up to 30 kV ( $U_m = 36$  kV)**



**THIS PUBLICATION IS COPYRIGHT PROTECTED**  
**Copyright © 2024 IEC, Geneva, Switzerland**

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Secretariat  
3, rue de Varembe  
CH-1211 Geneva 20  
Switzerland

Tel.: +41 22 919 02 11  
[info@iec.ch](mailto:info@iec.ch)  
[www.iec.ch](http://www.iec.ch)

**About the IEC**

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

**About IEC publications**

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

**IEC publications search - [webstore.iec.ch/advsearchform](http://webstore.iec.ch/advsearchform)**

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

**IEC Just Published - [webstore.iec.ch/justpublished](http://webstore.iec.ch/justpublished)**

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

**IEC Customer Service Centre - [webstore.iec.ch/csc](http://webstore.iec.ch/csc)**

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: [sales@iec.ch](mailto:sales@iec.ch).

**IEC Products & Services Portal - [products.iec.ch](http://products.iec.ch)**

Discover our powerful search engine and read freely all the publications previews, graphical symbols and the glossary. With a subscription you will always have access to up to date content tailored to your needs.

**Electropedia - [www.electropedia.org](http://www.electropedia.org)**

The world's leading online dictionary on electrotechnology, containing more than 22 500 terminological entries in English and French, with equivalent terms in 25 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

preview generated by EVS



IEC 60502-2

Edition 3.1 2024-05  
CONSOLIDATED VERSION

# INTERNATIONAL STANDARD



**Power cables with extruded insulation and their accessories for rated voltages from 1 kV ( $U_m = 1,2$  kV) up to 30 kV ( $U_m = 36$  kV) –  
Part 2: Cables for rated voltages from 6 kV ( $U_m = 7,2$  kV) up to 30 kV ( $U_m = 36$  kV)**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

ICS 29.060.20

ISBN 978-2-8322-9033-0

**Warning! Make sure that you obtained this publication from an authorized distributor.**

## CONTENTS

FOREWORD.....	11
1 Scope.....	13
2 Normative references .....	13
3 Terms and definitions .....	15
3.1 Definitions of dimensional values (thicknesses, cross-sections, etc.) .....	15
3.2 Definitions concerning the tests .....	16
4 Voltage designations and materials .....	16
4.1 Rated voltages.....	16
4.2 Insulating compounds .....	17
4.3 Sheathing compounds.....	18
5 Conductors.....	19
6 Insulation.....	19
6.1 Material .....	19
6.2 Insulation thickness .....	19
7 Screening.....	20
7.1 General.....	20
7.2 Conductor screen.....	20
7.3 Insulation screen .....	20
8 Assembly of three-core cables, inner coverings and fillers.....	21
8.1 General.....	21
8.2 Inner coverings and fillers.....	21
8.2.1 Construction .....	21
8.2.2 Material .....	21
8.2.3 Thickness of extruded inner covering.....	21
8.2.4 Thickness of lapped inner covering.....	21
8.3 Cables having a collective metal layer (see Clause 9).....	22
8.4 Cables having a metal layer over each individual core (see Clause 10).....	22
9 Metal layers for single-core and three-core cables.....	22
10 Metal screen.....	22
10.1 Construction .....	22
10.2 Requirements .....	23
10.3 Metal screens not associated with semi-conducting layers.....	23
11 Concentric conductor.....	23
11.1 Construction .....	23
11.2 Requirements .....	23
11.3 Application.....	23
12 Metal sheath.....	23
12.1 Lead sheath.....	23
12.2 Other metal sheaths.....	23
13 Metal armour.....	24
13.1 Types of metal armour .....	24
13.2 Materials.....	24
13.3 Application of armour.....	24
13.3.1 Single-core cables.....	24
13.3.2 Three-core cables.....	24

13.3.3	Separation sheath .....	24
13.3.4	Lapped bedding under armour for lead sheathed cables .....	25
13.4	Dimensions of the armour wires, <del>and</del> armour tapes and armour strips .....	25
13.5	Correlation between cable diameters and armour dimensions .....	25
13.6	Round or flat wire armour .....	26
13.7	Double tape armour .....	26
13.8	Interlock metal tape armour .....	27
14	Oversheath .....	27
14.1	General .....	27
14.2	Material .....	27
14.3	Thickness .....	28
15	Test conditions .....	28
15.1	Ambient temperature .....	28
15.2	Frequency and waveform of power frequency test voltages .....	28
15.3	Waveform of impulse test voltages .....	28
15.4	Determination of the cable conductor temperature .....	28
16	Routine tests .....	29
16.1	General .....	29
16.2	Electrical resistance of conductors .....	29
16.3	Partial discharge test .....	29
16.4	Voltage test .....	29
16.4.1	General .....	29
16.4.2	Test procedure for single-core cables .....	30
16.4.3	Test procedure for three-core cables .....	30
16.4.4	Test voltage .....	30
16.4.5	Requirement .....	30
16.5	Electrical test on oversheath of the cable .....	30
17	Sample tests .....	30
17.1	General .....	30
17.2	Frequency of sample tests .....	31
17.2.1	Conductor examination and check of dimensions .....	31
17.2.2	Electrical and physical tests .....	31
17.3	Repetition of tests .....	31
17.4	Conductor examination .....	31
17.5	Measurement of thickness of insulation and of non-metal sheaths (including extruded separation sheaths, but excluding inner extruded coverings) .....	31
17.5.1	General .....	31
17.5.2	Requirements for the insulation .....	31
17.5.3	Requirements for the non-metal sheaths .....	32
17.6	Measurement of thickness of lead sheath .....	32
17.6.1	General .....	32
17.6.2	Strip method .....	32
17.6.3	Ring method .....	32
17.7	Measurement of armour wires, <del>and</del> tapes and armour strips .....	33
17.7.1	Measurement on wires .....	33
17.7.2	Measurement on tapes and armour strips .....	33
17.7.3	Requirements .....	33

17.8	Measurement of external diameter .....	33
17.9	Voltage test for 4 h .....	33
17.9.1	Sampling .....	33
17.9.2	Procedure.....	33
17.9.3	Test voltages .....	33
17.9.4	Requirements .....	34
17.10	Hot set test for EPR, HEPR and XLPE insulations and elastomeric sheaths.....	34
17.10.1	Procedure.....	34
17.10.2	Requirements .....	34
17.11	Bending test on interlock armour cable followed by examination .....	34
18	Type tests, electrical .....	34
18.1	General.....	34
18.2	Cables having conductor screens and insulation screens.....	34
18.2.1	General .....	34
18.2.2	Sequence of tests.....	35
18.2.3	Special provisions .....	35
18.2.4	Bending test .....	35
18.2.5	Partial discharge test.....	36
18.2.6	Tan $\delta$ measurement for cables of rated voltage 6/10 (12) kV and above.....	36
18.2.7	Heating cycle test .....	36
18.2.8	Impulse test followed by a voltage test .....	37
18.2.9	Voltage test for 4 h .....	37
18.2.10	Resistivity of semi-conducting screens .....	37
18.3	Cables of rated voltage 3,6/6 (7,2) kV having unscreened insulation .....	38
18.3.1	General .....	38
18.3.2	Insulation resistance measurement at ambient temperature.....	38
18.3.3	Insulation resistance measurement at maximum conductor temperature .....	39
18.3.4	Voltage test for 4 h .....	39
18.3.5	Impulse test.....	39
19	Type tests, non-electrical.....	40
19.1	General.....	40
19.2	Measurement of thickness of insulation.....	40
19.2.1	Sampling .....	40
19.2.2	Procedure.....	40
19.2.3	Requirements .....	40
19.3	Measurement of thickness of non-metal sheaths (including extruded separation sheaths, but excluding inner coverings) .....	40
19.3.1	Sampling .....	40
19.3.2	Procedure.....	40
19.3.3	Requirements .....	40
19.4	Measurement of thickness of lead sheath .....	40
19.4.1	Sampling .....	40
19.4.2	Procedure.....	40
19.4.3	Requirements .....	40
19.5	Tests for determining the mechanical properties of insulation before and after ageing .....	40

19.5.1	Sampling .....	40
19.5.2	Ageing treatments .....	41
19.5.3	Conditioning and mechanical tests.....	41
19.5.4	Requirements .....	41
19.6	Tests for determining the mechanical properties of non-metal sheaths before and after ageing.....	41
19.6.1	Sampling .....	41
19.6.2	Ageing treatments .....	41
19.6.3	Conditioning and mechanical tests.....	41
19.6.4	Requirements .....	41
19.7	Additional ageing test on pieces of completed cables.....	41
19.7.1	General .....	41
19.7.2	Sampling .....	41
19.7.3	Ageing treatment .....	41
19.7.4	Mechanical tests.....	42
19.7.5	Requirements .....	42
19.8	Loss of mass test on PVC sheaths of type ST <sub>2</sub> .....	42
19.8.1	Procedure.....	42
19.8.2	Requirements .....	42
19.9	Pressure test at high temperature on insulations and non-metal sheaths .....	42
19.9.1	Procedure.....	42
19.9.2	Requirements .....	42
19.10	Test on PVC insulation, <del>and</del> PVC sheaths and halogen free sheaths at low temperatures .....	42
19.10.1	Procedure.....	42
19.10.2	Requirements .....	42
19.11	Test for resistance of PVC insulation and sheaths to cracking (heat shock test).....	42
19.11.1	Procedure.....	42
19.11.2	Requirements .....	42
19.12	Ozone resistance test for EPR and HEPR insulations .....	43
19.12.1	Procedure.....	43
19.12.2	Requirements .....	43
19.13	Hot set test for EPR, HEPR and XLPE insulations and elastomeric sheaths.....	43
19.14	Oil immersion test for elastomeric sheaths .....	43
19.14.1	Procedure.....	43
19.14.2	Requirements .....	43
19.15	Water absorption test on insulation .....	43
19.15.1	Procedure.....	43
19.15.2	Requirements .....	43
<del>19.16</del>	<del>Flame spread test on single cables .....</del>	<del>43</del>
19.16	Test under fire conditions.....	43
19.16.1	General .....	43
19.16.2	Flame spread test for single cables .....	43
19.16.3	Flame spread test for bunched cables .....	44
19.16.4	Measurement of smoke density of cables burning under defined conditions .....	44

19.16.5	Determination of acidity (by pH measurement) and conductivity of gases evolved during combustion of the non-metallic materials in the cable.....	44
19.16.6	Fire performance tests on halogen free oversheath material ST <sub>8</sub> .....	44
19.16.7	Fire performance tests on halogen free oversheath material ST <sub>12</sub> .....	45
19.16.8	Measurement of halogen content of gases evolved during combustion of the non-metallic materials in the cable .....	45
19.17	Measurement of carbon black content of black PE oversheaths .....	45
19.17.1	Procedure.....	45
19.17.2	Requirements .....	45
19.18	Shrinkage test for XLPE insulation .....	46
19.18.1	Procedure.....	46
19.18.2	Requirements .....	46
19.19	Thermal stability test for PVC insulation.....	46
19.19.1	Procedure.....	46
19.19.2	Requirements .....	46
19.20	Determination of hardness of HEPR insulation .....	46
19.20.1	Procedure.....	46
19.20.2	Requirements .....	46
19.21	Determination of the elastic modulus of HEPR insulation .....	46
19.21.1	Procedure.....	46
19.21.2	Requirements .....	46
19.22	Shrinkage test for PE and halogen free oversheaths .....	46
19.22.1	Procedure.....	46
19.22.2	Requirements .....	46
19.23	Strippability test for insulation screen.....	47
19.23.1	General .....	47
19.23.2	Procedure.....	47
19.23.3	Requirements .....	47
19.24	Water penetration test.....	47
19.25	Additional tests on halogen free oversheath of type ST <sub>8</sub> .....	48
19.25.1	General .....	48
19.25.2	Water absorption test for halogen free oversheath of type ST <sub>8</sub> .....	48
19.25.3	Abrasion test on halogen free oversheath of type ST <sub>8</sub> .....	48
19.26	Bending test on interlock armour.....	48
20	Electrical tests after installation .....	48
20.1	General.....	48
20.2	DC voltage test of the oversheath .....	48
20.3	<b>Insulation test</b> AC voltage test of the insulation .....	48
Annex A (normative) Fictitious calculation method for determination of dimensions of protective coverings.....		58
A.1	General.....	58
A.2	Method .....	58
A.2.1	Conductors .....	58
A.2.2	Cores .....	59
A.2.3	Diameter over laid-up cores.....	59
A.2.4	Inner coverings.....	59
A.2.5	Concentric conductors and metal screens.....	60

A.2.6	Lead sheath.....	61
A.2.7	Separation sheath .....	61
A.2.8	Lapped bedding.....	61
A.2.9	Additional bedding for tape-armoured cables (provided over the inner covering).....	62
A.2.10	Armour .....	62
Annex B (informative)	Tabulated continuous current ratings for cables having extruded insulation and a rated voltage from 3,6/6 kV up to 18/30 kV .....	63
B.1	General.....	63
B.2	Cable constructions .....	63
B.3	Temperatures .....	63
B.4	Soil thermal resistivity .....	64
B.5	Methods of installation .....	64
B.5.1	General .....	64
B.5.2	Single-core cables in air .....	64
B.5.3	Single-core cables buried direct.....	64
B.5.4	Single-core cables in earthenware ducts.....	65
B.5.5	Three-core cables.....	65
B.6	Screen bonding.....	66
B.7	Cable loading.....	66
B.8	Rating factors for grouped circuits .....	66
B.9	Correction factors .....	66
Annex C (normative)	Rounding of numbers.....	82
C.1	Rounding of numbers for the purpose of the fictitious calculation method.....	82
C.2	Rounding of numbers for other purposes .....	82
Annex D (normative)	Method of measuring resistivity of semi-conducting screens .....	83
Annex E (normative)	Determination of hardness of HEPR insulations .....	86
E.1	Test piece.....	86
E.2	Test procedure.....	86
E.2.1	General .....	86
E.2.2	Surfaces of large radius of curvature .....	86
E.2.3	Surfaces of small radius of curvature .....	86
E.2.4	Conditioning and test temperature .....	86
E.2.5	Number of measurements.....	87
Annex F (normative)	Water penetration test.....	88
F.1	Test piece.....	88
F.2	Test .....	88
F.3	Requirements .....	89
Annex G (informative)	Determination of the cable conductor temperature .....	90
G.1	Purpose .....	90
G.2	Calibration of the temperature of the main test loop .....	90
G.2.1	General .....	90
G.2.2	Installation of cable and temperature sensors .....	90
G.2.3	Calibration method .....	92
G.3	Heating for the test .....	93
G.3.1	Method 1 – Test using a reference cable .....	93
G.3.2	Method 2 – Test using conductor temperature calculations and measurement of the surface temperature .....	93

Annex H (normative) Test for water penetration in the conductor .....	95
H.1 General.....	95
H.2 Test piece .....	95
H.3 Test .....	95
H.4 Requirements .....	95
Annex I (normative) Methods of determining the weighted value of halogen content of the non-metallic materials in the cable .....	97
I.1 Calculating the weighted value of the cable when the halogen content of individual materials is tested .....	97
I.2 Preparation of the test sample for measurement of halogen content on a sample representative of the non-metallic materials in the cable .....	97
Bibliography.....	98
Figure B.1 – Single-core cables in air .....	64
Figure B.2 – Single-core cables buried direct.....	65
Figure B.3 – Single-core cables in earthenware ducts.....	65
Figure B.4 – Three-core cables.....	66
Figure D.1 – Preparation of samples for measurement of resistivity of conductor and insulation screens.....	85
Figure E.1 – Test on surfaces of large radius of curvature .....	87
Figure E.2 – Test on surfaces of small radius of curvature .....	87
Figure F.1 – Schematic diagram of apparatus for water penetration test .....	89
Figure G.1 – Typical test set-up for the reference loop and the main test loop .....	91
Figure G.2 – Example of an arrangement of the temperature sensors on the conductor of the reference loop.....	92
Figure H.1 – Schematic diagram of apparatus for water penetration test in the conductor.....	96
Table 1 – Recommended rated voltages $U_0$ .....	17
Table 2 – Insulating compounds.....	17
Table 3 – Maximum conductor temperatures for different types of insulating compound.....	18
Table 4 – Maximum conductor temperatures for different types of sheathing compound .....	18
Table 5 – Nominal thickness of PVC/B insulation .....	19
Table 6 – Nominal thickness of cross-linked polyethylene (XLPE) insulation.....	19
Table 7 – Nominal thickness of ethylene propylene rubber (EPR) and hard ethylene propylene rubber (HEPR) insulation.....	20
Table 8 – Thickness of extruded inner covering .....	21
Table 9 – Nominal diameter of round armour wires .....	26
Table 10 – Nominal thickness of armour tapes .....	26
Table 24 – Nominal thickness of armour strips.....	26
Table 11 – Routine test voltages.....	30
Table 12 – Number of samples for sample tests.....	31
Table 13 – Sample test voltages .....	34
Table 14 – Impulse voltages .....	37
Table 15 – Electrical type test requirements for insulating compounds.....	49
Table 16 – Non-electrical type tests (see Table 17 to Table 23 and Table 25).....	50

Table 17 – Test requirements for mechanical characteristics of insulating compounds (before and after ageing) .....	51
Table 18 – Test requirements for particular characteristics for PVC insulating compound.....	52
Table 19 – Test requirements for particular characteristics of various crosslinked insulating compounds .....	53
Table 20 – Test requirements for mechanical characteristics of sheathing compounds (before and after ageing) .....	54
Table 21 – Test requirements for particular characteristics for PVC sheathing compounds .....	54
Table 22 – Test requirements for particular characteristics of PE (thermoplastic polyethylene) sheathing compounds .....	55
Table 23 – Test requirements for particular characteristics of elastomeric sheathing compound.....	55
Table 25 – Test requirements for particular characteristics of halogen free sheathing compounds .....	56
Table A.1 – Fictitious diameter of conductor .....	59
Table A.2 – Increase of diameter for concentric conductors and metal screens.....	60
Table A.3 – Increase of diameter for additional bedding.....	62
Table A.4 – Increase of diameter over interlocked armour.....	62
Table B.1 – Nominal screen cross-sectional areas .....	63
Table B.2 – Current ratings for single-core cables with XLPE insulation – Rated voltage 3,6/6 kV to 18/30 kV * – Copper conductor .....	67
Table B.3 – Current ratings for single-core cables with XLPE insulation – Rated voltage 3,6/6 kV to 18/30 kV * – Aluminium conductor.....	68
Table B.4 – Current ratings for single-core cables with EPR insulation – Rated voltage 3,6/6 kV to 18/30 kV * – Copper conductor .....	69
Table B.5 – Current ratings for single-core cables with EPR insulation – Rated voltage 3,6/6 kV to 18/30 kV * – Aluminium conductor.....	70
Table B.6 – Current rating for three-core XLPE insulated cables – Rated voltage 3,6/6 kV to 18/30 kV * – Copper conductor, armoured and unarmoured .....	71
Table B.7 – Current rating for three-core XLPE insulated cables – Rated voltage 3,6/6 kV to 18/30 kV * – Aluminium conductor, armoured and unarmoured.....	72
Table B.8 – Current rating for three-core EPR insulated cables – Rated voltage 3,6/6 kV to 18/30 kV * – Copper conductor, armoured and unarmoured .....	73
Table B.9 – Current rating for three-core EPR insulated cables – Rated voltage 3,6/6 kV to 18/30 kV * – Aluminium conductor, armoured and unarmoured.....	74
Table B.10 – Correction factors for ambient air temperatures other than 30 °C.....	74
Table B.11 – Correction factors for ambient ground temperatures other than 20 °C .....	75
Table B.12 – Correction factors for depths of laying other than 0,8 m for direct buried cables.....	75
Table B.13 – Correction factors for depths of laying other than 0,8 m for cables in ducts .....	75
Table B.14 – Correction factors for soil thermal resistivities other than 1,5 K·m/W for direct buried single-core cables .....	76
Table B.15 – Correction factors for soil thermal resistivities other than 1,5 K·m/W single-core cables in buried ducts .....	76
Table B.16 – Correction factors for soil thermal resistivities other than 1,5 K·m/W for direct buried three-core cables.....	77

Table B.17 – Correction factors for soil thermal resistivities other than 1,5 K·m/W for three-core cables in ducts ..... 77

Table B.18 – Correction factors for groups of three-core cables in horizontal formation laid direct in the ground ..... 78

Table B.19 – Correction factors for groups of three-phase circuits of single-core cables laid direct in the ground ..... 78

Table B.20 – Correction factors for groups of three-core cables in single way ducts in horizontal formation ..... 79

Table B.21 – Correction factors for groups of three-phase circuits of single-core cables in single-way ducts ..... 79

Table B.22 – Reduction factors for groups of more than one multi-core cable in air – To be applied to the current-carrying capacity for one multi-core cable in free air ..... 80

Table B.23 – Reduction factors for groups of more than one circuit of single-core cables (Note 2) – To be applied to the current-carrying capacity for one circuit of single-core cables in free air ..... 81

This document is a preview generated by EVS

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

### **POWER CABLES WITH EXTRUDED INSULATION AND THEIR ACCESSORIES FOR RATED VOLTAGES FROM 1 kV ( $U_m = 1,2$ kV) UP TO 30 kV ( $U_m = 36$ kV) –**

#### **Part 2: Cables for rated voltages from 6 kV ( $U_m = 7,2$ kV) up to 30 kV ( $U_m = 36$ kV)**

### FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

**This consolidated version of the official IEC Standard and its amendment has been prepared for user convenience.**

**IEC 60502-2 edition 3.1 contains the third edition (2014-02) [documents 20/1469A/FDIS and 20/1472/RVD] and its amendment 1 (2024-05) [documents 20/2166/FDIS and 20/2181/RVD].**

**In this Redline version, a vertical line in the margin shows where the technical content is modified by amendment 1. Additions are in green text, deletions are in strikethrough**

**red text. A separate Final version with all changes accepted is available in this publication.**

International Standard IEC 60502-2 has been prepared by IEC technical committee 20: Electric cables.

This third edition cancels and replaces the second edition, published in 2005, and constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) a simplified calculation procedure for the thickness of the lead sheath and the oversheath;
- b) a new subclause for the determination of the cable conductor temperature;
- c) a modified procedure for the routine voltage test;
- d) a new subclause for a routine electrical test on oversheath;
- e) modified requirements for the non-metal sheaths including semi-conductive layer;
- f) modified tolerances for the bending test cylinder;
- g) the inclusion of a 0,1Hz test after installation.

In addition, the modified structure of the IEC 60811 series has been adopted for this third edition.

The following editorial changes have been made within the English version:

- 'metallic' has been replaced by 'metal';
- 'thermosetting' has been replaced by 'crosslinked'.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 60502 series, published under the general title *Power cables with extruded insulation and their accessories for rated voltages from 1kV ( $U_m = 1,2$  kV) up to 30 kV ( $U_m = 36$  kV)*, can be found on the IEC website.

The committee has decided that the contents of this document and its amendment will remain unchanged until the stability date indicated on the IEC website under [webstore.iec.ch](http://webstore.iec.ch) in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

**IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.**

**POWER CABLES WITH EXTRUDED INSULATION  
AND THEIR ACCESSORIES FOR RATED VOLTAGES  
FROM 1 kV ( $U_m = 1,2$  kV) UP TO 30 kV ( $U_m = 36$  kV) –**

**Part 2: Cables for rated voltages from 6 kV  
( $U_m = 7,2$  kV) up to 30 kV ( $U_m = 36$  kV)**

## 1 Scope

This part of IEC 60502 specifies the construction, dimensions and test requirements of power cables with extruded solid insulation from 6 kV up to 30 kV for fixed installations such as distribution networks or industrial installations.

When determining applications, it is recommended that the possible risk of radial water ingress is considered. Cable designs with barriers claimed to prevent longitudinal water penetration and an associated test are included in this part of IEC 60502.

Cables for special installation and service conditions are not included, for example cables for overhead networks, the mining industry, nuclear power plants (in and around the containment area) nor for submarine use or shipboard application.

## 2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60038, *IEC standard voltages*

IEC 60060-1, *High-voltage test techniques – Part 1: General definitions and test requirements*

IEC 60060-3, *High-voltage test techniques – Part 3: Definitions and requirements for on-site testing*

IEC 60183, *Guide to the selection of high-voltage cables*

IEC 60228, *Conductors of insulated cables*

IEC 60229:2007, *Tests on cable oversheaths which have a special protective function and are applied by extrusion*

IEC 60230, *Impulse tests on cables and their accessories*

IEC 60287-3-1, *Electric cables – Calculation of the current rating – Part 3: Sections on operating conditions – Section 1: Reference operating conditions and selection of cable type*

IEC 60332-1-2, *Tests on electric and optical fibre cables under fire conditions – Part 1-2: Test for vertical flame propagation for a single insulated wire or cable – Procedure for 1 kW pre-mixed flame*

IEC 60332-3-24, *Tests on electric and optical fibre cables under fire conditions – Part 3-24: Test for vertical flame spread of vertically-mounted bunched wires or cables – Category C*

IEC 60684-2, *Flexible insulating sleeving – Part 2: Methods of test*

IEC 60754-1, *Test on gases evolved during combustion of materials from cables – Part 1: Determination of the halogen acid gas content*

IEC 60754-2, *Test on gases evolved during combustion of materials from cables – Part 2: Determination of acidity (by pH measurement) and conductivity*

IEC 60754-3, *Test on gases evolved during combustion of materials from cables – Part 3: Measurement of low level of halogen content by ion chromatography*

IEC 60811 (all parts), *Electric and optical fibre cables – Test methods for non-metallic materials*

IEC 60811-201, *Electric and optical fibre cables – Test methods for non-metallic materials – Part 201: General tests – Measurement of insulation thickness*

IEC 60811-202, *Electric and optical fibre cables – Test methods for non-metallic materials – Part 202: General tests – Measurement of thickness of non-metallic sheath*

IEC 60811-203, *Electric and optical fibre cables – Test methods for non-metallic materials – Part 203: General tests – Measurement of overall dimensions*

IEC 60811-401, *Electric and optical fibre cables – Test methods for non-metallic materials – Part 401: Miscellaneous tests – Thermal ageing methods – Ageing in an air oven*

IEC 60811-402, *Electric and optical fibre cables – Test methods for non-metallic materials – Part 402: Miscellaneous tests – Water absorption tests*

IEC 60811-403, *Electric and optical fibre cables – Test methods for non-metallic materials – Part 403: Miscellaneous tests – Ozone resistance test on cross-linked compounds*

IEC 60811-404, *Electric and optical fibre cables – Test methods for non-metallic materials – Part 404: Miscellaneous tests – Mineral oil immersion tests for sheaths*

IEC 60811-405, *Electric and optical fibre cables – Test methods for non-metallic materials – Part 405: Miscellaneous tests – Thermal stability test for PVC insulations and PVC sheaths*

IEC 60811-409, *Electric and optical fibre cables – Test methods for non-metallic materials – Part 409: Miscellaneous tests – Loss of mass test for thermoplastic insulations and sheaths*

IEC 60811-501, *Electric and optical fibre cables – Test methods for non-metallic materials – Part 501: Mechanical tests – Tests for determining the mechanical properties of insulating and sheathing compounds*

IEC 60811-502, *Electric and optical fibre cables – Test methods for non-metallic materials – Part 502: Mechanical tests – Shrinkage test for insulations*

IEC 60811-503, *Electric and optical fibre cables – Test methods for non-metallic materials – Part 503: Mechanical tests – Shrinkage test for sheaths*

IEC 60811-504, *Electric and optical fibre cables – Test methods for non-metallic materials – Part 504: Mechanical tests – Bending tests at low temperature for insulation and sheaths*

IEC 60811-505, *Electric and optical fibre cables – Test methods for non-metallic materials – Part 505: Mechanical tests – Elongation at low temperature for insulations and sheaths*

IEC 60811-506, *Electric and optical fibre cables – Test methods for non-metallic materials – Part 506: Mechanical tests – Impact test at low temperature for insulations and sheaths*

IEC 60811-507, *Electric and optical fibre cables – Test methods for non-metallic materials – Part 507: Mechanical tests – Hot set test for cross-linked materials*

IEC 60811-508, *Electric and optical fibre cables – Test methods for non-metallic materials – Part 508: Mechanical tests – Pressure test at high temperature for insulation and sheaths*

IEC 60811-509, *Electric and optical fibre cables – Test methods for non-metallic materials – Part 509: Mechanical tests – Test for resistance of insulations and sheaths to cracking (heat shock test)*

IEC 60811-605, *Electric and optical fibre cables – Test methods for non-metallic materials – Part 605: Physical tests – Measurement of carbon black and/or mineral filler in polyethylene compounds*

IEC 60811-606, *Electric and optical fibre cables – Test methods for non-metallic materials – Part 606: Physical tests – Methods for determining the density*

IEC 60853 (all parts), *Calculation of the cyclic and emergency current rating of cables*

IEC 60853-2, *Calculation of the cyclic and emergency current rating of cables – Part 2: Cyclic rating of cables greater than 18/30 (36) kV and emergency ratings for cables of all voltages*

IEC 60885-3, *Electrical test methods for electric cables – Part 3: Test methods for partial discharge measurements on lengths of extruded power cables*

IEC 60986, *Short-circuit temperature limits of electric cables with rated voltages from 6 kV ( $U_m = 7,2$  kV) up to 30 kV ( $U_m = 36$  kV)*

IEC 61034-2, *Measurement of smoke density of cables burning under defined conditions – Part 2: Test procedure and requirements*

ISO 48, *Rubber, vulcanized or thermoplastic – Determination of hardness (hardness between 10 IRHD and 100 IRHD)*

### **3 Terms and definitions**

For the purposes of this document, the following terms and definitions apply.

#### **3.1 Definitions of dimensional values (thicknesses, cross-sections, etc.)**

##### **3.1.1**

##### **nominal value**

value by which a quantity is designated and which is often used in tables

Note 1 to entry: Usually, in this standard, nominal values give rise to values to be checked by measurements taking into account specified tolerances.