

GAASIPÕLETITE JA GAASISEADMETE OHUTUS- JA
JUHTSEADMED. OSA 2: RÕHUREGULAATORID
SISENDRÕHULE 50 KPA KUNI 500 KPA (K.A)

Safety and control devices for gas burners and gas
burning appliances - Part 2: Pressure regulators for
inlet pressures above 50 kPa up to and including 500
kPa

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

<p>See Eesti standard EVS-EN 88-2:2022+A1:2025 sisaldab Euroopa standardi EN 88-2:2022+A1:2024 ingliskeelset teksti.</p> <p>Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.</p> <p>Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 06.11.2024.</p> <p>Standard on kättesaadav Eesti Standardimis- ja Akrediteerimiskeskusest.</p>	<p>This Estonian standard EVS-EN 88-2:2022+A1:2025 consists of the English text of the European standard EN 88-2:2022+A1:2024.</p> <p>This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation and Accreditation.</p> <p>Date of Availability of the European standard is 06.11.2024.</p> <p>The standard is available from the Estonian Centre for Standardisation and Accreditation.</p>
--	---

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 23.060.40

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardimis- ja Akrediteerimiskeskusele. Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardimis- ja Akrediteerimiskeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardimis- ja Akrediteerimiskeskusega: Koduleht www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation and Accreditation. No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation and Accreditation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation and Accreditation: Homepage www.evs.ee; phone +372 605 5050; e-mail info@evs.ee

ICS 23.060.40

English Version

Safety and control devices for gas burners and gas burning appliances - Part 2: Pressure regulators for inlet pressures above 50 kPa up to and including 500 kPa

Dispositifs de sécurité et de contrôle pour les brûleurs à gaz et appareils utilisant des combustibles gazeux -
Partie 2 : Régulateurs de pression pour pressions amont comprises entre 50 kPa et 500 kPa

Sicherheits- und Regeleinrichtungen für Gasbrenner und Gasgeräte - Teil 2: Druckregler für Eingangsdrücke über 50 kPa bis einschließlich 500 kPa

This European Standard was approved by CEN on 8 August 2022 and includes Amendment 1 approved by CEN on 3 July 2024.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents	Page
European foreword.....	5
Introduction.....	6
1 Scope.....	8
2 Normative references.....	8
3 Terms and definitions.....	9
4 Classification.....	14
4.1 Classes of control.....	14
4.2 Groups of control.....	14
4.3 Classes of control functions.....	14
4.4 Types of <i>DC</i> supplied controls.....	15
5 Test conditions and uncertainty of measurements.....	15
6 Design and construction.....	15
6.1 General.....	15
6.2 Mechanical parts of the control.....	15
6.2.1 Appearance.....	15
6.2.2 Holes.....	15
6.2.3 Breather holes.....	15
6.2.4 Screwed fastenings.....	15
6.2.5 Jointing.....	15
6.2.6 Moving parts.....	15
6.2.7 Sealing caps.....	15
6.2.8 Dismantling and reassembly.....	15
6.2.9 Auxiliary canals and orifices.....	15
6.2.10 Presetting device.....	16
6.2.101 External visual indication of the position of the closure member.....	16
6.2.102 Parts transmitting actuating forces.....	16
6.2.103 Adjustments.....	16
6.2.104 Integral safety shut-off device.....	16
6.2.105 Resistance to pressure.....	16
6.2.106 Signal tube connections.....	17
6.2.107 Creep relief device.....	17
6.3 Materials.....	17
6.3.1 General material requirements.....	17
6.3.2 Housing.....	18
6.3.3 Zinc alloys.....	18
6.3.4 Springs.....	18
6.3.5 Resistance to corrosion and surface protection.....	18
6.3.6 Impregnation.....	18
6.3.7 Seals for glands for moving parts.....	18
6.4 Gas connections.....	18
6.5 Electrical parts of the control.....	18
6.5.1 General.....	18
6.5.2 Switching elements.....	18
6.5.3 Electrical components.....	18
6.6 Protection against internal faults for the purpose of functional safety.....	18

7	Performance	18
7.1	General.....	18
7.2	Leak-tightness.....	19
7.2.1	Requirements.....	19
7.2.2	Tests.....	19
7.3	Torsion and bending.....	19
7.4	Rated flow rate.....	19
7.4.1	Requirements.....	19
7.4.2	Test.....	19
7.4.3	Conversion of air flow rate.....	20
7.5	Durability.....	20
7.5.1	Elastomers in contact with gas.....	20
7.5.2	Marking.....	20
7.5.3	Resistance to scratching.....	20
7.5.4	Resistance to humidity.....	20
7.6	Performance tests for electronic controls.....	20
7.7	Long-term performance for electronic controls.....	20
7.8	Data exchange.....	20
7.101	Pressure regulator performance.....	20
7.101.1	General.....	20
7.101.2	General test procedure.....	20
7.102	Safety devices.....	26
7.102.1	Over-pressure safety shut-off devices.....	26
7.102.2	Under-pressure safety shut-off devices.....	30
7.102.3	Endurance of safety device.....	30
8	Electrical requirements	31
8.1	General.....	31
8.2	Protection by enclosure.....	31
8.101	Plug connections.....	31
9	Electromagnetic compatibility (EMC)	32
9.1	Protection against environmental influences.....	32
9.2	Supply voltage variations below 85 % of rated voltage.....	32
9.3	Voltage dips and interruptions.....	32
9.4	Supply frequency variations.....	32
9.5	Surge immunity tests.....	32
9.6	Electrical fast transient/burst.....	32
9.7	Immunity to conducted disturbances induced by radio frequency fields.....	32
9.8	Immunity to radiated disturbances induced by radio frequency fields.....	32
9.9	Electrostatic discharge tests.....	32
9.10	Power frequency magnetic field immunity tests.....	32
9.11	Harmonics and interharmonics including mains signalling at a. c. power port, low frequency immunity tests.....	32
10	Marking, instructions	33
10.1	Marking.....	33
10.2	Instructions.....	33
10.3	Warning notice.....	34
Annex A (informative) Abbreviations and Symbols		35
Annex B (informative) Leak-tightness tests for gas controls – volumetric method		36
Annex C (informative) Leak-tightness tests for gas controls – pressure loss method		37
Annex D (normative) Conversion of pressure loss into leakage rate		38

Annex E (normative) Electrical/electronic component fault modes.....	39
Annex F (normative) Additional requirements for safety accessories and pressure accessories as defined in EU Directive 2014/68/EU	40
Annex G (normative) Materials for pressurized parts.....	41
Annex H (normative) Additional materials for pressurized parts.....	42
Annex I (normative) Requirements for controls used in DC supplied burners and appliances burning gaseous or liquid fuels	43
Annex J (normative) Method for the determination of a Safety Integrity Level (SIL)	44
Annex K (normative) Method for the determination of a Performance Level (PL).....	45
Annex L (informative) Relationship between Safety Integrity Level (SIL) and Performance Level (PL)	46
Annex M (normative) Reset functions	47
Annex N (informative) Guidance document on Environmental Aspects.....	48
Annex O (normative) Seals of elastomer, cork and synthetic fibre mixtures.....	49
Annex AA (informative) Typical pressure regulators and safety devices	50
AA.1 Main components of a pressure regulator	50
AA.2 Main components of a safety shut-off device	53
Annex BB (informative) Overview of requirements and test conditions (as given in 7.101), and examples of performance curves for pressure regulators	55
Annex CC (normative) Creep relief device	58
CC.1 General.....	58
CC.2 Design and construction.....	58
CC.3 Performance requirements.....	58
CC.4 Marking, instructions	58
Annex DD (informative) Comparison between EN 334:2019 and $\boxed{A_1}$ EN 88-2:2022+A1:2024 $\boxed{A_1}$	59
Annex ZA (informative) Relationship between this European Standard and the essential requirements of Regulation (EU) 2016/426 aimed to be covered.....	60
Bibliography.....	63

European foreword

This document (EN 88-2:2022+A1:2024) has been prepared by Technical Committee CEN/TC 58 “Safety and control devices for burners and appliances burning gaseous or liquid fuels”, the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by May 2025, and conflicting national standards shall be withdrawn at the latest by November 2027.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document includes Amendment 1 approved by CEN on 3 July 2024.

The start and finish of text introduced or altered by amendment is indicated in the text by tags A1 A1.

This document supersedes A1 EN 88-2:2022.

This standard differs from EN 88:2022 as follows:

a) Annex ZA has been brought in line with Mandate M/595 and the normative references are updated. A1

A1 *deleted text* A1

This document has been prepared under a Standardization Request given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directive(s) / Regulation(s).

For relationship with EU Directive(s) / Regulation(s), see informative Annex ZA, which is an integral part of this document.

The EN 88 series consists of the following parts:

- EN 88-1, *Safety and control devices for gas burners and gas burning appliances — Part 1: Pressure regulators for inlet pressures up to and including 50 kPa;*
- EN 88-2, *Safety and control devices for gas burners and gas burning appliances — Part 2: Pressure regulators for inlet pressures above 50 kPa up to and including 500 kPa;*
- EN 88-3, *Safety and control devices for gas burners and gas burning appliances — Part 3: Pressure and/or flow rate regulators for inlet pressures up to and including 500 kPa, electronic types.*

Any feedback and questions on this document should be directed to the users’ national standards body. A complete listing of these bodies can be found on the CEN website.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.

Introduction

This document is intended to be used in conjunction with EN 13611:2019.

EN 13611:2019 recognizes the safety level specified by CEN/TC 58 and is regarded as a horizontal standard dealing with the safety, construction, performance and testing of controls for burners and appliances burning gaseous and/or liquid fuels.

The general requirements for controls are given in EN 13611:2019, and methods for classification and assessment for new controls and control functions are given in EN 14459:2021 (see Figure 1). EN 126:2012 (see Figure 1) specifies multifunctional controls combining two or more controls and Application Control Functions, one of which is a mechanical control function. The requirements for controls and Application Control Functions are given in the specific control standard (see Figure 1, control functions).




Figure 1 — Interrelation of control standards

EN 13611:2019 should be used in conjunction with the specific standard for a specific type of control (e.g. A_1 EN 88-1:2022+A1:2023 A_1 , A_1 EN 88-2:2022+A1:2024 A_1 , A_1 EN 88-3:2022+A1:2024 A_1 , A_1 EN 125:2022+A1:2024 A_1 , EN 126:2012, EN 161:2022, A_1 EN 257:2022+A1:2023 A_1 , EN 298:2022, A_1 EN 1106:2022+A1:2023 A_1 , EN 1643:2022, A_1 EN 1854:2022+A1:2023 A_1 , EN 12067-2:2022, A_1 EN 16304:2022+A1:2024 A_1 , EN 16340:2014, EN 16678:2022 and A_1 EN 16898:2022+A1:2023 A_1), or for controls for specific applications.

EN 13611:2019 can also be applied, so far as reasonable, to controls not mentioned in a specific standard and to controls designed on new principles, in which case additional requirements can be necessary. EN 14459:2021 provides methods for classification and assessment of new control principles.

Primarily in industrial applications it is common practice to rate the safety of a plant based on values describing the likelihood of a dangerous failure. These values are being used to determine Safety Integrity Levels or Performance Levels when the system is being assessed in its entirety.

CEN/TC 58 standards for safety relevant controls do go beyond this approach, because for a certain life time for which the product is specified, designed and tested a dangerous failure is not allowed at all. Failure modes are described and assessed in greater detail.

Measures to prevent from dangerous situations are defined. Field experience over many decades is reflected in the CEN/TC 58 standards. Requirements of EN 13611:2019 can be considered as proven in practice.

This document refers to clauses of EN 13611:2019 or adapts clauses by stating “with the following modification”, “with the following addition”, “is replaced by the following” or “is not applicable” in the corresponding clause.

This document adds clauses or subclauses to the structure of EN 13611:2019 which are particular to this document. Subclauses which are additional to those in EN 13611:2019 are numbered starting from 101. Additional Annexes are designated as Annex AA, BB, CC, etc. It should be noted that these clauses, subclauses and Annexes are not indicated as an addition.

If by reference to EN 13611:2019 the term “control” is given, this term should be read as “pressure regulator”.

This document is a preview generated by EVS

1 Scope

EN 13611:2019, Clause 1 applies with the following modification and addition:

Modification:

The 1st paragraph of EN 13611:2019, Clause 1 is replaced by:

This document specifies the safety, design, construction, and performance requirements and testing for pneumatic pressure regulators and safety devices for burners and appliances burning one or more gaseous fuels, hereafter referred to as “pressure regulators”.

This document is applicable to pressure regulators with declared maximum inlet pressures above 50 kPa up to and including 500 kPa and of nominal connection sizes up to and including DN 250.

Addition:

This document is applicable to:

- pressure regulators incorporating safety devices;
- pressure regulators and safety devices which use auxiliary energy;
- stand-alone pressure regulators or pressure regulators equipped with a control device for maximum or minimum gas pressure.

This document is not applicable to:

- pressure regulators connected directly to a gas distribution network or to a container that maintains a standard distribution pressure;
- pressure regulators intended for gas appliances to be installed in the open air and exposed to the environment.

The 4th paragraph of EN 13611:2019, Clause 1 is removed.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 161:2022, *Automatic shut-off valve for gas burners and gas appliances*

EN 549:2019+A2:2024 ^{A1}, *Rubber materials for seals and diaphragms for gas appliances and gas equipment*

EN 682:2002,¹ *Elastomeric seals — Materials requirements for seals used in pipes and fittings carrying gas and hydrocarbon fluids*

EN 13611:2019,² *Safety and control devices for burners and appliances burning gaseous and/or liquid fuels — General requirements*

¹ As impacted by EN 682:2002/A1:2005.

² As impacted by EN 13611:2019/AC:2021.

EN 60534-2-3:2016, *Industrial-process control valves — Part 2-3: Flow capacity — Test procedures (IEC 60534-2-3:2015)*

EN 175301-803:2006, *Detail Specification: Rectangular connectors — Flat contacts, 0,8 mm thickness, locking screw not detachable*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in EN 13611:2019 and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <https://www.electropedia.org/>
- ISO Online browsing platform: available at <https://www.iso.org/obp>

3.101

pressure regulator

device which maintains the outlet pressure constant independent of the variations in inlet pressure and/or flow rate within defined limits

[SOURCE: [A1](#) EN 88-1:2022+A1:2023 [A1](#), 3.101]

3.102

control member

movable part of the pressure regulator which varies flow rate and/or outlet pressure directly

[SOURCE: [A1](#) EN 88-1:2022+A1:2023 [A1](#), 3.107]

3.103

safety shut-off device

SSD

device having the function of staying in the open position under normal operating conditions and to shut off the gas flow automatically and completely when the monitored pressure deviates above or below the pre-set value

3.104

housing

part of the pressure regulator and/or *SSD* that is the main pressure containing envelope

3.105

controller

device which normally includes a setting element, normally a spring, to obtain a set value of the outlet pressure, and a pressure detector element, normally a diaphragm for the outlet pressure

3.106

actuator

device or mechanism which changes the signal from the controller into a corresponding movement controlling the position of the control member