

This document is a preview generated by EVS

Leak detection systems - Part 3: Requirements and test/assessment methods for liquid systems for tanks

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

<p>See Eesti standard EVS-EN 13160-3:2016+A1:2025 sisaldab Euroopa standardi EN 13160-3:2016+A1:2024 ingliskeelset teksti.</p> <p>Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.</p> <p>Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 13.11.2024.</p> <p>Standard on kättesaadav Eesti Standardimis- ja Akrediteerimiskeskusest.</p>	<p>This Estonian standard EVS-EN 13160-3:2016+A1:2025 consists of the English text of the European standard EN 13160-3:2016+A1:2024.</p> <p>This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation and Accreditation.</p> <p>Date of Availability of the European standard is 13.11.2024.</p> <p>The standard is available from the Estonian Centre for Standardisation and Accreditation.</p>
--	---

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 23.020.01, 23.040.99

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardimis- ja Akrediteerimiskeskusele. Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardimis- ja Akrediteerimiskeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardimis- ja Akrediteerimiskeskusega: Koduleht www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation and Accreditation. No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation and Accreditation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation and Accreditation: Homepage www.evs.ee; phone +372 605 5050; e-mail info@evs.ee

English Version

Leak detection systems - Part 3: Requirements and test/assessment methods for liquid systems for tanks

Systèmes de détection de fuites - Partie 3: Exigences et méthodes d'essai/d'évaluation des systèmes à liquide pour des réservoirs

Leckanzeigesysteme - Teil 3: Anforderungen und Prüf-/Bewertungsmethoden für Flüssigkeitssysteme für Tanks

This European Standard was approved by CEN on 8 April 2016 and includes Amendment 1 approved by CEN on 11 September 2024.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents	Page
European foreword.....	4
1 Scope	5
2 Normative references	6
3 Terms and definitions	7
4 Requirements	7
4.1 Effectiveness	7
4.1.1 General	7
4.1.2 Leak detection kit	7
4.1.3 Measure the level change (Sensing device)	7
4.1.4 Requirements for software (only if provided)	10
4.2 Durability of effectiveness	10
4.2.1 Durability of effectiveness against temperature	10
4.2.2 Durability of effectiveness against chemical attack	10
4.2.3 Durability of effectiveness against microbiological growth	11
5 Testing, assessment and sampling methods	11
5.1 Effectiveness of leak detection kits	11
5.1.1 General function	11
5.1.2 Leak detection kit	11
5.1.3 Measure the level change (Sensing device)	11
5.1.4 Software	16
5.2 Durability of effectiveness	17
5.2.1 Durability of effectiveness against temperature	17
5.2.2 Durability of effectiveness against chemical attack	19
5.2.3 Durability of effectiveness against microbiological growth	20
6 Assessment and verification of constancy of performance - AVCP	22
6.1 General	22
6.2 Type testing	22
6.2.1 General	22
6.2.2 Test samples, testing and compliance criteria	23
6.2.3 Test reports	23
6.2.4 Shared other party results	23
6.2.5 Cascading determination of the product type results	24
6.3 Factory production control (FPC)	25
6.3.1 General	25
6.3.2 Requirements	26
6.3.3 Product specific requirements	28
6.3.4 Procedure for modifications	28
6.3.5 One-off products, pre-production products (e.g. prototypes) and products produced in very low quantity	29
7 Marking, labelling and packaging	30
8 Environmental aspects	30
Annex A (informative) Environmental aspects	31
Annex B (normative) Test of the compatibility of leak detection liquids with metals	33

B.1	Test equipment.....	33
B.2	Test specimen	33
B.3	Preparation of the test liquid.....	34
B.4	Procedure.....	34
B.5	Test results.....	35
	Bibliography	38

This document is a preview generated by EVS

European foreword

This document (EN 13160-3:2016+A1:2024) has been prepared by Technical Committee CEN/TC 393 “Equipment for storage tanks and for filling stations”, the secretariat of which is held by DIN.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by May 2025, and conflicting national standards shall be withdrawn at the latest by August 2026.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document includes Amendment 1 approved by CEN on 11 September 2024.

This document supersedes A1 EN 13160-3:2016 A1.

The start and finish of text introduced or altered by amendment is indicated in the text by tags A1 A1.

A1 *deleted text* A1

According to edition 2003 the following fundamental changes are given:

- requirements and test methods for the leak detection liquids revised;
- consideration of the Construction Product Regulation 305/2011/EU;
- new structure — technical requirements for the system provided consisting of sensing device, evaluation device, alarm device;);
- including of environmental aspects;
- requirements from EN 13160-1:2003 included, which are no longer contained in EN 13160-1:2016;
- requirements for software included;
- reference to REACH — Regulation (EC) No 1907/2006 of the European Parliament and of the Council of 18 December 2006 concerning the Registration, Evaluation, Authorization and Restriction of Chemicals (REACH), establishing a European Chemicals Agency and GHS — Globally Harmonized System of Classification and Labelling of Chemicals (GHS)
- using of temperature types;
- crevice test pieces and test method changed.

This European Standard *Leak detection systems* consists of 7 parts:

- *Part 1: General principles*
- *Part 2: Requirements and test/assessment methods for pressure and vacuum systems*
- *Part 3: Requirements and test/assessment methods for liquid systems for tanks*
- *Part 4: Requirements and test/assessment methods for sensor based leak detection systems*

- *Part 5: Requirements and test/assessment methods for in-tank gauge systems and pressurized pipework systems*
- *Part 6: Sensors in monitoring wells*
- *Part 7: Requirements and test/assessment methods for interstitial spaces, leak detection linings and leak detection jackets*

Any feedback and questions on this document should be directed to the users' national standards body. A complete listing of these bodies can be found on the CEN website.

According to the CEN-CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.

1 Scope

This European Standard gives requirements and the corresponding test/assessment methods applicable to leak detection kits based on the drop of the liquid level in the leak detection liquid reservoir. Leak detection kits are intended to be used with double skin, underground or above ground, non-pressurized, tanks designed for water polluting liquids.

The liquid leak detection kits are usually composed of:

- sensing device (liquid sensor);
- evaluation device;
- alarm device.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 981:1996+A1:2008, *Safety of machinery — System of auditory and visual danger and information signals*

EN 1412, *Copper and copper alloys — European numbering system*

EN 1652, *Copper and copper alloys — Plate, sheet, strip and circles for general purposes*

EN 10027-1, *Designation systems for steels — Part 1: Steel names*

EN 12285-1, *Workshop fabricated steel tanks — Part 1: Horizontal cylindrical single skin and double skin tanks for the underground storage of flammable and non-flammable water polluting liquids*

EN 12285-2, *Workshop fabricated steel tanks — Part 2: Horizontal cylindrical single skin and double skin tanks for the aboveground storage of flammable and non-flammable water polluting liquids*

EN 13160-1:2016, *Leak detection systems — Part 1: General Principles*

EN 13160-7, *Leak detection systems — Part 7: Requirements and test/assessment methods for interstitial spaces, leak detection linings and leak detection jackets*

EN 13341:2005+A1:2011, *Static thermoplastic tanks for above ground storage of domestic heating oils, kerosene and diesel fuels — Blow moulded and rotationally moulded polyethylene tanks and rotationally moulded tanks made of anionically polymerized polyamide 6 — Requirements and test methods*

EN 27888, *Water quality — Determination of electrical conductivity (ISO 7888)*

EN 60079-0:2012, *Explosive atmospheres — Part 0: Equipment — General requirements (IEC 60079-0:2011, modified + Cor.:2012)*

EN 61672-1, *Electroacoustics — Sound level meters — Part 1: Specifications (IEC 61672-1)*

EN ISO 175:2010, *Plastics — Methods of test for the determination of the effects of immersion in liquid chemicals (ISO 175:2010)*

EN ISO 2719, *Determination of flash point — Pensky-Martens closed cup method (ISO 2719)*

EN ISO 3104, *Petroleum products — Transparent and opaque liquids — Determination of kinematic viscosity and calculation of dynamic viscosity (ISO 3104)*

EN ISO 12185, *Crude petroleum and petroleum products — Determination of density — Oscillating U-tube method (ISO 12185)*

ISO 431, *Copper refinery shapes*

ISO 7619-1, *Rubber, vulcanized or thermoplastic — Determination of indentation hardness — Part 1: Durometer method (Shore hardness)*

ASTM D 1177, *Standard Test Method for Freezing Point of Aqueous Engine Coolants*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in EN 13160-1:2016 apply.

4 Requirements

4.1 Effectiveness

4.1.1 General

This type of leak detection kit is classified according to EN 13160-1:2016 as class II.

The general requirements on leak detection systems according to Clause 5 of EN 13160-1:2016 shall be met.

The interstitial space shall fulfil the requirements according to EN 13160-7, EN 12285-1 or EN 12285-2.

NOTE To ensure the effectiveness of the system a liquid leak detection kit can only serve one tank.

A complete documentation shall be provided by the manufacturer. The documentation shall contain the technical values according to 4.1.3 to 4.1.4 and 4.2 as well as a statement about the reaction of the leak detection kit by over and under power supply voltage and current.

4.1.2 Leak detection kit

The leak detection kit shall consist of:

- sensing device (liquid sensor);
- evaluation device;
- alarm device.

4.1.3 Measure the level change (Sensing device)

4.1.3.1 Leak detection liquid reservoir

The leak detection liquid reservoir shall have a useable volume of:

- at least 1 l/100 l of leak detection liquid in the interstitial space of tanks with at least 0,3 m earth cover;
- at least 1 l/35 l of leak detection liquid in the interstitial space for all other tanks.