

Insulators for overhead lines - Composite suspension and tension insulators with AC voltage greater than 1 000 V and DC voltage greater than 1 500 V -
Definitions, test methods and acceptance criteria

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

<p>See Eesti standard EVS-EN IEC 61109:2025 sisaldab Euroopa standardi EN IEC 61109:2025 ingliskeelset teksti.</p> <p>Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.</p> <p>Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 18.04.2025.</p> <p>Standard on kättesaadav Eesti Standardimis- ja Akrediteerimiskeskusest.</p>	<p>This Estonian standard EVS-EN IEC 61109:2025 consists of the English text of the European standard EN IEC 61109:2025.</p> <p>This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation and Accreditation.</p> <p>Date of Availability of the European standard is 18.04.2025.</p> <p>The standard is available from the Estonian Centre for Standardisation and Accreditation.</p>
--	---

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 29.080.10

<p>Standardite ja standardilaadsete dokumentide reprodutseerimise ja levitamise õigus kuulub Eesti Standardimis- ja Akrediteerimiskeskusele</p> <p>Eesti standardid ja standardilaadsed dokumendid on Eesti Standardimis- ja Akrediteerimiskeskuse intellektuaalomand ning neid kasutatakse litsentsi alusel dokumentide kasutuslepingu tingimuste kohaselt.</p> <p>Ilma Eesti Standardimis- ja Akrediteerimiskeskuse eelneva kirjaliku loata on keelatud standardite ja standardilaadsete dokumentide täielik või osaline reprodutseerimine, levitamine, muutmine või kasutamine mis tahes kujul ja viisil - sealhulgas kopeerimine, skaneerimine, salvestamine või jagamine teel digiplatvormidel (k.a masinõppe ja tehisintellekti rakendustes). Loata kasutamine väljaspool litsentsi tingimusi käsitletakse õigusrikkumisena.</p> <p>Kui Teil on küsimusi standardite ja standardilaadsete dokumentide autoriõiguse kaitse kohta, võtke palun ühendust Eesti Standardimis- ja Akrediteerimiskeskusega: Veebileht www.evs.ee; telefon +372 6055050; e-post info@evs.ee</p> <p>The right to reproduce and distribute standards and standard-like documents belongs to the Estonian Centre for Standardisation and Accreditation</p> <p>Estonian standards and standard-like documents are the intellectual property of the Estonian Centre for Standardisation and Accreditation and are made available under license in accordance with the terms and conditions of the document use agreement.</p> <p>Without the prior written permission of the Estonian Centre for Standardisation and Accreditation, the full or partial reproduction, distribution, modification, or use of standards and standard-like documents in any form or by any means - including photocopying, scanning, storing, or sharing via digital platforms (incl. in machine learning and artificial intelligence applications) - is strictly prohibited. Any unauthorized use beyond the scope of the granted license is prohibited and may result in legal action.</p> <p>If you have any questions about copyright, please contact Estonian Centre for Standardisation and Accreditation: Homepage www.evs.ee; phone +372 605 5050; e-mail info@evs.ee</p>
--

English Version

**Insulators for overhead lines - Composite suspension and
tension insulators with AC voltage greater than 1 000 V and DC
voltage greater than 1 500 V - Definitions, test methods and
acceptance criteria
(IEC 61109:2025)**

Isolateurs pour lignes aériennes - Isolateurs composites de
suspension et d'ancrage de tension supérieure à 1 000 V
en courant alternatif et à 1 500 V en courant continu -
Définitions, méthodes d'essai et critères d'acceptation
(IEC 61109:2025)

Isolatoren für Freileitungen - Verbund-Hänge- und -
Abspannisolatoren mit einer Wechselspannung über 1 000
V und einer Gleichspannung über 1500 V - Begriffe,
Prüfverfahren und Annahmekriterien
(IEC 61109:2025)

This European Standard was approved by CENELEC on 2025-04-02. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

European foreword

The text of document 36/609/FDIS, future edition 3 of IEC 61109, prepared by TC 36 "Insulators" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 61109:2025.

The following dates are fixed:

- latest date by which the document has to be implemented at national (dop) 2026-04-30 level by publication of an identical national standard or by endorsement
- latest date by which the national standards conflicting with the (dow) 2028-04-30 document have to be withdrawn

This document supersedes EN 61109:2008 and all of its amendments and corrigenda (if any).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Any feedback and questions on this document should be directed to the users' national committee. A complete listing of these bodies can be found on the CENELEC website.

Endorsement notice

The text of the International Standard IEC 61109:2025 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standard indicated:

- | | | |
|-------------|------|--------------------------|
| IEC 60721-1 | NOTE | Approved as EN 60721-1 |
| IEC 60721-1 | NOTE | Approved as EN 60721-1 |
| IEC 60587 | NOTE | Approved as EN IEC 60587 |

INTERNATIONAL STANDARD

NORME INTERNATIONALE

Insulators for overhead lines – Composite suspension and tension insulators with AC voltage greater than 1 000 V and DC voltage greater than 1 500 V – Definitions, test methods and acceptance criteria

Isolateurs pour lignes aériennes – Isolateurs composites de suspension et d'ancrage de tension supérieure à 1 000 V en courant alternatif et à 1 500 V en courant continu – Définitions, méthodes d'essai et critères d'acceptation



THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2025 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Secretariat
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews, graphical symbols and the glossary. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 500 terminological entries in English and French, with equivalent terms in 25 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Recherche de publications IEC -

webstore.iec.ch/advsearchform

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études, ...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et une fois par mois par email.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Découvrez notre puissant moteur de recherche et consultez gratuitement tous les aperçus des publications, symboles graphiques et le glossaire. Avec un abonnement, vous aurez toujours accès à un contenu à jour adapté à vos besoins.

Electropedia - www.electropedia.org

Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22 500 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 25 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

INTERNATIONAL STANDARD

NORME INTERNATIONALE

Insulators for overhead lines – Composite suspension and tension insulators with AC voltage greater than 1 000 V and DC voltage greater than 1 500 V – Definitions, test methods and acceptance criteria

Isolateurs pour lignes aériennes – Isolateurs composites de suspension et d'ancrage de tension supérieure à 1 000 V en courant alternatif et à 1 500 V en courant continu – Définitions, méthodes d'essai et critères d'acceptation

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 29.080.10

ISBN 978-2-8327-0210-9

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	5
INTRODUCTION.....	7
1 Scope.....	8
2 Normative references	8
3 Terms, definitions and abbreviated terms	9
3.1 Terms and definitions.....	9
3.2 Abbreviated terms.....	12
4 Identification.....	12
5 Environmental conditions.....	12
6 Transport, storage and installation.....	13
7 Tolerances	13
8 Classification of tests.....	14
8.1 Design tests.....	14
8.2 Type tests	15
8.3 Sample tests.....	15
8.4 Routine tests.....	15
9 Design tests	18
9.1 General.....	18
9.2 Test specimens.....	18
9.2.1 Tests on interfaces and connections of end fittings.....	18
9.2.2 Tracking and erosion test	19
9.2.3 Tests on core material	19
9.2.4 Tests on core with housing	19
9.3 Product specific pre-stressing for tests on interfaces and connections of end fittings.....	19
9.3.1 General	19
9.3.2 Sudden load release.....	19
9.3.3 Thermal-mechanical pre-stress.....	19
9.4 Assembled core load-time tests	20
9.4.1 Test specimens	20
9.4.2 Mechanical load test.....	21
10 Type tests	21
10.1 General.....	21
10.2 Electrical tests on string insulator units	21
10.2.1 General	21
10.2.2 Test specimens	22
10.2.3 Mounting arrangements for electrical tests.....	22
10.2.4 Dry lightning impulse withstand voltage test.....	22
10.2.5 Wet power-frequency voltage tests	22
10.2.6 Wet switching impulse withstand voltage test.....	22
10.2.7 Corona and radio interference voltage (RIV) tests.....	22
10.2.8 Power arc test	23
10.3 Damage limit proof test and test of the tightness of the interface between end fittings and insulator housing.....	23
10.3.1 Test specimens	23
10.3.2 Performance of the test	23

10.3.3	Evaluation of the test	24
11	Sample tests	25
11.1	General rules	25
11.2	Verification of dimensions (E1 + E2)	25
11.3	Verification of the end fittings (E2)	26
11.4	Verification of tightness of the interface between end fittings and insulator housing (E2) and of the specified mechanical load, SML (E1)	26
11.5	Galvanizing test (E2)	26
11.6	Minimum sheath thickness (E1)	27
11.7	Re-testing procedure	27
12	Routine tests	28
12.1	Mechanical routine test	28
12.2	Visual examination	29
Annex A (informative) Principles of the damage limit, load coordination and testing for composite suspension and tension insulators		30
A.1	Introductory remark	30
A.2	Load-time behaviour and the damage limit	30
A.3	Service load coordination	31
A.4	Verification tests	33
Annex B (informative) Example of two possible devices for sudden release of load		35
B.1	Device 1 (Figure B.1)	35
B.2	Device 2 (Figure B.2)	35
Annex C (informative) Guidance on non-standard mechanical stresses and dynamic mechanical loading of composite insulators		37
C.1	Introductory remark	37
C.2	Torsion loads	37
C.3	Compressive (buckling) loads	37
C.4	Bending loads	38
C.5	Dynamic mechanical loads	38
C.6	Limits	39
Annex D (informative) Electric field control for AC		40
Annex E (informative) Typical sketches for composite insulator assemblies		42
Annex F (informative) Mechanical evaluation of the adhesion between core and housing		43
F.1	General	43
F.2	Method A: Pull-off test	44
F.2.1	General	44
F.2.2	Specimens	44
F.2.3	Procedure	44
F.3	Method B: Peel test	46
F.3.1	General	46
F.3.2	Specimens	46
F.3.3	Procedure	47
F.4	Method C: Shear test	48
F.4.1	General	48
F.4.2	Specimens	48
F.4.3	Procedure	48
Annex G (informative) Applicability of design and type tests for DC applications		49
Bibliography		51

Figure 1 – Thermal-mechanical pre-stressing.....	20
Figure 2 – Examples for 1 min SML withstand test.....	24
Figure 3 – Location for minimum sheath thickness measurement.....	27
Figure 4 – Method of re-testing at different stages.....	28
Figure A.1 – Load-time strength and damage limit of a core assembled with fittings.....	31
Figure A.2 – Graphical representation of the relationship of the damage limit to the mechanical characteristics and service loads of an insulator with a 16 mm diameter core and an SML rating of 133 kN.....	32
Figure A.3 – Applied specific force relationship, example 1.....	32
Figure A.4 – Applied specific force relationship, example 2.....	33
Figure A.5 – Test loads.....	34
Figure B.1 – Example of possible device 1 for sudden release of load.....	35
Figure B.2 – Example of possible device 2 for sudden release of load.....	36
Figure C.1 – Example of compression loads in V-string assemblies.....	38
Figure C.2 – Buckling of composite insulator in a phase-to-phase configuration.....	38
Figure D.1 – Example for electrical field vectors on a composite insulator.....	41
Figure E.1 – Interface description for insulator with housing made by modular assembly and external sealant.....	42
Figure E.2 – Interface description for insulator with housing made by injection molding and overmolded end fitting.....	42
Figure F.1 – Example for type of housing separation.....	43
Figure F.2 – Example of specimen mounted in a tensile test machine.....	45
Figure F.3 – Example of test object for pull-off test and application clamping and force.....	45
Figure F.4 – Relevant dimensions for the calculation of the area of the pull-off section.....	46
Figure F.5 – Example of test specimen for peel test.....	47
Figure F.6 – Method of peel test and tested specimens after peel test.....	47
Figure F.7 – Method of shear test and tested samples after shear test with cohesive bonding, sample passed the test.....	48
Table 1 – Normal environmental conditions.....	13
Table 2 – Tests to be carried out after design changes.....	16
Table 3 – Design tests.....	18
Table 4 – Application and mounting arrangements for electrical tests.....	23
Table 5 – Sample sizes.....	25
Table G.1 – Design and type tests for DC applications.....	49

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**INSULATORS FOR OVERHEAD LINES
COMPOSITE SUSPENSION AND TENSION INSULATORS
WITH AC VOLTAGE GREATER THAN
1 000 V AND DC VOLTAGE GREATER THAN 1 500 V –
DEFINITIONS, TEST METHODS AND ACCEPTANCE CRITERIA**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 61109 has been prepared by subcommittee 36B: Insulators for overhead lines, of IEC technical committee 36: Insulators. It is an International Standard.

This third edition cancels and replaces the second edition published in 2008. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) extension of this document to apply both to AC and DC systems;
- b) modifications of Clause 3, Terms, definitions and abbreviations;
- c) removal of Clause 7, Hybrid insulators, from this document;

- d) modifications of tests procedures recently included in IEC 62217 (hydrophobicity transfer test, stress corrosion, water diffusion test on the core with housing);
- e) modifications on environmental conditions;
- f) modifications on classification of tests and include the relevance of the interfaces;
- g) clarification and modification of the parameters determining the need to repeat design and type tests;
- h) revision of Table 1;
- i) revision of electrical type tests;
- j) revision of re-testing procedure of sample test;
- k) addition of a new Annex D on electric field control for AC;
- l) addition of a new Annex E on typical sketch for composite insulators assembly;
- m) addition of a new Annex F on mechanical evaluation of the adhesion between core and housing;
- n) addition of a new Annex G on applicability of design- and type tests for DC applications.

The text of this International Standard is based on the following documents:

Draft	Report on voting
36/609/FDIS	36/611/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

This International Standard is to be used in conjunction with IEC 62217:2012.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

INTRODUCTION

Composite suspension and tension insulators (in the following the term "composite insulator" is used) consist of fibreglass insulating core, bearing the mechanical load protected by a polymeric housing, the load being transmitted to the core by metallic end fittings. Despite these common features, the materials used and the design details and manufacturing process used by different manufacturers may differ.

Some tests have been grouped together as "Design tests", to be performed only once on insulators which satisfy the same design conditions. For all design tests of these composite insulators, the appropriate common clauses defined in IEC 62217 are applied. As far as practical, the influence of time on the electrical and mechanical properties of its components (core, housing, interfaces etc.) and of the complete composite insulators has been considered in specifying the design tests to ensure a satisfactory lifetime under normally known stress conditions of transmission lines. Explanation of the principles of the damage limit, load coordination and testing are presented in Annex A.

It has not been considered useful to specify a power arc test as a mandatory test. The test parameters are manifold and can have very different values depending on the configurations of the network and the supports and on the design of arc-protection devices. The heating effect of power arcs need to be considered in the design of metal fittings. Critical damage to the metal fittings resulting from the magnitude and duration of the short-circuit current can be avoided by properly designed arc-protection devices. This document, however, does not exclude the possibility of a power arc test by agreement between the manufacturer and customer. IEC 61467 gives details on AC power arc testing of complete insulator sets, that match their configuration with actual protective and string fittings, to recreate the real electromagnetic field affecting the arc movement.

This document covers both AC and DC composite insulators. Before the appropriate standard for DC applications is issued, the majority of tests listed in this document can also be applicable for DC (Annex G). Due to the difference in AC and DC tracking performance, a specific tracking and erosion test procedure for DC applications as a design test is planned to be developed. The 1 000 h AC tracking and erosion test of IEC 62217 can be used only to establish a minimum requirement for the tracking and erosion resistance. This 1 000 h salt fog tracking and erosion test is considered as a screening test intended to reject materials in combination with the design which are inadequate. Tracking and erosion tests are not intended to evaluate long term performance of insulators. Such tests, e.g. the 5 000 h multiple stress test and wheel test in IEC TR 62730 [1]¹, or other tests intended for research or sometimes used as a supplementary design test, are not considered in this document.

Composite suspension and tension insulators are, in general, not intended for torsion or other non-tensile loads. However, due to consideration to non-standard applications (interphase spacers etc.) loads during handling and installation have to be considered in the design. Guidance on non-standard loads is given in Annex C.

Wherever possible, IEC Guide 111 [2] has been followed for the drafting of this document.

¹ Numbers in square brackets refer to the bibliography.

**INSULATORS FOR OVERHEAD LINES
COMPOSITE SUSPENSION AND TENSION INSULATORS
WITH AC VOLTAGE GREATER THAN
1 000 V AND DC VOLTAGE GREATER THAN 1 500 V –
DEFINITIONS, TEST METHODS AND ACCEPTANCE CRITERIA**

1 Scope

This International Standard applies to composite insulators for overhead lines consisting of a load-bearing cylindrical insulating solid core consisting of fibres – usually glass – in a resin-based matrix, a housing (surrounding the insulating core) made of polymeric material and metal end fittings permanently attached to the insulating core.

Composite insulators covered by this document are intended for use as suspension/tension line insulators, but these insulators could occasionally be subjected to compression or bending, for example when used as interphase-spacers. Guidance on such loads is outlined in Annex C.

The object of this document is to

- define the terms used,
- specify test methods,
- specify acceptance criteria.

This document does not include requirements dealing with the choice of insulators for specific operating conditions or environments beyond normal environmental conditions defined in Table 1.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60060-1, *High-voltage test techniques – Part 1: General definitions and test requirements*

IEC 60383-1, *Insulators for overhead lines with a nominal voltage above 1000 V – Part 1: Ceramic or glass insulator units for AC systems – Definitions, test methods and acceptance criteria*

IEC 60383-2, *Insulators for overhead lines with a nominal voltage above 1 000 V – Part 2: Insulator strings and insulator sets for AC systems – Definitions, test methods and acceptance criteria*

IEC 60437, *Radio interference test on high-voltage insulators*

IEC 61284, *Overhead lines – Requirements and tests for fittings*

IEC 61466-1, *Composite string insulator units for overhead lines with a nominal voltage greater than 1 000 V – Part 1: Standard strength classes and end fittings*

IEC 61467, *Insulators for overhead lines – Insulator strings and sets for lines with a nominal voltage greater than 1 000 V – AC power arc tests*

IEC 62217:², *Polymeric HV insulators for indoor and outdoor use – General definitions, test methods and acceptance criteria*

IEC 62231, *Composite station post insulators for substations with AC voltages greater than 1 000 V up to 245 kV – Definitions, test methods and acceptance criteria*

ISO 3452 (all parts), *Non-destructive testing – Penetrant testing*

3 Terms, definitions and abbreviated terms

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- IEC Electropedia: available at <https://www.electropedia.org/>
- ISO Online browsing platform: available at <https://www.iso.org/obp>

Note 1 to entry: Certain terms from IEC 62217:2012 are reproduced here for ease of reference. Additional definitions applicable to insulators can be found in IEC 60050-471 [3].

3.1 Terms and definitions

3.1.1

polymeric insulator

insulator whose insulating body consists of at least one organic based material

Note 1 to entry: Polymeric insulators are also known as non-ceramic insulators.

Note 2 to entry: Coupling devices may be attached to the ends of the insulating body.

[SOURCE: IEC 60050-471:2007, 471-01-13]

3.1.2

composite insulator

insulator made of at least two insulating parts, namely a core and a housing equipped with end fittings

Note 1 to entry: Composite insulators can consist either of individual sheds mounted on the core, with or without an intermediate sheath, or alternatively, of a housing directly moulded or cast in one or several pieces on to the core.

[SOURCE: IEC 60050-471:2007, 471-01-02]

3.1.3

core (of an insulator)

central insulating part of an insulator which provides the mechanical characteristics

Note 1 to entry: The housing and sheds are not part of the core.

[SOURCE: IEC 60050-471:2007, 471-01-03]

² Under preparation. Stage at the time of publication: IEC/RFDIS 62217:2025.