

MADALPINGELISED SULAVKAITSMED. OSA 3:
LISANÕUDED TAVAIKUTE POOLT (PEAMISELT
MAJAPIDAMISES JA MUUDEL TAOLISTEL
RAKENDUSTEL) KASUTAMISEKS ETTENÄHTUD
SULAVKAITSMETELE. SULAVKAITSMETE
STANDARDSÜSTEEMIDE A KUNI F NÄITED

Low-voltage fuses - Part 3: Supplementary
requirements for fuses for operation by unskilled
persons (fuses mainly for household and similar
applications) - Examples of standardized systems of
fuses A to F

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

<p>See Eesti standard EVS-EN IEC 60269-3:2025 sisaldab Euroopa standardi EN IEC 60269-3:2025 ingliskeelset teksti.</p> <p>Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.</p> <p>Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 27.06.2025.</p> <p>Standard on kättesaadav Eesti Standardimis- ja Akrediteerimiskeskusest.</p>	<p>This Estonian standard EVS-EN IEC 60269-3:2025 consists of the English text of the European standard EN IEC 60269-3:2025.</p> <p>This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation and Accreditation.</p> <p>Date of Availability of the European standard is 27.06.2025.</p> <p>The standard is available from the Estonian Centre for Standardisation and Accreditation.</p>
--	---

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 29.120.50

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardimis- ja Akrediteerimiskeskusele. Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardimis- ja Akrediteerimiskeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardimis- ja Akrediteerimiskeskusega: Koduleht www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation and Accreditation. No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation and Accreditation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation and Accreditation: Homepage www.evs.ee; phone +372 605 5050; e-mail info@evs.ee

English Version

Low-voltage fuses - Part 3: Supplementary requirements for fuses for operation by unskilled persons (fuses mainly for household and similar applications) - Examples of standardized systems of fuses A to F
(IEC 60269-3:2024)

Fusibles basse tension - Partie 3: Exigences supplémentaires pour les fusibles destinés à être utilisés par des personnes non qualifiées (fusibles pour usages essentiellement domestiques et analogues) - Exemples de systèmes de fusibles normalisés A à F
(IEC 60269-3:2024)

Niederspannungssicherungen - Teil 3: Ergänzende Anforderungen an Sicherungen zur Betätigung durch Laien (Sicherungen vorwiegend für den Hausgebrauch und ähnliche Anwendungen) - Beispiele für genormte Sicherungssysteme A bis F
(IEC 60269-3:2024)

This European Standard was approved by CENELEC on 2024-10-16. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

European foreword

The text of document 32B/745/FDIS, future edition 5 of IEC 60269-3, prepared by SC 32B "Low-voltage fuses" of IEC/TC 32 "Fuses" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 60269-3:2025.

The following dates are fixed:

- latest date by which the document has to be implemented at national (dop) 2026-06-30 level by publication of an identical national standard or by endorsement
- latest date by which the national standards conflicting with the (dow) 2028-06-30 document have to be withdrawn

This document supersedes HD 60269-3:2010 and all of its amendments and corrigenda (if any).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

This document is read in conjunction with EN IEC 60269-1:2025.

This document has been prepared under a standardization request addressed to CENELEC by the European Commission. The Standing Committee of the EFTA States subsequently approves these requests for its Member States.

Any feedback and questions on this document should be directed to the users' national committee. A complete listing of these bodies can be found on the CENELEC website.

Endorsement notice

The text of the International Standard IEC 60269-3:2024 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standard indicated:

IEC 60529	NOTE	Approved as EN 60529
IEC 60269-6	NOTE	Approved as EN 60269-6
ISO 228-1	NOTE	Approved as EN ISO 228-1
ISO 228-2	NOTE	Approved as EN ISO 228-2

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Low-voltage fuses –
Part 3: Supplementary requirements for fuses for operation by unskilled persons
(fuses mainly for household or similar applications) – Examples of standardized
systems of fuses A to F**

**Fusibles basse tension –
Partie 3: Exigences supplémentaires pour les fusibles destinés à être utilisés
par des personnes non qualifiées (fusibles pour usages essentiellement
domestiques et analogues) – Exemples de systèmes de fusibles normalisés A à
F**



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2024 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Secretariat
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews, graphical symbols and the glossary. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 500 terminological entries in English and French, with equivalent terms in 25 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Recherche de publications IEC -

webstore.iec.ch/advsearchform

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études, ...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et une fois par mois par email.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Découvrez notre puissant moteur de recherche et consultez gratuitement tous les aperçus des publications, symboles graphiques et le glossaire. Avec un abonnement, vous aurez toujours accès à un contenu à jour adapté à vos besoins.

Electropedia - www.electropedia.org

Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22 500 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 25 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Low-voltage fuses –
Part 3: Supplementary requirements for fuses for operation by unskilled persons
(fuses mainly for household or similar applications) – Examples of standardized
systems of fuses A to F**

**Fusibles basse tension –
Partie 3: Exigences supplémentaires pour les fusibles destinés à être utilisés par
des personnes non qualifiées (fusibles pour usages essentiellement
domestiques et analogues) – Exemples de systèmes de fusibles normalisés A à
F**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 29.120.50

ISBN 978-2-8322-9107-8

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	10
INTRODUCTION.....	13
1 General Scope.....	14
2 Normative references	14
3 Terms and definitions	15
Fuse system A: D type fuse system	16
1 General	16
1.1 Scope	16
2 Terms and definitions	16
3 Conditions for operation in service.....	16
4 Classification	16
5 Characteristics of fuses	16
5.2 Rated voltage	16
5.3.1 Rated current of the fuse-link.....	17
5.3.2 Rated current of the fuse-holder	17
5.3.3 Rated current of the gauge-piece.....	17
5.5 Rated power dissipation of a fuse-link and rated acceptable power dissipation of a fuse-holder	17
5.6 Limits of time-current characteristics.....	17
5.6.1 Time-current characteristics, time-current zones and overload curves	17
5.6.2 Conventional times and currents.....	18
5.6.3 Gates	18
5.7 Breaking range and breaking capacity	18
5.7.2 Rated breaking capacity	18
6 Markings.....	18
6.1 General.....	18
6.2 Marking of fuse-bases.....	19
6.3 Marking of the gauge-pieces	19
7 Standard conditions for construction.....	19
7.1 Mechanical design	19
7.1.2 Connections including terminals	19
7.1.3 Fuse-contacts.....	20
7.1.4 Construction of a gauge-piece	20
7.1.6 Construction of a fuse-carrier	20
7.1.7 Construction of a fuse-link	21
7.1.8 Non-interchangeability	21
7.1.9 Construction of a fuse-base	21
7.2 Insulating properties and suitability for isolation.....	22
7.3 Temperature rise, power dissipation of the fuse-link and acceptable power dissipation of the fuse-holder	22
7.7 I^2t characteristics	23
7.7.1 Pre-arcing I^2t values	23
7.7.2 Operating I^2t values	23
7.8 Overcurrent discrimination of "gG" fuse-links	23
7.9 Protection against electric shock.....	24

8	Tests	24
8.1.4	Arrangement of the fuse and dimensions	24
8.2	Verification of the insulating properties and of the suitability for isolation	25
8.2.1	Arrangement of the fuse-holder	25
8.2.6	Creepage distances, clearances and distances through sealing compound.....	26
8.3	Verification of temperature rise and power dissipation	26
8.3.1	Arrangement of the fuse	26
8.3.3	Measurement of the power dissipation of the fuse-link	26
8.3.5	Acceptability of test results	26
8.5.1	Arrangement of the fuse	27
8.5.2	Characteristics of the test circuit.....	27
8.5.5	Test method	28
8.5.8	Acceptability of test results	28
8.7.4	Verification of overcurrent discrimination	28
8.9	Verification of resistance to heat.....	29
8.9.1	Fuse-base	29
8.9.2	Fuse-carrier.....	30
8.10	Verification of non-deterioration of contacts	30
8.10.1	Arrangement of the fuse	30
8.10.2	Test method	30
8.10.3	Acceptability of test results	31
8.11	Mechanical and miscellaneous tests	32
8.11.1	Mechanical strength.....	32
Annex AA	(informative) Special test for cable overload protection (for fuse system A)	67
AA.1	Arrangement of the fuse.....	67
AA.2	Test method and acceptability of test results.....	67
	Fuse system B – Cylindrical fuses (NF cylindrical fuse system)	68
1	General	68
1.1	Scope	68
2	Terms and definitions	68
3	Conditions for operation in service.....	68
4	Classification	69
5	Characteristics of fuses	69
5.2	Rated voltage	69
5.3.1	Rated current of the fuse-link.....	69
5.3.2	Rated current of the fuse-holder	69
5.5	Rated power dissipation of a fuse-link and rated acceptable power dissipation of a fuse-holder	69
5.6.2	Conventional times and currents.....	69
5.6.3	Gates	70
5.7.2	Rated breaking capacity	70
6	Markings.....	70
7	Standard conditions for construction.....	70
7.1	Mechanical design	71
7.1.2	Connections including terminals	71
7.1.6	Construction of a fuse-carrier	71
7.1.7	Construction of a fuse-link	71

7.1.8	Non-interchangeability	72
7.1.9	Construction of a fuse-base	72
7.2	Insulating properties and suitability for isolation	72
7.3	Temperature rise, power dissipation of the fuse-link and acceptable power dissipation of the fuse-holder	73
7.7	I^2t characteristics	73
7.7.1	Pre-arcing I^2t values	73
7.7.2	Operating I^2t values	74
7.8	Overcurrent discrimination of "gG" fuse-links	74
7.9	Protection against electric shock	74
8	Tests	74
8.1.6	Testing of fuse-holders	74
8.3.1	Arrangement of the fuse	75
8.3.3	Measurement of the power dissipation of the fuse-link	75
8.4	Verification of operation	76
8.4.1	Arrangement of the fuse	76
8.5	Verification of the breaking capacity	76
8.5.1	Arrangement of the fuse	76
8.5.5	Test method	77
8.5.8	Acceptability of test results	77
8.7.4	Verification of overcurrent discrimination	77
8.8	Verification of the degree of protection of enclosures	77
8.8.1	Verification of protection against electric shock	77
8.9	Verification of resistance to heat	78
8.10	Verification of non-deterioration of contacts	78
8.10.1	Arrangement of the fuse	78
8.10.2	Test method	78
8.10.3	Acceptability of test results	79
8.12	Verification of the reliability of terminals	82
	Fuse system C – Cylindrical fuses (BS cylindrical fuse system)	90
1	General	90
1.1	Scope	90
2	Terms and definitions	90
3	Conditions for operation in service	90
4	Classification	90
5	Characteristics of fuses	91
5.2	Rated Voltage	91
5.3	Rated current	91
5.3.1	Rated current of the fuse-link	91
5.3.2	Rated current of the fuse-holder	91
5.5	Rated power dissipation of a fuse-link and rated acceptable power dissipation of a fuse-holder	91
5.6	Limits of time-current characteristics	91
5.6.1	Time-current characteristics, time-current curves and overload curves	91
5.6.2	Conventional times and currents	91
5.7	Breaking range and breaking capacity	92
5.7.2	Rated breaking capacity	92
6	Markings	92

7	Standard conditions for construction	92
7.1	Mechanical design	92
7.1.2	Connections including terminals	92
7.1.6	Construction of a fuse-carrier	92
7.1.7	Construction of a fuse-link	92
7.1.8	Non-interchangeability	92
7.1.9	Construction of a fuse-base	92
7.2	Insulating properties and suitability for isolation	93
7.3	Temperature rise, power dissipation of the fuse-link and acceptable power dissipation of the fuse-holder	93
7.7	I^2t characteristics	93
7.9	Protection against electric shock	93
8	Tests	93
8.1	General	93
8.1.4	Arrangement of the fuse	93
8.3	Verification of temperature rise and power dissipation	93
8.3.1	Arrangement of the fuse	93
8.3.3	Measurement of the power dissipation of the fuse-link	93
8.4	Verification of operation	94
8.4.1	Arrangement of fuse	94
8.5	Verification of breaking capacity	94
8.5.1	Arrangement of the fuse	94
8.5.2	Characteristics of the test circuit	94
8.5.5	Test method	94
8.5.8	Acceptability of test results	94
8.10	Verification of non-deterioration of contacts	94
8.10.1	Arrangement of the fuse	94
8.10.2	Test method	94
8.10.3	Acceptability of test results	95
	Fuse system F – Cylindrical fuse-links for use in plugs (BS plugtop system)	103
1	General	103
1.1	Scope	103
2	Terms and definitions	103
3	Conditions for operation in service	103
4	Classification	103
5	Characteristics of fuses	103
5.2	Rated voltage	103
5.3.1	Rated current of the fuse-link	103
5.3.2	Rated current of the fuse-holder	104
5.5	Rated power dissipation of a fuse-link and rated acceptable power dissipation of a fuse-holder	104
5.6.1	Time-current characteristics, time-current zones and overload curves	104
5.6.2	Conventional times and currents	104
5.6.3	Gates	104
5.7.2	Rated breaking capacity	104
6	Markings	104
7	Standard conditions for construction	105
7.1.7	Construction of a fuse-link	105

7.1.8	Non-interchangeability	105
7.2	Insulating properties and suitability for isolation	105
7.3	Temperature rise, power dissipation of the fuse-link and acceptable power dissipation of the fuse-holder	105
7.7	I^2t characteristics	105
7.7.1	Pre-arcing I^2t values	105
7.9	Protection against electric shock	105
8	Tests	106
8.1.4	Arrangement of the fuse-link for tests	106
8.1.5	Testing of fuse-links	106
8.2.4	Acceptability of test results	107
8.3	Verification of temperature rise and power dissipation	108
8.3.1	Arrangement of the fuse	108
8.3.4	Test method	108
8.3.5	Acceptability of test results	108
8.4	Verification of operation	108
8.4.1	Arrangement of the fuse	108
8.5	Breaking-capacity tests	109
8.5.1	Arrangement of the fuse	109
8.5.2	Characteristics of the test circuit	109
8.5.4	Calibration of the test circuit	109
8.5.5	Test method	109
8.5.8	Acceptability of test results	109
8.7	Verification of I^2t characteristics and overcurrent discrimination	110
8.7.3	Verification of compliance for fuse-links at 0,01 s	110
8.10	Verification of non-deterioration of contacts	110
8.11.1	Mechanical strength	110
Annex BB (informative) (for all fuse systems) – Alternative tests for tests No. 1 and No. 2 of Table 20 of IEC 60269-1:2024		115
BB.1	Test method	115
BB.2	Test No. 1	115
BB.3	Test No. 2	115
Annex CC (informative) Recommendations for future designs of fuses (for all fuse systems)		117
CC.1	Overview	117
CC.2	Fuse contacts	117
CC.3	Protection against electric shock	117
Bibliography		118
Figure 101 – Time-current zones for "gG" fuse-links		35
Figure 102 – Time-current zones for "gG" fuse-links		36
Figure 103 – Time-current zone for "gG" fuse-links 13 A and 32 A		37
Figure 104 – Dummy fuse-links according to 8.3 and 8.9.1.1		38
Figure 105 – Test rigs for fuse-links		39
Figure 106 – Test rigs for fuse-links		40
Figure 107 – Test arrangement for fuse-bases according to 8.9.1.2		41
Figure 108 – Example of a torque wrench according to 8.9.2		42

Figure 109 – Measuring points according to 8.3.3, 8.3.4.1 and 8.10.2 of fuse system A	43
Figure 110 – Fuse-link, D-type. Sizes D01-D03.....	44
Figure 111 – Fuse-link, D-type. Sizes DII-DIV	46
Figure 112 – Fuse-carrier, D-type. Sizes D01-D03	47
Figure 113 – Fuse-carrier, D-type. Sizes DII-DIII.....	48
Figure 114 – Fuse-carrier, D-type. Size DIV.....	49
Figure 115 – Edison thread for D-type fuses; limit dimensions	50
Figure 116 – Gauges for Edison thread for D-type fuses for screwed shells of fuse-carrier go ring gauges	51
Figure 117 – Gauges for Edison thread, D-type fuses, go and not-go plug gauges for screwed shells of fuse-bases	53
Figure 118 – Fuse-base, D-type. Sizes D01-D03	54
Figure 119 – Fuse-base, D-type. Sizes DII-DIV.....	55
Figure 120 – Fuse-base, D-type for push-in gauge pieces. Size DII-DIII.....	56
Figure 121 – Gauge-piece and hand-key, D-type. Sizes D01-D03	58
Figure 122 – Gauge-piece and hand-key, D-type. Sizes DII-DIV	60
Figure 123 – Gauge-piece and hand-key, D-type push-in gauge rings. Size DII-DIII.....	62
Figure 124 – Whitworth thread W 3/16 for screw-in gauge rings and corresponding fuse-bases of sizes DII and DIII	63
Figure 125 – Gauges C 17 for concentricity of fuse-bases	64
Figure 126 – Test dummies DII, DIII, D01, D02 and D03 for fuse-carrier test	65
Figure 127 – Time-current zone for "gG" fuse-links 40 A.....	66
Figure 201 – Fuse-link	83
Figure 202 – Dummy fuse-link	84
Figure 203 – Test-rig and ferrules for the measurement of the voltage drop and the verification of operating characteristics of the cartridge.....	85
Figure 204 – Fuse-base, A-type and B-type	86
Figure 205 – Housing for verification of operation of the fuse-links with a test rig according to Figure 203	87
Figure 206 – Test rig and ferrules for verification of breaking capacity	88
Figure 207 – Gauge for verification of the upholding of the cartridge in the fuse-carrier during withdrawal.....	89
Figure 301 – Details of cylindrical fuse-links	96
Figure 302 – Typical outline dimensions of carriers and bases for 230 V cylindrical fuse-links	97
Figure 303 – Typical carrier and base for 400 V cylindrical fuse-links	97
Figure 304 – Time-current zones for "gG" fuse-link	98
Figure 305 – Time-current zones for "gG" fuse-link	99
Figure 306 – Standard test rig for power-dissipation test.....	100
Figure 307 – Breaking-capacity test rig	102
Figure 601 – Dimensions for cylindrical fuse-links (primarily used in plugs).....	111
Figure 602 – Time-current zones for "gG" fuse-links	112
Figure 603 – Test fuse-base	113
Figure 604 – Typical diagram of the circuit used for breaking-capacity tests	114
Figure BB.1 – Instant of making for Test No. 1.....	116

Table 101 – Maximum values of power dissipation.....	17
Table 102 – Conventional time and current for "gG" fuse-links	18
Table 103 – Gates for specified pre-arcing times of "gG" fuse-links with rated currents 2 A, 4 A, 6 A, 10 A, 13 A and 35 A	18
Table 104 – Cross-sections of rigid (solid or stranded) or flexible copper conductors.....	20
Table 105 – Creepage distances, clearances and distances through sealing compound	22
Table 106 – Temperature-rise limits for terminals	23
Table 107 – Pre-arcing I^2t values at 0,01 s for "gG" fuse-links.....	23
Table 108 – I^2t values for the discrimination with circuit breakers	23
Table 109 – Survey of tests on fuse-links.....	25
Table 110 – Survey of tests on fuse-bases, fuse-carriers and gauge-pieces	25
Table 111 – Test torque for verification of temperature rise and power dissipation.....	26
Table 112 – Test according to 8.5.5.1	27
Table 113 – Test currents and I^2t limits for the discrimination test.....	28
Table 114 – Power dissipation of a dummy fuse-link at rated and conventional fusing currents including tolerances	29
Table 115 – Test-torque for mechanical strength	33
Table 116 – Mechanical strength of screw-thread	33
Table 201 – Maximum values of rated power dissipation and values of rated acceptable power dissipation	69
Table 202 – Conventional times and currents for "gG" fuse-links	70
Table 203 – Gates for specified pre-arcing times of "gG" fuse-links with rated currents lower than 16 A.....	70
Table 204 – Minimum rated breaking capacities.....	70
Table 205 – Nominal section of copper conductors that the terminals shall accept.....	71
Table 206 – Creepage distances and clearances	73
Table 207 – Temperature rise limits for terminals.....	73
Table 208 – Pre-arcing I^2t values at 0,01 s for "gG" fuse-links.....	73
Table 209 – Survey of tests on fuse-link	74
Table 210 – Survey of tests on fuse-holder and number of fuse-holders to be tested	75
Table 211 – Screw-thread diameters and applied torques.....	75
Table 212 – Values concerning the choice and the adjustment of the test base	76
Table 213 – Values for adjustment of the test base.....	77
Table 214 – Hammer and height of fall for test for verification of resistance to shocks	80
Table 215 – Torque to be applied to the fuse-carrier	81
Table 216 – Mechanical strength of screw-thread	82
Table 301 – Conventional time and current for "gG" fuse-links	91
Table 302 – Temperature-rise limits for terminals	93
Table 303 – Mechanical strength of screw-thread	95
Table 601 – Conventional I^2t times and conventional currents	104
Table 602 – Gates for specified pre-arcing times of "gG" fuse-links for use in plugs.....	104
Table 603 – Temperature-rise limits for terminals	105

Table 604 – Pre-arcing I^2t values at 0,01 s for "gG" fuse-links.....	105
Table 605 – Survey of tests on fuse-links.....	107
Table 606 – Values for breaking-capacity tests	109
Table BB.1 – Approximate values of prospective currents for breaking capacity test No. 2..	115

This document is a preview generated by EVS

INTERNATIONAL ELECTROTECHNICAL COMMISSION

LOW-VOLTAGE FUSES –

**Part 3: Supplementary requirements for fuses
for operation by unskilled persons
(fuses mainly for household and similar applications) –
Examples of standardized systems of fuses A to F**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 60269-3 has been prepared by subcommittee 32B: Low-voltage fuses, of IEC technical committee 32: Fuses. It is an International Standard.

This fifth edition cancels and replaces the fourth edition published in 2010, Amendment 1:2013 and Amendment 2:2019. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) Introduction and general scope fully updated;
- b) Normative references updated and editorial changes;

- c) Terms “ordinary person”, “operation” and “non-interchangeability” defined;
- d) In System A: Parts defined for removal;
- e) In System A: Marking of fuse-bases added for direction of current flow;
- f) In System A: Clarifications added for connection;
- g) In System A: Clarification of construction of fuse-carrier and fuse-link;
- h) In System A: Clarification of voltage drop measurement.

The text of this International Standard is based on the following documents:

Draft	Report on voting
32B/745/FDIS	32B/754/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This part is to be used in conjunction with IEC 60269-1:2024, *Low-voltage fuses – Part 1: General requirements*.

This Part 3 supplements or modifies the corresponding clauses or subclauses of Part 1.

Where no change is necessary, this Part 3 indicates that the relevant clause or subclause applies.

Tables and figures which are additional to those in Part 1 are numbered starting from 101. Additional annexes are numbered AA, BB, etc.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

IEC 60269 consists of the following parts, under the general title *Low-voltage fuses*:

Part 1: *General requirements*

Part 2: *Supplementary requirements for fuses for use by authorized persons (fuses mainly for industrial application) – Examples of standardized systems of fuses A to K*

Part 3: *Supplementary requirements for fuses for use by unskilled persons (fuses mainly for household or similar applications) – Examples of standardized systems of fuses A to F*

Part 4: *Supplementary requirements for fuse-links for the protection of semiconductor devices*

Part 5: *Guidance for the application of low-voltage fuses*

A list of all parts of the IEC 60269 series, under the general title, *Low-voltage fuses*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

This document is a preview generated by EVS

INTRODUCTION

Fuses for use by unskilled persons according to the following fuse systems comply with all subclauses of IEC 60269-1 and with the requirements laid down in the relevant fuse systems.

This part of IEC 60269 is divided into four fuse systems, each dealing with a specific example of standardized fuses for use by unskilled persons.

All systems provide their own mechanical solution to avoid the use of a fuse-link with higher current rating (non-interchangeability) to ensure the protection of cables and lines. The applicant is required to take care to replace a fuse-link by the same type.

Fuse system	Principles of non-interchangeability
Fuse system A: D type fuse system 1)	Diameter and shape at bottom side of the fuse-links differs, fuse bases require gauge-pieces
Fuse system B: Cylindrical fuses (NF cylindrical fuse system) 2)	Fuse-links and suitable fuse-holders (fuse-carriers) provide unique dimensions
Fuse system C: Cylindrical fuses (BS cylindrical fuse system) 2)	Fuse-links and suitable fuse-holders (fuse-carriers) provide unique dimensions
Fuse system F: Cylindrical fuse-links for use in plugs (BS plugtop fuse system) 1)	Fuse-links and suitable fuse-holders (fuse-carriers) provide unique dimensions

NOTE 1 Applicants of system A and F may have fuse-bases in their installation not providing degree of protection IP2X all the time. The degree of protection may temporarily be reduced to IP1X, when replacing the fuse-link. The temporary suspension of the complete protection IP2X against electric shock (after many years of sufficiently safe application of the D-type fuse system by unskilled users) need not be regarded as dangerous, as there is enough experience with interchanging of incandescent lamps, where comparable degrees of safety exist. For future designs Annex CC recommends that the degree of protection against electric shock during the period of replacing a fuse-link should be at least IP2X.

NOTE 2 Fuse-links are not to be interchanged with fuse-links of the same dimension but with different characteristics (e. g. aM).

It is important for safety and therefore strictly forbidden to mix components of different fuse-systems such as fuse-links, fuse-holders and fuse-bases.

LOW-VOLTAGE FUSES –

Part 3: Supplementary requirements for fuses for operation by unskilled persons (fuses mainly for household and similar applications) – Examples of standardized systems of fuses A to F

1 General Scope

This part of IEC 60269 is divided into four fuse systems, each dealing with a specific example of standardized fuses for use by unskilled persons.

This part applies to “gG” fuses only.

Unskilled persons do not have technical knowledge or sufficient experience. To avoid dangers, which electricity may create, the relevant part of the fuse standard shall provide requirements for maximum safety in service. IEC 60269-3 provides four systems for use by unskilled persons. Instructions for the safe operation of fuse-links are provided in the manufacturer’s literature.

All systems provide their own mechanical solution to avoid the use of a fuse-link with higher current rating (non-interchangeability) whereas the protection of cables and lines is ensured. The applicant is required to take care to replace a fuse-link by the same type.

Fuse system	Principles of non-interchangeability
Fuse system A: D type fuse system 1)	Diameter and shape at bottom side of the fuse-links differs, fuse bases require gauge-pieces
Fuse system B: Cylindrical fuses (NF cylindrical fuse system) 2)	Fuse-links and suitable fuse-holders (fuse-carriers) provide unique dimensions
Fuse system C: Cylindrical fuses (BS cylindrical fuse system) 2)	Fuse-links and suitable fuse-holders (fuse-carriers) provide unique dimensions
Fuse system F: Cylindrical fuse-links for use in plugs (BS plugtop fuse system) 1)	Fuse-links and suitable fuse-holders (fuse-carriers) provide unique dimensions

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60068-2-31, *Environmental testing – Part 2-31: Tests – Test Ec: Rough handling shocks, primarily for equipment-type specimens*

IEC 60269-1:2024, *Low-voltage fuses – Part 1: General requirements*

IEC 60664 (all parts), *Insulation coordination for equipment within low-voltage systems*

IEC 60898-1:2015, *Electrical accessories – Circuit-breakers for overcurrent protection for household and similar installations – Part 1: Circuit-breakers for AC operation*
IEC 60898-1:2015/AMD1:2019

IEC 60999-1:1999, *Connecting devices – Electrical copper conductors – Safety requirements for screw-type and screwless-type clamping units – Part 1: General requirements and particular requirements for clamping units for conductors from 0,2 mm² up to 35 mm² (included)*

IEC 61439-1, *Low-voltage switchgear and controlgear assemblies – Part 1: General rules*

IEC 61439-3:2012, *Low-voltage switchgear and controlgear assemblies – Part 3: Distribution boards intended to be operated by ordinary persons (DBO)*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 60269-1:2024 and the following apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- IEC Electropedia: available at <https://www.electropedia.org/>
- ISO Online browsing platform: available at <https://www.iso.org/obp>

3.1

ordinary person

person who is neither a skilled person nor an instructed person

3.2

operation

operation is defined for this standard as the exchange of the fuse-link

3.3

non interchangeability

limitations on shape and/or dimensions with the object of avoiding in a specific fuse-base the inadvertent use of fuse-links having electrical properties other than those ensuring the desired degree of protection

[SOURCE: IEC 60050-441:1984, 441-18-33]