



Sisaldab värvilisi lehekülgi
Colour inside

**RAUDTEEALASTE RAKENDUSTE PÜSIPAIGALDISED.
ELEKTRIOHUTUS, MAANDAMINE JA TAGASIVOOLOUAHEL.
OSA 1: KAITSEMEETMED ELEKTRILÖÖGI EEST**

**Fixed installations for railway applications - Electrical
safety, earthing and the return circuit - Part 1: Protective
provisions against electric shock**

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 50122-1:2022+A1:2025 sisaldab Euroopa standardi EN 50122-1:2022 ja selle muudatuse A1:2025 ingliskeelset teksti.	This Estonian standard EVS-EN 50122-1:2022+A1:2025 consists of the English text of the European standard EN 50122-1:2022 and its amendment A1:2025.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas. Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 02.09.2022, muudatus A1 01.08.2025.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation and Accreditation. Date of Availability of the European standard is 02.09.2022, for A1 01.08.2025.
Muudatusega A1 lisatud või muudetud teksti algus ja lõpp on tekstis tähistatud sümbolitega   .	The start and finish of text introduced or altered by amendment A1 is indicated in the text by tags   .
Standard on kättesaadav Eesti Standardimis- ja Akrediteerimiskeskusest.	The standard is available from the Estonian Centre for Standardisation and Accreditation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 29.280

<p>Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardimis- ja Akrediteerimiskeskusele</p> <p>Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardimis- ja Akrediteerimiskeskuse kirjaliku loata on keelatud.</p> <p>Kui Teil on küsimusi standardite autoriõiguse kaitse kohta, võtke palun ühendust Eesti Standardimis- ja Akrediteerimiskeskusega: Koduleht www.evs.ee; telefon 605 5050; e-post info@evs.ee</p> <p>The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation and Accreditation</p> <p>No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation and Accreditation.</p> <p>If you have any questions about standards copyright protection, please contact the Estonian Centre for Standardisation and Accreditation: Homepage www.evs.ee; phone +372 605 5050; e-mail info@evs.ee</p>
--

ICS 29.280

Supersedes EN 50122-1:2011; EN 50122-1:2011/A1:2011; EN 50122-1:2011/AC:2012; EN 50122-1:2011/A2:2016; EN 50122-1:2011/A3:2016; EN 50122-1:2011/A4:2017

English Version

A1 Fixed installations for railway application **A1** - Electrical safety, earthing and the return circuit - Part 1: Protective provisions against electric shock**A1** Installations Fixes pour applications ferroviaires **A1** - Sécurité électrique, mise à la terre et circuit de retour - Partie 1: Mesures de protection contre les chocs électriques**A1** Ortsfeste Anlagen für Bahnanwendungen **A1** - Elektrische Sicherheit, Erdung und Rückleitung - Teil 1: Schutzmaßnahmen gegen elektrischen Schlag

This European Standard was approved by CENELEC on 2022-07-25. Amendment A1 was approved by CENELEC on 2025-06-23. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard and its amendment the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard and its Amendment A1 exist in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents

	Page
European foreword	7
▣ Amendment A1 European foreword ▣	8
1 Scope	9
2 Normative references	10
3 Terms and definitions	11
3.1 Electrical safety and hazards	11
3.2 Earthing and equipotential bonding	13
3.3 Return circuit	15
3.4 Electric traction power supply system	17
3.5 Contact line	18
3.6 Corrosion and corrosion protection	21
3.7 Current collection	21
3.8 Residual current devices	22
3.9 General terms	22
4 Contact line zone and current collector zone	25
4.1 Overhead contact line	25
4.2 Ground level conductor rail	28
4.3 Trolleybuses and road vehicles using an overhead contact line	28
4.4 Limitation of the zones	29
5 Protective provisions against direct contact	30
5.1 Preconditions	30
5.1.1 General	30
5.1.2 Design procedure	30
5.1.3 Electrical clearances	31
5.1.4 Standing surface	32
5.2 Protection by clearance	33
5.2.1 Calculation method for protection by clearance	33
5.2.2 Dimensions of clearances	34
5.2.3 Clearances for working persons	36
5.2.4 Warning signs	36
5.2.5 Minimum height of wires of an overhead contact line system above traffic areas	37
5.2.6 ▣ Clearances above standing surfaces on vehicles with open roof ▣	37
5.2.7 Feeders above loading roads	37
5.2.8 Clearance between live parts of overhead contact line systems and trees and bushes	37
5.3 Protection by electrically protective obstacles	37
5.3.1 General	37
5.3.2 Common requirements for electrically protective obstacles	38
5.3.3 Methods for determining reach	39
5.3.4 Requirements for electrically protective obstacles	41
5.3.5 Specific requirements for electrically protective obstacles in restricted areas	47
5.3.6 Anti climbing provisions	48
5.4 Protection against direct contact with live parts mounted on vehicles	48
5.5 Protective provisions allowing working under live conditions	49
5.5.1 General	49
5.5.2 Overhead contact lines for railways beneath structures	50

5.5.3	Overhead contact lines for trolley busses and electric road vehicles beneath structures	50
5.6	Specific protective provisions against electric shock in ground level conductor rail systems.....	52
5.6.1	Location of conductor rail at platforms	52
5.6.2	Exceptions.....	52
5.6.3	Protection provisions in workshops and depots.....	52
5.6.4	Protective boarding for ground level conductor rails in restricted areas	53
5.6.5	Requirements for top contact ground level conductor rails in public areas	53
5.6.6	Requirements for top contact ground level conductor rails in restricted areas.....	53
5.7	Specific protective provisions against electric shock in systems in which the wheels of the vehicles are not used for return circuit	56
5.7.1	General.....	56
5.7.2	Railway systems	56
5.7.3	Trolleybus systems and systems for electric road vehicles	56
6	Protective provisions against indirect contact and non-galvanic coupling.....	57
6.1	General.....	57
6.2	Protective provisions for exposed-conductive-parts	57
6.2.1	AC railways	57
6.2.2	DC railways	58
6.2.3	Exceptions for low voltage electric traction power supply systems	58
6.2.4	Stays of non-conductive masts	59
6.3	Protective provisions for wholly or partly conductive structures in the overhead contact line zone or the current collector zone.....	59
6.3.1	Protective provisions by means of connection to the return circuit.....	59
6.3.2	Exceptions for small wholly and partly conductive parts.....	60
6.3.3	Exceptions for temporarily stored parts close to the rails	61
6.3.4	Protective provisions preventing contact between conductive parts and live parts.....	61
6.3.5	Protective provisions by means of bare conductive parts connected to the return circuit.....	61
6.3.6	Protective provisions by automatic disconnection of supply.....	61
6.4	Parts which can become hazardous due to inductive or capacitive coupling.....	61
7	Protective provisions for low voltage non-traction power supply systems	62
7.1	General.....	62
7.2	Protective provisions for electrical installations in the overhead contact line zone or the current collector zone.....	63
7.2.1	Equipment of protection Class I	63
7.2.2	Equipment of protection Class II	64
7.2.3	Cables	65
7.2.4	Low voltage connected equipment	65
7.3	Protective provisions for installations which are endangered by the traction power supply return circuit.....	65
7.3.1	Design of low voltage non-traction power supply	65
7.3.3	Low voltage power supply by TN system.....	69
7.3.4	Low voltage power supply by IT system	71
7.3.5	Special provisions	73
8	Protective provisions where track systems, which are utilized for carrying traction return current, or/and overhead contact line systems pass through hazardous zones.....	76
8.1	General.....	76
8.2	Equipotential bonding.....	77
8.3	Parallel pipework.....	78

8.4	Insulating joints	78
8.5	Surge arrester	79
8.6	Overhead contact line of loading sidings	79
9	Limits for touch voltage and protective provisions against the danger of rail potential	79
9.1	General	79
9.1.1	Preconditions	79
9.1.2	Body voltage and touch voltage	80
9.1.3	Touch voltage at vehicles	80
9.1.4	Short-circuit duration	80
9.1.5	Voltage limits and time duration aspects	80
9.2	Touch voltage limits in AC railways	80
9.2.1	General	80
9.2.2	AC voltage limits for the safety of persons	81
9.3	Touch voltage limits in DC railways	84
9.3.1	General	84
9.3.2	DC voltage limits for the safety of persons	84
9.4	Access Control	87
10	Additional requirements	87
10.1	Traction substations and traction switching stations	87
10.2	Cables	88
10.2.1	General requirements	88
10.2.2	Cables in AC electric traction power supply systems	88
10.2.3	Cables in DC electric traction systems	88
10.3	Extended return circuit connections and earthing conductors	88
10.3.1	General requirements	88
10.3.2	Continuity of the extended return circuit	88
10.3.3	Cross bonding of the return circuit	89
10.3.4	Railway systems in which the traction current is confined within insulated conductors	89
10.4	Removing of decommissioned contact lines	89
10.5	Means of achieving safe isolation between sections	89
10.6	Lightning protection	89
Annex A (normative)	Clearances from standing surfaces for exceptional use on existing lines with restricted gauge	90
Annex B (informative)	Typical layouts of protective obstacles	92
B.1	General	92
B.2	Examples	94
Annex C (normative)	Warning sign	101
Annex D (informative)	Guiding values for rail potential gradient	102
D.1	AC railways	102
D.2	DC railways	103
Annex E (informative)	Effective touch voltage and body voltage with respect to the body current	104
E.1	Preconditions for the calculation	104
E.2	Impedances	104
E.3	Body current and related body voltage	107
Annex F (normative)	Measurement methods for effective touch voltages	110
Annex G (normative)	Use of voltage-limiting devices	111
G.1	General	111

G.2	Types.....	111
G.3	Technical requirements.....	111
	Bibliography.....	113

Figures

Figure 1	— Overhead contact line zone and current collector zone.....	27
Figure 2	— Overhead contact line zone and current collector zone for trolley bus systems and electric road vehicles using a bipolar contact line.....	29
Figure 3	— Design procedure to achieve protection against direct contact.....	31
Figure 4	— Manikin model to be used for the analysis of the arm's reach.....	34
Figure 5	— Minimum distances to accessible live parts from standing surfaces accessible to persons.....	35
Figure 6	— Application of taut string line method compared with manikin method.....	40
Figure 7	— Minimum distance behind electrically protective obstacles with openings.....	43
Figure 8	— Example for a gap between a standing surface and an electrically protective obstacle, side view.....	45
Figure 9	— Effect of an electrically protective obstacle on arms reach of person including an object, top view.....	46
Figure 10	— Live parts below standing surfaces.....	47
Figure 11	— Method for the determination of clearances for live parts on the outside of vehicles.....	49
Figure 12	— Example of an insulated obstacle beneath a structure.....	50
Figure 13	— Example of an insulated electrically protective obstacle beneath a structure for an unearthed installation.....	51
Figure 14	— Example of an insulated electrically protective obstacle beneath a structure for a bipolar overhead contact line in which the negative contact wire is earthed or connected to the return circuit of a tramway system.....	52
Figure 15	— Public level crossing, private level crossing.....	53
Figure 16	— Trackside structures.....	54
Figure 17	— Track-side telephone mounted on a signal-post.....	54
Figure 18	— Authorized trackside walking route.....	55
Figure 19	— Railway controlled crossing (depots, goods yard, station crossing).....	55
Figure 20	— Protection Class I equipment installed outside the overhead contact line zone and the current collector zone.....	64
Figure 21	— Typical TT system for AC railways.....	67
Figure 22	— Typical TT system for DC railways.....	68
Figure 23	— Typical TN system for AC railways.....	70
Figure 24	— Typical TN system for DC railways.....	71
Figure 25	— Typical IT system for AC railways.....	72
Figure 26	— TN system for AC railways with interconnected earth system.....	74
Figure 27	— TN system for AC railways with multiple supply points.....	75
Figure 28	— Disposition of rail-to-rail cross bonds and track-to-track cross bonds (double-rail illustration) and connection of the contact line in case of the loading siding having a contact line.....	78
Figure 29	— Location of a surge arrester outside the overhead contact line zone of a loading siding if there is a possibility of flashovers of the insulating pieces through lightning strikes.....	79
Figure 30	— Design of return circuit, with regard to permissible effective touch voltage by checking the rail potential or the effective touch voltage.....	81
Figure A.1	— Alternative clearances for existing lines/networks.....	91
Figure B.1	— Typical protective obstacles and obstacle combinations and their dimensions and properties.....	93

Figure B.2 — Inclined protective obstacle, total height 1,00 m, solid-wall 94

Figure B.3 — Solid-wall protective obstacle, total height 1,69 m (balustrade wall)..... 95

Figure B.4 — Combined protective obstacle with an inclined part on the top of the main protective obstacle, total height 1,50 m..... 96

Figure B.5 — Combined protective obstacle with an inclined part (0,50 m width) on the standing surface level, total height 1,00 m..... 97

Figure B.6 — Combined protective obstacle with an inclined part (1,60 m width) on the standing surface level, total height 1,00 m..... 98

Figure B.7 — Combined protective obstacle with a total height of 1,80 m..... 99

Figure B.8 — Arrangement of three protective obstacles..... 100

Figure C.1 — Warning sign 101

Figure D.1 — Guidance values for the rail potential gradient measured at the mast in a right angle to the track of an AC railway..... 102

Figure E.1 — Equivalent circuit for the calculation of the permissible touch voltage 106

Tables

Table 1 — Electrical clearances 32

Table 2 — Protection clearances..... 32

Table 3 — Minimum vertical height V of accessible live parts above standing surfaces for public areas..... 36

Table 4 — Minimum distance d_0 between live parts and an electrically protective obstacle 44

Table 5 — Maximum dimensions for small wholly and partly conductive parts 60

Table 6 — Types of low voltage non-traction supplies 66

Table 7 — Maximum permissible body voltages $U_{b, \max}$ in AC electric traction power supply systems as a function of time duration 82

Table 8 — Maximum permissible effective touch voltages $U_{te, \max}$ in AC electric traction power supply systems as a function of time duration..... 83

Table 9 — Maximum permissible body voltages $U_{b, \max}$ in DC electric traction power supply systems as a function of time duration 85

Table 10 — Maximum permissible effective touch voltages $U_{te, \max}$ in DC electric traction power supply systems as a function of time duration..... 86

Table D.1 — Guidance values for the rail potential gradient (see Figure D.1)..... 103

Table E.1 — Body impedance Z_b , body resistance R_b and body current I_b 105

Table E.2 — Example of the maximum permissible prospective touch voltage for AC railways for short-term conditions and $R_a = 1\ 150\ \Omega$ 107

Table E.3 — Body currents, body voltages and touch voltages as function of time duration in AC electric traction power supply systems 108

Table E.4 — Body currents, body voltages and touch voltages as function of time duration in DC electric traction power supply systems 109

European foreword

This document (EN 50122-1:2022) has been prepared by CLC/SC 9XC "Electric supply and earthing systems for public transport equipment and ancillary apparatus (Fixed installations)".

The following dates are fixed:

- latest date by which this document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2023-07-25
- latest date by which the national standards conflicting with this document have to be withdrawn (dow) 2025-07-25

This document supersedes EN 50122-1:2011 and all of its amendments and corrigenda (if any).

EN 50122-1:2022 includes the following significant technical changes with respect to EN 50122-1:2011:

- some definitions were modified;
- the dimensions for protection by clearance were modified, and there are now voltage dependent differences for high voltage electric traction power supply systems;
- methods for the use of protective obstacles were significantly changed.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a Standardization Request given to CENELEC by the European Commission and the European Free Trade Association.

Any feedback and questions on this document should be directed to the users' national committee. A complete listing of these bodies can be found on the CENELEC website.

A1 Amendment A1 European foreword

This document (EN 50122-1:2022/A1:2025) has been prepared by SC 9XC, “Electric supply and earthing systems for public transport equipment and ancillary apparatus (fixed installations)”, of CLC/TC 9X, “Electrical and electronic applications for railways”.

The following dates are fixed:

- latest date by which this document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2026-08-31
- latest date by which the national standards conflicting with this document have to be withdrawn (dow) 2028-08-31

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a Standardization Request addressed to CENELEC by the European Commission. The Standing Committee of the EFTA States subsequently approves these requests for its Member States.

Any feedback and questions on this document should be directed to the users' national committee. A complete listing of these bodies can be found on the CENELEC website. **A1**

1 Scope

This document specifies requirements for the protective provisions relating to electrical safety in fixed installations associated with AC and/or DC traction systems and to any installations that can be endangered by the electric traction power supply system. This also includes requirements applicable to vehicles on electrified lines.

It also applies to all aspects of fixed installations which are necessary to ensure electrical safety during maintenance work within electric traction power supply systems.

This document applies to new electric traction power supply systems and major revisions to electric traction power supply systems for:

- a) railways;
- b) guided mass transport systems such as
 - 1) tramways,
 - 2) elevated and underground railways,
 - 3) mountain railways,
 - 4) trolleybus systems,
 - 5) electric traction power supply systems for road vehicles, which use an overhead contact line system, and
 - 6) magnetically levitated systems, which use a contact line system;
- c) material transportation systems.

This document does not apply to:

- a) electric traction power supply systems in underground mines,
- b) cranes, transportable platforms and similar transportation equipment on rails, temporary structures (e.g. exhibition structures) in so far as these are not supplied directly or via transformers from the contact line system and are not endangered by the electric traction power supply system,
- c) suspended cable cars,
- d) funicular railways,
- e) existing vehicles.

This document does not specify working rules for maintenance.

The requirements within this document related to protection against electric shock are applicable to persons only.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 50119:2020, *Railway applications - Fixed installations - Electric traction overhead contact lines*

EN 50122-2:2022, *Railway applications – Fixed installations – Electrical safety, earthing and the return circuit - Part 2: Provisions against the effects of stray currents caused by d.c. traction systems*

EN 50124-1:2017, *Railway applications - Insulation coordination - Part 1: Basic requirements - Clearances and creepage distances for all electrical and electronic equipment*

EN 50153:2014,¹ *Railway applications - Rolling stock - Protective provisions relating to electrical hazards*

EN 50163:2004,² *Railway applications - Supply voltages of traction systems*

EN 50341 (series), *Overhead electrical lines exceeding AC 1 kV*

EN 50522:2010, *Earthing of power installations exceeding 1 kV a.c.*

EN 60529:1991,³ *Degrees of protection provided by enclosures (IP Code) (IEC 60529:1989)*

EN 60898-1:2019, *Electrical accessories - Circuit-breakers for overcurrent protection for household and similar installations - Part 1: Circuit-breakers for a.c. operation (IEC 60898-1:2016)*

EN 61140:2016, *Protection against electric shock - Common aspects for installation and equipment (IEC 61140:2016)*

EN 61936-1:2010,⁴ *Power installations exceeding 1 kV a.c. - Part 1: Common rules (IEC 61936-1:2010)*

EN 62305 (series), *Protection against lightning (IEC 62305 series)*

HD 60364-4-41:2017,⁵ *Low-voltage electrical installations – Part 4-41: Protection for safety – Protection against electric shock (IEC 60364-4-41:2005, modified)*

IEC 60755:2017, *General safety requirements for residual current operated protective devices*

ISO 3864-1:2011, *Graphical symbols — Safety colours and safety signs — Part 1: Design principles for safety signs and safety markings*

ISO 7010:2019, *Graphical symbols — Safety colours and safety signs — Registered safety signs*

¹ As impacted by EN 50153:2014/A1:2017 and EN 50153:2014/A2:2020.

² As impacted by EN 50163:2004/AC:2013 and EN 50163:2004/A2:2020.

³ As impacted by EN 60529:1991/A1:2000 and EN 60529:1991/A2:2013.

⁴ As impacted by EN 61936-1:2010/AC:2011, EN 61936-1:2010:2013 and EN 61936-1:2010/A1:2014.

⁵ As impacted by HD 60364-4-41:2017/A11:2017 and HD 60364-4-41:2017/A12:2019.