

TECHNICAL REPORT

RAPPORT TECHNIQUE



BASIC SAFETY PUBLICATION

PUBLICATION FONDAMENTALE DE SÉCURITÉ

**Insulation coordination for equipment within low-voltage systems –
Part 2-1: Application guide – Explanation of the application of
the IEC 60664 series, dimensioning examples and dielectric testing**

**Coordination de l'isolement des matériels dans les systèmes (réseaux) à basse
tension –**

**Partie 2-1: Guide d'application – Explication de l'application de la série
CEI 60664, exemples de dimensionnement et d'essais diélectriques**



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2011 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland
Email: inmail@iec.ch
Web: www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: www.iec.ch/searchpub

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: www.iec.ch/online_news/justpub

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: www.iec.ch/webstore/custserv

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: csc@iec.ch

Tel.: +41 22 919 02 11

Fax: +41 22 919 03 00

A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

- Catalogue des publications de la CEI: www.iec.ch/searchpub/cur_fut-f.htm

Le Catalogue en-ligne de la CEI vous permet d'effectuer des recherches en utilisant différents critères (numéro de référence, texte, comité d'études,...). Il donne aussi des informations sur les projets et les publications retirées ou remplacées.

- Just Published CEI: www.iec.ch/online_news/justpub

Restez informé sur les nouvelles publications de la CEI. Just Published détaille deux fois par mois les nouvelles publications parues. Disponible en-ligne et aussi par email.

- Electropedia: www.electropedia.org

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International en ligne.

- Service Clients: www.iec.ch/webstore/custserv/custserv_entry-f.htm

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions, visitez le FAQ du Service clients ou contactez-nous:

Email: csc@iec.ch

Tél.: +41 22 919 02 11

Fax: +41 22 919 03 00

TECHNICAL REPORT

RAPPORT TECHNIQUE



BASIC SAFETY PUBLICATION

PUBLICATION FONDAMENTALE DE SÉCURITÉ

**Insulation coordination for equipment within low-voltage systems –
Part 2-1: Application guide – Explanation of the application of
the IEC 60664 series, dimensioning examples and dielectric testing**

**Coordination de l'isolement des matériels dans les systèmes (réseaux) à basse
tension –
Partie 2-1: Guide d'application – Explication de l'application de la série
CEI 60664, exemples de dimensionnement et d'essais diélectriques**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

PRICE CODE
CODE PRIX

XB

ICS 29.080.30

ISBN 978-2-88912-351-3

CONTENTS

FOREWORD.....	6
INTRODUCTION.....	8
1 Scope.....	9
2 Normative references.....	9
3 Terms and definitions.....	10
4 Principles and practical application of the IEC 60664 series for insulation dimensioning of LV equipment.....	17
4.1 Basic principles.....	17
4.2 Coordination of overvoltage categories inside equipment.....	17
4.3 Practical use of the IEC 60664 series for the dimensioning of clearances.....	18
4.3.1 General.....	18
4.3.2 Practical use of Tables F.2 and F.7 of IEC 60664-1:2007 for the dimensioning of clearances.....	18
4.3.3 Practical use of Tables 2 and 3 of IEC 60664-5:2007 for the dimensioning of clearances.....	20
4.4 Practical use of the IEC 60664 series for the dimensioning of creepage distances.....	20
4.4.1 General.....	20
4.4.2 Practical use of Table F.4 of IEC 60664-1:2007 and Table 4 of IEC 60664-5:2007 for the dimensioning of creepage distances.....	21
4.4.3 Practical use of Table 5 in IEC 60664-5:2007 for dimensioning of creepage distances.....	22
4.4.4 Practical use of IEC 60664-1:2007 for checking the dimensioning of creepage distances with regard to time under voltage stress.....	22
4.4.5 Practical use of IEC 60664-3:2003 for the reduction of micro-environmental conditions for the dimensioning of creepage distances.....	23
4.5 Practical use of the IEC 60664 series for the dimensioning of solid insulation.....	23
4.5.1 General.....	23
4.5.2 Coordination of clearances and solid insulation.....	24
4.5.3 Practical information for checking the correct dimensioning of solid insulation.....	25
4.6 Practical use of the IEC 60664 series for designing functional insulation.....	31
4.6.1 General.....	31
4.6.2 Dimensioning and testing of functional isolation compared to basic insulation.....	31
4.7 Practical use of the IEC 60664 series for dimensioning with respect to the influence of the frequency of the voltage.....	32
4.7.1 General influence of the frequency on withstand characteristics.....	32
4.7.2 Influence of the frequency on the withstand characteristics of clearances.....	32
4.7.3 Influence of frequency on the withstand characteristics of creepage distances.....	32
4.7.4 Influence of frequency on the withstand characteristics of solid insulation.....	33
5 Four examples showing appropriate dimensioning of insulation within equipment.....	34
5.1 General.....	34
5.2 Examples for the dimensioning of clearances for class I equipment according to IEC 60664-1.....	36

5.3	Examples for the dimensioning of clearances for class II equipment according to IEC 60664-1	37
5.4	Examples for the dimensioning of clearances for class II equipment according to IEC 60664-5	39
6	Practical application of the IEC 60664 series with regards to particular questions	40
6.1	General	40
6.2	Testing complete equipment in case of components bridging the basic insulation.....	40
6.3	Testing complete equipment in case of components bridging the functional insulation.....	41
6.3.1	General	41
6.3.2	Verification of clearances and creepage distances	41
6.3.3	Verification of components bridging the insulation	42
6.4	Dimensioning of insulation distances for parts of equipment which can have isolation capability.....	42
6.4.1	General	42
6.4.2	Dimensioning for device associated with an equipment declared suitable for isolation	42
6.4.3	Dimensioning for device associated with an equipment not declared suitable for isolation	42
6.5	Testing with respect to high-frequency voltage stress.....	43
6.6	Practical information in case of substitution an impulse withstand test by an AC or DC test.....	43
6.6.1	General	43
6.6.2	Characteristics of the a.c. voltage substituted to an impulse withstand test for dielectric test	43
6.6.3	Characteristics of the d.c. voltage substituted to an impulse withstand test for dielectric test	44
7	Examples of a dimensioning worksheet (based on case A as described in IEC 60664-1:2007)	44
7.1	Use of IEC 60664-1:2007, for circuits in equipment either directly or not directly connected to the mains supply	44
7.2	Use of IEC 60664-5:2007, for circuits in equipment either directly or not directly connected to the mains supply	45
7.3	Use of IEC 60664-4:2005, for circuits in equipment either directly or not directly connected to the mains supply	46
7.4	Examples comparing the dimensioning of clearances and creepage distances according to IEC 60664-1 and IEC 60664-5 based on case A condition (basic insulation, for equipment up to 2 000 m altitude).....	48
7.4.1	Circuits not directly connected to mains supply.....	48
7.4.2	Circuits not directly connected to mains supply.....	49
7.5	Examples of dimension comparison for clearances and creepage distances according to IEC 60664-1 and IEC 60664-4 based on case A condition (basic insulation, for equipment up to 2 000 m altitude)	50
7.5.1	Circuits not directly connected to mains supply.....	50
7.5.2	Circuits not directly connected to mains supply.....	52
	Annex A (informative) Overview of Clauses of IEC 60664-1 requiring decisions by technical committees, specification of options or requiring activities by the manufacturer	54
	Annex B (informative) Overview of Clauses of IEC 60664-4 requiring decisions by technical committees	58

Annex C (informative) Overview of Clauses of IEC 60664-5 requiring decisions by technical committees, specification of options or requiring activities by the manufacturer	59
Annex D (informative) Dimensioning of clearances and creepage distances for d.c. voltages above 1000 V d.c.....	63
Bibliography.....	64
Figure 1 – Breakdown voltage of solid insulation depending upon the time of voltage stress	24
Figure 2 – Series connection of clearance and solid insulation.....	27
Figure 3 – Capacitive voltage divider	27
Figure 4 – Permissible field strength for dimensioning of solid insulation according to Equation (7).....	34
Figure 5a – Example 1 – Simple illustration of insulation system containing functional, basic and reinforced/double insulation for a class I equipment.....	35
Figure 5b – Example 2 – Dimensioning of clearances for class I equipment, based on overvoltage category III	36
Figure 5c – Example 3 – Dimensioning of clearances (class II equipment).....	37
Figure 5d – Example 4 – Dimensioning of clearances (class II equipment).....	39
Figure 6 – Arrangement for a.c. (or d.c.) voltage test	41
Table 1 – Examples for rated voltage 100 V and 230 V and overvoltage category II.....	26
Table 2 – Example 2 – Dimensioning of clearances according to Table F.2 of IEC 60664-1:2007 (pollution degree 2) (see example 2 of Figure 5b).....	36
Table 3 – Example 2 – Dimensioning of clearances according to Tables F.2 and F.7a of IEC 60664-1:2007, temporary overvoltages according to 5.3.3.2.3 of IEC 60664-1:2007 (U_n+1200 V) (see example 2 of Figure 5b)	37
Table 4 – Example 3 – Dimensioning of clearances according to Table F.2 of IEC 60664-1:2007 (pollution degree 2) (see example 3 of Figure 5c).....	38
Table 5 – Example 3 – Dimensioning of clearances according to Tables F.2 and F.7a of IEC 60664-1:2007, temporary overvoltages according to 5.3.3.2.3 of IEC 60664-1:2007 (U_n+1200 V) (see example 3 of Figure 5c)	38
Table 6 – Example 4 – Dimensioning of clearances according to Table 2 of IEC 60664-5:2007 (see example 4 on Figure 5d)	39
Table 7 – Example 4 – Dimensioning of clearances according to Tables 2 and 3 of IEC 60664-5:2007, temporary overvoltages according to 5.3.3.2.3 of IEC 60664-1:2007 (U_n+1200 V) (see example 4 on Figure 5d).....	40
Table 8 – Relationship between influencing parameters and normative references in IEC 60664-1	44
Table 9 – Relationship between influencing parameters and normative references in IEC 60664-1 or IEC 60664-5.....	45
Table 10 – Relationship between influencing parameters and normative references in IEC 60664-1 or IEC 60664-4	46
Table 11 – Example for dimensioning a clearance and creepage distance following IEC 60664-1	48
Table 12 – Example for dimensioning a clearance and creepage distance following IEC 60664-5	49
Table 13 – Example for dimensioning a clearance and creepage distance following IEC 60664-1 in circuits not directly connected to mains supply	49

Table 14 – Example for dimensioning a clearance and creepage distance following IEC 60664-5 in circuits not directly connected to mains supply	50
Table 15 – Example for dimensioning a clearance and creepage distance following IEC 60664-1 in circuits not directly connected to mains supply	51
Table 16 – Example for dimensioning a clearance and creepage distance following IEC 60664-4 (approximately homogeneous field)	51
Table 17 – Example for dimensioning a clearance and creepage distance following IEC 60664-1 in circuits not directly connected to mains supply	52
Table 18 – Example for dimensioning a clearance and creepage distance following IEC 60664-4 (approximately homogeneous field)	53
Table A.1 – Clauses and titles of IEC 60664-1 and items to be considered by technical committees	54
Table A.2 – Clauses and titles of IEC 60664-1 and optional specifications for consideration by technical committees	56
Table A.3 – Clauses and titles of IEC 60664-1 and required manufacturer activities	57
Table B.1 – Clauses and titles of IEC 60664-4 and optional specifications for consideration by technical committees	58
Table C.1 – Clauses and titles of IEC 60664-5 and items to be considered by technical committees	59
Table C.2 – Clauses and titles of IEC 60664-5 and optional specifications for consideration by technical committees	61
Table C.3 – Clauses and titles of IEC 60664-5 and required manufacturer activities	62
Table D.1 – Rated impulse voltage for equipment	63

INTERNATIONAL ELECTROTECHNICAL COMMISSION

INSULATION COORDINATION FOR EQUIPMENT WITHIN LOW-VOLTAGE SYSTEMS –

Part 2-1: Application guide – Explanation of the application of the IEC 60664 series, dimensioning examples and dielectric testing

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. However, a technical committee may propose the publication of a technical report when it has collected data of a different kind from that which is normally published as an International Standard, for example "state of the art".

IEC/TR 60664-2-1, which is a technical report, serves as an application guide for the IEC 60664 series and has been prepared by IEC technical committee 109: Insulation coordination for low-voltage equipment.

This second edition cancels and replaces the first edition, published in 1997, and constitutes a technical revision.

The main changes with respect to the previous edition are listed below:

- the previous edition was only an application guide for IEC 60664-1. This second edition takes into account not only IEC 60664-1 but also the other parts IEC 60664-3, IEC 60664-4, and IEC 60664-5 and their interrelation;
- principles of the IEC 60664 series for insulation dimensioning of LV equipment are explained and examples of practical application are provided together with some background information;
- Annex A provides an overview of clauses of IEC 60664-1 requiring decisions by technical committees, or specification of options, or requiring activities of the manufacturer;
- Annex B provides an overview of such clauses of IEC 60664-4;
- Annex C provides an overview of such clauses of IEC 60664-5;
- Annex D amends the tables of Annex F of IEC 60664-1:2007 with rated impulse voltages for voltages line to neutral derived from nominal d.c. voltages up to and including 1 500 V.

The text of this application guide is based on the following documents:

Enquiry draft	Report on voting
109/82/DTR	109/83/RVC

Full information on the voting for the approval of this application guide can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

It has the status of a basic safety publication in accordance with IEC Guide 104.

A list of all the parts in the IEC 60664 series, published under the general title *Insulation coordination for equipment within low-voltage systems*, can be found on the IEC website.

The committee has decided that the contents of this amendment and the base publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

This application guide provides information relating to insulation coordination, as described in the IEC 60664 series, for the benefit of IEC technical committees and manufacturers. It covers general information for the dimensioning of clearances, creepage distances and solid insulation for equipment.

It aims to highlight the use and understanding of the IEC 60664 series when applied by technical committees and manufacturers.

Insulation coordination for equipment implies the assessment of the minimum necessary dimensioning for clearances, creepage distances and solid insulation in order to allow safe use of the equipment during its lifetime, taking into consideration the foreseeable environmental conditions.

The main parameters to be taken into account for the understanding of the IEC 60664 series include:

- the maximum voltage stress to be withstood in order to avoid flashover across clearances;
- the characteristics of the solid insulating material and the environmental conditions regarding tracking. IEC 60664-3 provides methods for improving the micro-environment at the creepage distance;
- the electrical field stress through solid insulation as it relates to the risk of partial discharge and dielectric loss causing a risk of breakdown due to excessive heating. In particular, technical committees and manufacturers should consider a partial discharge test if the maximum peak voltage across the insulation material exceeds 700 V and the peak value of the field strength exceeds 1 kV/mm. Due to the fact that both partial discharge phenomena and dielectric losses increase in importance with voltage frequency, a dedicated standard, IEC 60664-4, applies for frequencies higher than 30 kHz;

NOTE IEC 60664-4 provides information concerning clearances, creepage distances, solid insulation and testing for frequencies above 30 kHz.

- the long-term maximum voltage stress to be withstood in order to avoid tracking over the surface of the insulation material;
- flashover; besides tracking, this is increasingly important with reduction of creepage distance in the presence of high humidity. IEC 60664-5 introduces humidity levels classifying the effects of humidity on creepage distances equal to or less than 2 mm.

Other stresses such as heat, vibration, mechanical shocks, radiation, etc. may influence the performance of solid insulating materials in service. Technical committees and manufacturers should consider the risks related to these stresses when specifying conditions for testing equipment to be used under particular situations.

INSULATION COORDINATION FOR EQUIPMENT WITHIN LOW-VOLTAGE SYSTEMS –

Part 2-1: Application guide – Explanation of the application of the IEC 60664 series, dimensioning examples and dielectric testing

1 Scope

This part of IEC 60664, which is a technical report, serves as an application guide for technical committees and manufacturers specifying dimensioning requirements for products in accordance with the IEC 60664 series.

The significant items for consideration are as follows:

- a) nominal system voltage(s) or rated insulation voltage(s);
- b) overvoltage category of the products (OV cat.);
- c) any type of overvoltages;
- d) frequency of the voltage;
- e) characteristics of the solid insulating material;
- f) pollution degree and humidity levels.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60085:2007, *Electrical insulation – Thermal evaluation and designation*

IEC 60112:2003, *Method for the determination of the proof and the comparative tracking indices of solid insulating materials*
Amendment 1 (2009)

IEC 60216 (all parts), *Electrical insulating materials – Properties of thermal endurance*

IEC 60364-4-44:2007, *Low-voltage electrical installations – Part 4-44: Protection for safety – Protection against voltage disturbances and electromagnetic disturbances*

IEC 60664-1:2007, *Insulation coordination for equipment within low-voltage systems – Part 1: Principles, requirements and tests*

IEC 60664-3:2003, *Insulation coordination for equipment within low-voltage systems – Part 3: Use of coating, potting or moulding for protection against pollution*

IEC 60664-4:2005, *Insulation coordination for equipment within low-voltage systems – Part 4: Consideration of high-frequency voltage stress*

IEC 60664-5:2007, *Insulation coordination for equipment within low-voltage systems – Part 5: Comprehensive method for determining clearances and creepage distances equal to or less than 2 mm*

IEC 61140:2001, *Protection against electric shock – Common aspects for installation and equipment*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

NOTE All definitions can be found in the various parts of the IEC 60664 series, as indicated below.

3.1 approximately homogeneous field

for frequencies exceeding 30 kHz the field is considered to be approximately homogeneous when the radius of curvature of the conductive parts is equal or greater than 20 % of the clearance

[IEC 60664-4:2005, 3.1]

3.2 base material

insulating material upon which a conductive pattern may be formed

NOTE The base material may be rigid or flexible, or both. It may be a dielectric or an insulated metal sheet.
(IEC 60194, definition 40.1334)

[IEC 60664-3:2003, 3.1]

3.3 basic insulation

insulation of hazardous-live-parts which provides basic protection

NOTE The concept does not apply to insulation used exclusively for functional purposes.
(IEV 826-12-14)

[IEC 60664-1:2007, 3.17.2]

3.4 clearance

shortest distance in air between two conductive parts

[IEC 60664-1:2007, 3.2]

3.5 coating

insulating material such as varnish or dry film laid on the surface of the assembly

NOTE Coating and base material of a printed board form an insulating system that may have properties similar to solid insulation.

[IEC 60664-3:2003, 3.5]

3.6 conductor

single conductive path in a conductive pattern

(IEC 60194, definition 22.0251)

[IEC 60664-3:2003, 3.3]