

**Akustika. Ventilaatoritest ja muudest ventilatsiooniseadmetest kiirguva müratugevuse määramine. Šahtsisene meetod (ISO 5136:2003)**

Acoustics - Determination of sound power radiated into a duct by fans and other air moving devices - Induct method

## EESTI STANDARDI EESSÕNA

## NATIONAL FOREWORD

<p>Käesolev Eesti standard EVS-EN ISO 5136:2004 sisaldab Euroopa standardi EN ISO 5136:2003 ingliskeelset teksti.</p> <p>Käesolev dokument on jõustatud 23.11.2004 ja selle kohta on avaldatud teade Eesti standardiorganisatsiooni ametlikus väljaandes.</p> <p>Standard on kättesaadav Eesti standardiorganisatsioonist.</p>	<p>This Estonian standard EVS-EN ISO 5136:2004 consists of the English text of the European standard EN ISO 5136:2003.</p> <p>This document is endorsed on 23.11.2004 with the notification being published in the official publication of the Estonian national standardisation organisation.</p> <p>The standard is available from Estonian standardisation organisation.</p>
--	---

<p><b>Käsitlusala:</b> This International Standard specifies a method for testing ducted fans and other air-moving devices to determine the sound power radiated into an anechoically terminated duct on the inlet and/or outlet side of the equipment.</p>	<p><b>Scope:</b> This International Standard specifies a method for testing ducted fans and other air-moving devices to determine the sound power radiated into an anechoically terminated duct on the inlet and/or outlet side of the equipment.</p>
---	---

ICS 17.140.20, 23.120

Võtmesõnad:

English version

Acoustics

Determination of sound power radiated into a duct  
by fans and other air-moving devices

In-duct method  
(ISO 5136 : 2003)

Acoustique – Détermination de la  
puissance acoustique rayonnée dans  
un conduit par des ventilateurs et  
d'autres systèmes de ventilation –  
Méthode en conduit  
(ISO 5136 : 2003)

Akustik – Bestimmung der von Ven-  
tilatoren und anderen Strömungs-  
maschinen in Kanäle abgestrahlten  
Schalleistung – Kanalverfahren  
(ISO 5136 : 2003)

This European Standard was approved by CEN on 2003-03-11.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Management Centre or to any CEN member.

The European Standards exist in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, the Czech Republic, Denmark, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Luxembourg, Malta, the Netherlands, Norway, Portugal, Slovakia, Spain, Sweden, Switzerland, and the United Kingdom.

**CEN**

European Committee for Standardization  
Comité Européen de Normalisation  
Europäisches Komitee für Normung

Management Centre: rue de Stassart 36, B-1050 Brussels

## Foreword

International Standard

ISO 5136 : 2003 Acoustics – Determination of sound power radiated into a duct by fans and other air-moving devices – In-duct method,

which was prepared by ISO/TC 43 'Acoustics' of the International Organization for Standardization, has been adopted by Technical Committee CEN/TC 211 'Acoustics', the Secretariat of which is held by DS, as a European Standard.

This European Standard has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of the relevant EU Directive.

For relationship with this directive, see Annex ZB.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, and conflicting national standards withdrawn, by October 2003 at the latest.

In accordance with the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard:

Austria, Belgium, the Czech Republic, Denmark, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Luxembourg, Malta, the Netherlands, Norway, Portugal, Slovakia, Spain, Sweden, Switzerland, and the United Kingdom.

## Endorsement notice

The text of the International Standard ISO 5136 : 2003 was approved by CEN as a European Standard without any modification.

NOTE: Normative references to international publications are listed in Annex ZA (normative).

This document is a preview generated by EVS

## Contents

Page

Foreword .....	2
Introduction .....	4
<b>1 Scope .....</b>	<b>5</b>
<b>1.1 General .....</b>	<b>5</b>
<b>1.2 Types of sound source .....</b>	<b>5</b>
<b>2 Normative references .....</b>	<b>6</b>
<b>3 Terms, definitions and symbols .....</b>	<b>6</b>
<b>4 Uncertainty of the measurement method .....</b>	<b>11</b>
<b>5 Test facilities and instrumentation .....</b>	<b>12</b>
<b>5.1 General requirements .....</b>	<b>12</b>
<b>5.2 Duct specifications .....</b>	<b>13</b>
<b>5.3 Instrumentation .....</b>	<b>20</b>
<b>5.4 System calibration .....</b>	<b>23</b>
<b>6 Test arrangement .....</b>	<b>24</b>
<b>6.1 Sampling tube mounting .....</b>	<b>24</b>
<b>6.2 Microphone position .....</b>	<b>24</b>
<b>6.3 Operating condition control equipment .....</b>	<b>25</b>
<b>7 Test procedure .....</b>	<b>25</b>
<b>7.1 Operating conditions .....</b>	<b>25</b>
<b>7.2 Sound pressure level readings .....</b>	<b>25</b>
<b>7.3 Measurements with and without flow straightener on the outlet side .....</b>	<b>26</b>
<b>7.4 Inlet side measurements — Large fans: installation category D (according to ISO 5801:1997) .....</b>	<b>26</b>
<b>8 Calculations .....</b>	<b>27</b>
<b>8.1 Average sound pressure level .....</b>	<b>27</b>
<b>8.2 Sound power level .....</b>	<b>27</b>
<b>9 Information to be recorded .....</b>	<b>28</b>
<b>10 Information to be reported .....</b>	<b>28</b>
<b>Annex A (normative) Determination of the combined mean flow velocity and modal correction <math>C_{3,4}</math> .....</b>	<b>29</b>
<b>Annex B (normative) Determination of the signal-to-noise ratio of sound vs. turbulent pressure fluctuation in the test duct .....</b>	<b>35</b>
<b>Annex C (normative) Computational procedures for calculating the A-weighted sound power level from one-third-octave-band sound power levels .....</b>	<b>38</b>
<b>Annex D (informative) Example of calculation of <math>C_{3,4}</math> for a given duct diameter and mean flow velocity .....</b>	<b>39</b>
<b>Annex E (informative) Guidelines for the design and construction of an anechoic termination .....</b>	<b>41</b>
<b>Annex F (informative) Evaluation of performance of anechoic terminations .....</b>	<b>50</b>
<b>Annex G (informative) Sampling tube information .....</b>	<b>52</b>
<b>Annex H (informative) Test method for small ducted fans .....</b>	<b>56</b>
<b>Annex I (informative) Test method for large ducted fans .....</b>	<b>60</b>
<b>Annex J (informative) Measurement of the swirl component .....</b>	<b>67</b>
<b>Bibliography .....</b>	<b>68</b>

## Introduction

This International Standard describes a procedure for the measurement of sound pressure levels in the inlet or outlet ducts of a fan and a method to use these sound pressure levels to calculate the sound power levels radiated by the fan to the duct system.

Annex A lists values of coefficients for the determination of the combined mean flow velocity and modal correction. Annex B specifies two procedures for the determination of the signal-to-noise ratio of sound versus turbulence. A computational procedure for the calculation of the A-weighted sound power level from one-third-octave band levels is given in Annex C. Annex D shows an example of the calculation of the combined mean flow velocity and modal correction.

The sound power radiated into a duct by a fan or other air-moving device depends to some extent on the type of duct, characterized by its acoustical impedance. For a measurement method, the test duct has, therefore, to be clearly specified. In this International Standard, the test duct is of circular cross-section and terminated anechoically. Details of typical anechoic terminations are given in Annex E. The sound power obtained under these special conditions is a representative value for actual applications, as the anechoic termination forms an impedance about midway between the higher and lower impedances found in practice. The sound power radiated in actual applications can, in theory, be estimated from data on air-moving devices and duct impedances. Since this information is at present incomplete, these effects are not usually considered in acoustical calculations.

In order to suppress the turbulent pressure fluctuations at the microphone, the use of a long cylindrical windscreen ("sampling tube") is preferred. The microphone, with the sampling tube, is mounted at a radial position such that the sound pressure is well related to the sound power by the plane wave formula to an acceptable extent, even in the frequency range in which higher-order acoustic modes are possible.

The uncertainty of measurement (see Clause 4) is given in terms of the standard deviation to be expected if the measurements were repeated in many different laboratories.

The procedures for measuring the operating conditions (performance measurements) are not specified in detail in this International Standard. The operating conditions are specified in ISO 5801.

This International Standard is one of a series specifying different methods for determining the sound power levels of fans and other air-moving devices.

In general, the sound powers radiated from a fan inlet or outlet into free space and into a duct are different because of the reflection of sound energy at the fan inlet or outlet plane when there is no connected duct. The in-duct method according to this International Standard is suitable for determining the sound power radiated into a duct by a fan inlet or outlet. The sound power radiated into free space by a fan inlet or outlet should be determined using the a reverberation room method (ISO 3741, ISO 3743), a free-field method (ISO 3744, ISO 3745, ISO 3746) or a sound intensity method (ISO 9614).

## 1 Scope

### 1.1 General

This International Standard specifies a method for testing ducted fans and other air-moving devices to determine the sound power radiated into an anechoically terminated duct on the inlet and/or outlet side of the equipment.

NOTE 1 For the sake of brevity, wherever the term “fan” occurs in the text, it means “fan or other air-moving device”.

The method is applicable to fans which emit steady, broad-band, narrow-band and discrete-frequency sound and to air temperatures between  $-50\text{ °C}$  and  $+70\text{ °C}$ . The test duct diameter range is from 0,15 m to 2 m. Test methods for small ( $d < 0,15\text{ m}$ ) and large ( $d > 2\text{ m}$ ) test ducts are described in the informative Annexes H and I, respectively.

The maximum mean flow velocity at the microphone head for which the method is suitable depends on the type of microphone shield used, and is as follows:

- foam ball 15 m/s;
- nose cone 20 m/s;
- sampling tube 40 m/s.

Above these values the suppression of turbulent pressure fluctuations by the microphone shield (see 3.9) may be insufficient.

It is expected that sound power tests will be conducted in conjunction with airflow performance tests in accordance with ISO 5801. The ducting arrangement will therefore normally incorporate a “star” type flow straightener on the outlet side of the fan which will minimize swirl (see 7.3). Where it is permissible to delete the straightener as, for example, with large fans to installation category C according to ISO 5801:1997, the method is limited to a swirl angle of  $15^\circ$ . (An example of a method for determining the angle of swirl is given in Annex J.)

NOTE 2 The installation categories defined in ISO 5801 imply that the fan is either ducted on the outlet side only (category B), on the inlet side only (category C) or on both sides (category D).

### 1.2 Types of sound source

The method described in this International Standard is applicable to a sound source in which a fan is connected to ducts on at least one side. It is also applicable to other fan/attenuator combinations or equipment incorporating fans which can be considered as “black boxes”.

Examples of fans and other equipment covered by this International Standard are

- ducted centrifugal fans,
- ducted axial flow fans,

- ducted mixed-flow fans,
- ducted air-handling units,
- ducted dust-collection units,
- ducted air-conditioning units, and
- ducted furnaces.

This International Standard is also applicable to other aerodynamic sources such as boxes, dampers and throttle devices provided that a quiet air flow delivered by an auxiliary fan is available, and the signal-to-noise ratio of sound pressures to turbulent pressure fluctuations in the test duct is at least 6 dB (see 7.2.1).

An alternative method to determine the sound power level of the flow-generated noise of such aerodynamic sound sources, which does not require the measurement of sound pressure in a flow environment, is described in ISO 7235. The method was originally devised for the determination of the flow noise level of ducted silencers. The sound power is determined in a reverberation room connected to the test duct via a transition element.

In the case of ducted fans with closely coupled attenuators, the signal-to-noise ratio of sound pressures to turbulent pressures may be insufficient when using the in-duct method. Therefore the method described in ISO 7235 is recommended for such fan/attenuator combinations.

This International Standard is not applicable to non-ducted fans or equipment.

## 2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 266, *Acoustics — Preferred frequencies*

ISO 5801:1997, *Industrial fans — Performance testing using standardized airways*

IEC 60651:2001, *Sound level meters*

IEC 60942:1997, *Electroacoustics — Sound calibrators*

IEC 61260, *Electroacoustics — Octave-band and fractional-octave-band filters*

## 3 Terms, definitions and symbols

For the purpose of this document, the following terms and definitions apply. The symbols are given in Table 1.

### 3.1

#### fan inlet area

$S_{f1}$

surface plane bounded by the upstream extremity of the fan

NOTE 1 The inlet area is, by convention, taken as the gross area in the inlet plane inside the casing. No deduction is made for motors, fairings or other obstructions.