

**Tööstuslikud ventilaatorid. Telgventilaatorite  
töökarakteristikute katsetamine standardiseeritud  
õhutunnelites**

Industrial fans - Performance testing using  
standardized airways

## EESTI STANDARDI EESSÕNA

## NATIONAL FOREWORD

|  |   |
|--|---|
| <p>Käesolev Eesti standard EVS-EN ISO 5801:2008 sisaldab Euroopa standardi EN ISO 5801:2008 ingliskeelset teksti.</p> <p>Standard on kinnitatud Eesti Standardikeskuse 15.12.2008 käskkirjaga ja jõustub sellekohase teate avaldamisel EVS Teatajas.</p> <p>Euroopa standardimisorganisatsioonide poolt rahvuslikele liikmetele Euroopa standardi teksti kättesaadavaks tegemise kuupäev on 22.10.2008.</p> <p>Standard on kättesaadav Eesti standardiorganisatsioonist.</p> | <p>This Estonian standard EVS-EN ISO 5801:2008 consists of the English text of the European standard EN ISO 5801:2008.</p> <p>This standard is ratified with the order of Estonian Centre for Standardisation dated 15.12.2008 and is endorsed with the notification published in the official bulletin of the Estonian national standardisation organisation.</p> <p>Date of Availability of the European standard text 22.10.2008.</p> <p>The standard is available from Estonian standardisation organisation.</p> |
|--|---|

ICS 23.120

Võtmesõnad:

### Standardite reprodutseerimis- ja levitamiseõigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonilisse süsteemi või edastamine ükskõik millises vormis või millisel teel on keelatud ilma Eesti Standardikeskuse poolt antud kirjaliku loata.

Kui Teil on küsimusi standardite autorikaitse kohta, palun võtke ühendust Eesti Standardikeskusega:  
Aru 10 Tallinn 10317 Eesti; [www.evs.ee](http://www.evs.ee); Telefon: 605 5050; E-post: [info@evs.ee](mailto:info@evs.ee)

ICS 23.120

English Version

## Industrial fans - Performance testing using standardized airways (ISO 5801:2007 including Cor 1:2008)

Ventilateurs industriels - Essais aérauliques sur circuits  
normalisés (ISO 5801:2007, Cor 1:2008 inclus)

This European Standard was approved by CEN on 2 October 2008.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION  
COMITÉ EUROPÉEN DE NORMALISATION  
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: rue de Stassart, 36 B-1050 Brussels

## Foreword

The text of ISO 5801:2007 including Cor 1:2008 has been prepared by Technical Committee ISO/TC 117 "Industrial fans" of the International Organization for Standardization (ISO) and has been taken over as EN ISO 5801:2008 by Technical Committee CEN/TC 156 "Ventilation for buildings" the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by April 2009, and conflicting national standards shall be withdrawn at the latest by April 2009.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

### Endorsement notice

The text of ISO 5801:2007 including Cor 1:2008 has been approved by CEN as a EN ISO 5801:2008 without any modification.

# Contents

Page

|  |      |
|--|------|
| Foreword.....  | vii  |
| Introduction.....  | viii |
| 1 Scope.....   | 1    |
| 2 Normative references.....  | 1    |
| 3 Terms and definitions.....   | 1    |
| 4 Symbols and units.....   | 16   |
| 4.1 Symbols.....   | 16   |
| 4.2 Subscripts.....  | 19   |
| 5 General.....   | 19   |
| 6 Instruments for pressure measurement.....                            | 20   |
| 6.1 Barometers.....  | 20   |
| 6.2 Manometers.....  | 21   |
| 6.3 Damping of manometers.....   | 21   |
| 6.4 Checking of manometers.....  | 21   |
| 6.5 Position of manometers.....  | 22   |
| 7 Determination of average pressure in an airway.....                  | 22   |
| 7.1 Methods of measurement.....  | 22   |
| 7.2 Use of wall tappings.....  | 22   |
| 7.3 Construction of tappings.....                                      | 22   |
| 7.4 Position and connections.....                                      | 23   |
| 7.5 Checks for compliance.....   | 23   |
| 7.6 Use of Pitot-static tube.....                                      | 23   |
| 8 Measurement of temperature.....                                      | 24   |
| 8.1 Thermometers.....  | 24   |
| 8.2 Thermometer location.....  | 24   |
| 8.3 Humidity.....  | 24   |
| 9 Measurement of rotational speed.....                                 | 25   |
| 9.1 Fan shaft speed.....   | 25   |
| 9.2 Acceptable instruments.....  | 25   |
| 10 Determination of power input.....                                   | 25   |
| 10.1 Measurement accuracy.....   | 25   |
| 10.2 Fan shaft power.....  | 25   |
| 10.3 Determination of fan shaft power by electrical measurement.....   | 25   |
| 10.4 Impeller power.....   | 26   |
| 10.5 Transmission systems.....   | 26   |
| 11 Measurement of dimensions and determination of areas.....           | 26   |
| 11.1 Flow-measurement devices.....                                     | 26   |
| 11.2 Tolerance on dimensions.....                                      | 26   |
| 11.3 Determination of cross-sectional area.....                        | 27   |
| 12 Determination of air density, humid gas constant and viscosity..... | 27   |
| 12.1 Density of air in the test enclosure at section $x$ .....         | 27   |
| 12.2 Determination of vapour pressure.....                             | 28   |
| 12.3 Determination of air viscosity.....                               | 30   |
| 13 Determination of flow rate.....                                     | 31   |
| 13.1 General.....  | 31   |

|      |   |    |
|------|---|----|
| 13.2 | In-line flowmeters (standard primary devices).....  | 31 |
| 13.3 | Traverse methods .....  | 32 |
| 14   | Calculation of test results .....   | 34 |
| 14.1 | General .....   | 34 |
| 14.2 | Units .....   | 34 |
| 14.3 | Temperature.....  | 34 |
| 14.4 | Mach number and reference conditions.....   | 36 |
| 14.5 | Fan pressure.....   | 40 |
| 14.6 | Calculation of stagnation pressure at a reference section of the fan from gauge pressure,<br>$p_{ex}$ measured at a section $x$ of the test duct..... | 43 |
| 14.7 | Inlet volume flow rate .....  | 44 |
| 14.8 | Fan air power and efficiency.....   | 44 |
| 15   | Rules for conversion of test results.....   | 52 |
| 15.1 | Laws on fan similarity.....   | 52 |
| 15.2 | Conversion rules.....   | 54 |
| 16   | Fan characteristic curves.....  | 57 |
| 16.1 | General.....  | 57 |
| 16.2 | Methods of plotting.....  | 58 |
| 16.3 | Characteristic curves at constant speed.....  | 58 |
| 16.4 | Characteristic curves at inherent speed.....  | 58 |
| 16.5 | Characteristic curves for adjustable-duty fan.....  | 59 |
| 16.6 | Complete fan characteristic curve .....   | 60 |
| 16.7 | Test for a specified duty.....  | 61 |
| 17   | Uncertainty analysis .....  | 62 |
| 17.1 | Principle .....   | 62 |
| 17.2 | Pre-test and post-test analysis .....   | 62 |
| 17.3 | Analysis procedure.....   | 62 |
| 17.4 | Propagation of uncertainties .....  | 62 |
| 17.5 | Reporting uncertainties.....  | 63 |
| 17.6 | Maximum allowable uncertainties measurement .....   | 63 |
| 17.7 | Maximum allowable uncertainty of results.....   | 64 |
| 18   | Selection of test method .....  | 65 |
| 18.1 | Classification .....  | 65 |
| 18.2 | Installation categories .....   | 65 |
| 18.3 | Test report.....  | 65 |
| 18.4 | User installations .....  | 66 |
| 18.5 | Alternative methods.....  | 66 |
| 18.6 | Duct simulation .....   | 66 |
| 19   | Installation of fan and test airways .....  | 66 |
| 19.1 | Inlets and outlets.....   | 66 |
| 19.2 | Airways.....  | 66 |
| 19.3 | Test enclosure .....  | 67 |
| 19.4 | Matching fan and airway .....   | 67 |
| 19.5 | Outlet area.....  | 67 |
| 20   | Carrying out the test .....   | 67 |
| 20.1 | Working fluid .....   | 67 |
| 20.2 | Rotational speed .....  | 67 |
| 20.3 | Steady operation .....  | 67 |
| 20.4 | Ambient conditions.....   | 68 |
| 20.5 | Pressure readings.....  | 68 |
| 20.6 | Tests for a specified duty.....   | 68 |
| 20.7 | Tests for a fan characteristic curve .....  | 68 |
| 20.8 | Operating range .....   | 68 |
| 21   | Determination of flow rate.....   | 68 |
| 21.1 | Multiple nozzle.....  | 68 |
| 21.2 | Conical or bellmouth inlet.....   | 68 |

|      |   |     |
|------|---|-----|
| 21.3 | Orifice plate .....   | 68  |
| 21.4 | Pilot-static tube traverse (see ISO 3966 and ISO 5221) .....                    | 69  |
| 22   | Determination of flow rate using multiple nozzles .....                         | 69  |
| 22.1 | Installation .....  | 69  |
| 22.2 | Geometric form .....  | 69  |
| 22.3 | Inlet zone .....  | 70  |
| 22.4 | Multiple-nozzle characteristics .....   | 70  |
| 22.5 | Uncertainty .....   | 72  |
| 23   | Determination of flow rate using a conical or bellmouth inlet .....             | 73  |
| 23.1 | Geometric form .....  | 73  |
| 23.2 | Screen loading .....  | 74  |
| 23.3 | Inlet zone .....  | 75  |
| 23.4 | Conical inlet performance .....   | 75  |
| 23.5 | Bellmouth inlet performance .....   | 75  |
| 23.6 | Uncertainties .....   | 77  |
| 24   | Determination of flow rate using an orifice plate .....                         | 77  |
| 24.1 | Installation .....  | 77  |
| 24.2 | Orifice plate .....   | 77  |
| 24.3 | Ducts .....   | 81  |
| 24.4 | Pressure tapplings .....  | 81  |
| 24.5 | Calculation of mass flow rate .....   | 81  |
| 24.6 | Reynolds number .....   | 82  |
| 24.7 | In-duct orifice with $D$ and $D/2$ taps [see Figure 20 a) and ISO 5167-1] ..... | 82  |
| 24.8 | Outlet orifice with wall tapplings [see Figure 20 c) and e)] .....              | 86  |
| 25   | Determination of flow rate using a Pitot-static tube traverse .....             | 88  |
| 25.1 | General .....   | 88  |
| 25.2 | Pitot-static tube .....   | 88  |
| 25.3 | Limits of air velocity .....  | 93  |
| 25.4 | Location of measurement points .....  | 93  |
| 25.5 | Determination of flow rate .....  | 94  |
| 25.6 | Flow rate coefficient .....   | 94  |
| 25.7 | Uncertainty of measurement .....  | 95  |
| 26   | Installation and setup categories .....   | 95  |
| 26.1 | Category A: free inlet and free outlet .....                                    | 95  |
| 26.2 | Category B: free inlet and ducted outlet .....                                  | 95  |
| 26.3 | Category C: ducted inlet and free outlet .....                                  | 96  |
| 26.4 | Category D: ducted inlet and ducted outlet .....                                | 96  |
| 26.5 | Test installation type .....  | 96  |
| 27   | Flow straighteners .....  | 96  |
| 27.1 | Types of straightener .....   | 97  |
| 27.2 | Rules for use of a straightener .....   | 98  |
| 28   | Common-segment airways for ducted fan installations .....                       | 99  |
| 28.1 | Common segments .....   | 99  |
| 28.2 | Common segment at fan outlet .....  | 99  |
| 28.3 | Common segment at fan inlet .....   | 101 |
| 28.4 | Outlet duct simulation .....  | 103 |
| 28.5 | Inlet duct simulation .....   | 103 |
| 28.6 | Loss allowances for standardized airways .....                                  | 104 |
| 29   | Standardized test chambers .....  | 107 |
| 29.1 | Test chamber .....  | 107 |
| 29.2 | Variable supply and exhaust systems .....                                       | 112 |
| 29.3 | Standardized inlet test chambers .....  | 112 |
| 29.4 | Standardized outlet test chambers .....   | 115 |
| 30   | Standard methods with test chambers — Category A installations .....            | 118 |
| 30.1 | Types of fan setup .....  | 118 |

|                     |   |            |
|---------------------|---|------------|
| <b>30.2</b>         | <b>Inlet-side test chambers</b> .....   | <b>118</b> |
| <b>30.3</b>         | <b>Outlet-side test chambers</b> .....  | <b>131</b> |
| <b>31</b>           | <b>Standard test methods with outlet-side test ducts — Category B installations</b> .....   | <b>136</b> |
| <b>31.1</b>         | <b>Types of fan setup</b> .....   | <b>136</b> |
| <b>31.2</b>         | <b>Outlet-side test ducts with antiwhirl device</b> .....   | <b>137</b> |
| <b>31.3</b>         | <b>Outlet chamber test ducts without antiwhirl device</b> .....   | <b>149</b> |
| <b>32</b>           | <b>Standard test methods with inlet-side test ducts or chambers — Category C installations</b> ....   | <b>156</b> |
| <b>32.1</b>         | <b>Types of fan setup</b> .....   | <b>156</b> |
| <b>32.2</b>         | <b>Inlet-side test ducts</b> .....  | <b>157</b> |
| <b>32.3</b>         | <b>Inlet-side test chambers</b> .....   | <b>170</b> |
| <b>33</b>           | <b>Standard methods with inlet- and outlet-side test ducts — Category D installations</b> .....   | <b>180</b> |
| <b>33.1</b>         | <b>Types of fan setup</b> .....   | <b>180</b> |
| <b>33.2</b>         | <b>Installation category B with outlet antiwhirl device and with an additional inlet duct or inlet-duct simulation</b> .....                              | <b>184</b> |
| <b>33.3</b>         | <b>Installation category B without outlet antiwhirl device nor common segment, modified with addition of an inlet duct or inlet-duct simulation</b> ..... | <b>190</b> |
| <b>33.4</b>         | <b>Installation category C with common inlet duct, modified with the addition of an outlet common segment with antiwhirl device</b> .....                 | <b>193</b> |
| <b>33.5</b>         | <b>Installation category C, modified with the addition of an outlet-duct simulation without antiwhirl device</b> .....                                    | <b>197</b> |
| <b>Annex A</b>      | <b>(normative) Fan pressure and fan installation category</b> .....   | <b>205</b> |
| <b>Annex B</b>      | <b>(normative) Fan-powered roof exhaust ventilators</b> .....   | <b>209</b> |
| <b>Annex C</b>      | <b>(informative) Chamber leakage test procedure</b> .....   | <b>211</b> |
| <b>Annex D</b>      | <b>(informative) Fan outlet elbow in the case of a non-horizontal discharge axis</b> .....  | <b>217</b> |
| <b>Annex E</b>      | <b>(informative) Electrical input power consumed by a fan installation</b> .....  | <b>220</b> |
| <b>Annex F</b>      | <b>(informative) Preferred methods of performance testing</b> .....   | <b>227</b> |
| <b>Bibliography</b> | .....   | <b>228</b> |

## Introduction

This International Standard is the result of almost 30 years of discussion, comparative testing and detailed analyses by leading specialists from the fan industry and research organizations throughout the world.

It was demonstrated many years ago that the codes for fan performance testing established in different countries do not always lead to the same results.

The need for an International Standard has been evident for some time and Technical Committee ISO/TC 117 started its work in 1963. Important progress has been achieved over the years and, although the International Standard itself was not yet published, the successive revisions of various national standards led to much better agreement among them.

It has now become possible to complete this International Standard by agreement on certain essential points. It must be borne in mind that the test equipment, especially for large fans, is very expensive and it was necessary to include in this International Standard many setups from various national codes in order to authorize their future use. This explains the sheer volume of this document.

Essential features of this International Standard are as follows:

### a) Categories of installation

Since the connection of a duct to a fan outlet and/or inlet modifies its performance, it has been agreed that four standard installation categories should be recognized (see 18.2).

A fan adaptable to more than one installation category will have more than one standardized performance characteristic. Users should select the installation category closest to their application.

### b) Common parts

The differences obtained by testing the same fan according to various test codes depend chiefly on the flow pattern at the fan outlet and, while often minor, can be of substantial significance. There is general agreement that it is essential that all standardized test airways to be used with fans have portions in common adjacent to the fan inlet and/or outlet sufficient to ensure consistent determination of fan pressure.

Geometric variations of these common segments are strictly limited.

However, conventional agreement has been achieved for some particular situations:

- 1) For fans where the outlet swirl is less than  $15^\circ$ , i.e. centrifugal, cross-flow or vane-axial fans, it is possible to use a simplified outlet duct without straightener when discharging to the atmosphere or to a measuring chamber. If there is any doubt about the degree of swirl, then a test should be performed to establish how much is present.
- 2) For large fans (outlet diameter exceeding 800 mm), it may be difficult to carry out the tests with standardized common airways at the outlet including a straightener. In this case, by mutual agreement between the parties concerned, the fan performance may be measured using a duct of length  $3D$  on the outlet side. Results obtained in this way may differ to some extent from those obtained using the normal category D installation, especially if the fan produces a large swirl. Establishment of a possible value of differences, is still a subject of research.

**c) Calculations**

Fan pressure is defined as the difference between the stagnation pressure at the outlet of the fan and the stagnation pressure at the inlet of the fan. The compressibility of air must be taken into account when high accuracy is required. However, simplified methods may be used when the reference Mach number does not exceed 0,15.

A method for calculating the stagnation pressure and the fluid or static pressure in a reference section of the fan, which stemmed from the work of the ad hoc group of Subcommittee 1 of ISO/TC 117, is given in Annex C.

Three methods are proposed for calculation of the fan power output and efficiency. All three methods give very similar results (difference of a few parts per thousand for pressure ratios equal to 1,3).

**d) Flow rate measurement**

Determination of flow rate has been completely separated from the determination of fan pressure. A number of standardized methods may be used.

# Industrial fans — Performance testing using standardized airways

## 1 Scope

This International Standard deals with the determination of the performance of industrial fans of all types except those designed solely for air circulation, e.g. ceiling fans and table fans.

Estimates of uncertainty of measurement are provided and rules for the conversion, within specified limits, of test results for changes in speed, gas handled and, in the case of model tests, size, are given.

## 2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 3966, *Measurement of fluid flow in closed conduits — Velocity area method using Pitot static tubes*

ISO 5167-1, *Measurement of fluid flow by means of pressure differential devices inserted in circular cross-section conduits running full — Part 1: General principles and requirements*

ISO 5168, *Measurement of fluid flow — Procedures for the evaluation of uncertainties*

ISO 5221, *Air distribution and air diffusion — Rules to methods of measuring air flow rate in an air handling duct*

IEC 60034-2:1972, *Rotating electrical machines — Part 2: Methods for determining losses and efficiency of rotating electrical machinery from tests (excluding machines for traction vehicles)*

IEC 60051-2, *Direct acting indicating analogue electrical measuring instruments and their accessories — Part 2: Special requirements for ammeters and voltmeters*

IEC 60051-3, *Direct acting indicating analogue electrical measuring instruments and their accessories — Part 3: Special requirements for wattmeters and varmeters*

IEC 60051-4, *Direct acting indicating analogue electrical measuring instruments and their accessories — Part 4: Special requirements for frequency meters*

## 3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 5168 and the following apply.

NOTE All the symbols used in this International Standard are listed with their units in Clause 4.