

**AUTOMAATNE
TULEKAHJUSIGNALISATSIOONISÜSTEEM. OSA 29:
MITME SENSORIGA TULEKAHJUANDURID.
KOMBINEERITUD SUITSU- JA
TEMPERATUURISENSORIGA PUNKTIANDURID**

Fire detection and fire alarm systems - Part 29: Multi-sensor fire detectors - Point detectors using a combination of smoke and heat sensors

EESTI STANDARDI EESSÕNA**NATIONAL FOREWORD**

See Eesti standard EVS-EN 54-29:2015 sisaldab Euroopa standardi EN 54-29:2015 ingliskeelset teksti.	This Estonian standard EVS-EN 54-29:2015 consists of the English text of the European standard EN 54-29:2015.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 08.04.2015.	Date of Availability of the European standard is 08.04.2015.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 13.220.20

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:
Aru 10, 10317 Tallinn, Eesti; koduleht www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:

Aru 10, 10317 Tallinn, Estonia; homepage www.evs.ee; phone +372 605 5050; e-mail info@evs.ee

ICS 13.220.20

English Version

Fire detection and fire alarm systems - Part 29: Multi-sensor fire detectors - Point detectors using a combination of smoke and heat sensors

Systèmes de détection et d'alarme incendie - Partie 29 :
DéTECTEURS d'incendie multi-capteurs - DéTECTEURS ponctuels
utilisant une combinaison de capteurs de fumée et de
chaleur

Brandmeldeanlagen - Teil 29: Mehrfachsensor-
Brandmelder - Punktförmige Melder mit kombinierten
Rauch- und Wärmesensoren

This European Standard was approved by CEN on 15 February 2015.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents

Page

Foreword.....	6
Introduction	8
1 Scope	9
2 Normative references	9
3 Terms and definitions	10
4 Requirements	10
4.1 General.....	10
4.2 Nominal activation conditions/sensitivity	10
4.2.1 Individual alarm indication	10
4.2.2 Response to slowly developing fires.....	10
4.2.3 Repeatability of smoke response.....	11
4.2.4 Directional dependence of smoke response	11
4.2.5 Directional dependence of heat response	11
4.2.6 Lower limit of heat response	11
4.2.7 Reproducibility of smoke response.....	11
4.2.8 Reproducibility of heat response.....	11
4.2.9 Air movement	11
4.2.10 Dazzling	11
4.3 Operational reliability	11
4.3.1 Connection of ancillary devices.....	11
4.3.2 Monitoring of detachable detectors.....	11
4.3.3 Manufacturer's adjustments	12
4.3.4 On-site adjustment of response behaviour	12
4.3.5 Protection against the ingress of foreign bodies.....	12
4.3.6 Software controlled detectors	12
4.4 Tolerance to supply parameters	13
4.4.1 Variation in supply parameters	13
4.5 Performance parameters under fire conditions	14
4.5.1 Fire sensitivity.....	14
4.6 Durability of nominal activation conditions/sensitivity	14
4.6.1 Temperature resistance	14
4.6.2 Humidity resistance.....	14
4.6.3 Shock and vibration resistance.....	14
4.6.4 Electrical stability	15
4.6.5 Resistance to chemical agents	15
5 Test and assessment and sampling methods	15
5.1 General.....	15
5.1.1 Atmospheric conditions for tests	15
5.1.2 Operating conditions for tests	15
5.1.3 Mounting arrangements	15
5.1.4 Tolerances	16
5.1.5 Measurement of smoke response value	16
5.1.6 Measurement of heat response value	16
5.1.7 Provision for tests	17
5.1.8 Test schedule	17
5.2 Nominal activation conditions/sensitivity	18
5.2.1 Individual alarm indication	18

5.2.2	Response to slowly developing fires	19
5.2.3	Repeatability of smoke response	19
5.2.4	Directional dependence of smoke response	19
5.2.5	Directional dependence of heat response	20
5.2.6	Lower limit of heat sensitivity	20
5.2.7	Reproducibility of smoke response	21
5.2.8	Reproducibility of heat response	21
5.2.9	Air movement.....	22
5.2.10	Dazzling	22
5.3	Operational reliability.....	23
5.3.1	Connection of ancillary devices	23
5.3.2	Monitoring of detachable detectors	23
5.3.3	Manufacturer's adjustments.....	23
5.3.4	On-site adjustment of behaviour	23
5.3.5	Protection against the ingress of foreign bodies	23
5.3.6	Software controlled devices.....	23
5.4	Tolerance to supply parameters	24
5.4.1	Variation in supply parameters.....	24
5.5	Performance parameters under fire conditions	24
5.5.1	Fire sensitivity	24
5.6	Durability of nominal activation conditions/sensitivity.....	26
5.6.1	Temperature resistance	26
5.6.2	Humidity resistance	28
5.6.3	Shock and vibration resistance	30
5.6.4	Electrical stability.....	34
5.6.5	Resistance to chemical agents	35
6	Assessment and verification of constancy of performance (AVCP)	37
6.1	General	37
6.2	Type testing	37
6.2.1	General	37
6.2.2	Test samples, testing and compliance criteria	38
6.2.3	Test reports.....	38
6.3	Factory production control (FPC).....	38
6.3.1	General	38
6.3.2	Requirements.....	39
6.3.3	Product specific requirements.....	41
6.3.4	Initial inspection of factory and FPC	42
6.3.5	Continuous surveillance of FPC	42
6.3.6	Procedure for modifications	42
6.3.7	One-off products, pre-production products, (e.g. prototypes) and products produced in very low quantities	43
7	Classification and designation	43
8	Marking, Labelling and Packaging	44
Annex A	(normative) Smoke tunnel for smoke response values	45
Annex B	(normative) Test aerosol for smoke response value measurements	46
Annex C	(normative) Smoke measuring instruments	47
C.1	Obscuration meter.....	47
C.2	Measuring ionization chamber (MIC).....	47
Annex D	(normative) Heat tunnel for heat response value	51
Annex E	(normative) Apparatus for dazzling test	52
Annex F	(informative) Apparatus for impact test.....	54

Annex G (normative) Fire test room	56
Annex H (normative) Open wood fire (TF1)	58
H.1 Fuel	58
H.2 Arrangement	58
H.3 Method of ignition	58
H.4 Variables	58
H.5 End-of-test condition	58
H.6 Test validity criteria	59
Annex I (normative) Smouldering (pyrolysis) wood fire (TF2)	61
I.1 Fuel	61
I.2 Hotplate	61
I.3 Arrangement	61
I.4 Heating rate	61
I.5 End-of-test condition	61
I.6 Test validity criteria	61
Annex J (normative) Glowing smouldering cotton fire (TF3)	65
J.1 Fuel	65
J.2 Arrangement	65
J.3 Ignition	66
J.4 End-of-test condition	67
J.5 Test validity criteria	67
Annex K (normative) Open plastics (polyurethane) fire (TF4)	69
K.1 Fuel	69
K.2 Conditioning	69
K.3 Arrangement	69
K.4 Ignition	69
K.5 Method of ignition	69
K.6 End-of-test condition	69
K.7 Test validity criteria	69
Annex L (normative) Liquid (heptane) fire (TF5)	71
L.1 Fuel	71
L.2 Arrangement	71
L.3 Ignition	71
L.4 End-of-test condition	71
L.5 Test validity criteria	71
Annex M (normative) Low temperature black smoke (decalene) liquid fire (TF8)	73
M.1 Fuel	73
M.2 Arrangement	73

M.3	Ignition	73
M.4	End-of-test condition	73
M.5	Test validity criteria	73
Annex N	(informative) Information concerning the construction of the smoke tunnel	75
Annex O	(informative) Construction of the heat tunnel	77
Annex P	(informative) Information concerning test procedures and requirements for the response to slowly developing fires	80
Annex Q	(informative) Information concerning the construction of the measuring ionization chamber	84
Annex ZA	(informative) Clauses of this European Standard addressing the provisions of the EU Construction Products Regulation	86
ZA.1	Scope and relevant characteristics	86
ZA.2	Procedure for assessment and verification of constancy of performance (AVCP) of point detectors using a combination of smoke and heat sensors	88
ZA.3	CE marking and labelling	92
	Bibliography	96

Foreword

This document (EN 54-29:2015) has been prepared by Technical Committee CEN/TC 72 "Fire detection and fire alarm systems", the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by October 2015, and conflicting national standards shall be withdrawn at the latest by January 2017.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports the basic requirements of Regulation (EU) 305/2011.

For relationship with EU Regulations, see informative Annex ZA which is an integral part of this document.

EN 54, *Fire detection and fire alarm systems*, consists of the following parts:

- *Part 1: Introduction*
- *Part 2: Control and indicating equipment*
- *Part 3: Fire alarm devices – Sounders*
- *Part 4: Power supply equipment*
- *Part 5: Heat detectors – Point detectors*
- *Part 7: Smoke detectors – Point detectors using scattered light, transmitted light or ionization*
- *Part 10: Flame detector – Point detectors*
- *Part 11: Manual call points*
- *Part 12: Smoke detectors – Line detector using an optical light beam*
- *Part 13: Compatibility assessment of system components*
- *Part 14: Technical Specification: Guidelines for planning, design, installation, commissioning, use and maintenance*
- *Part 16: Voice alarm control and indicating equipment*
- *Part 17: Short circuit isolators*
- *Part 18: Input/output devices*
- *Part 20: Aspirating smoke detectors*
- *Part 21: Alarm transmission and fault warning routing equipment*
- *Part 22: Resettable Line-type heat detectors*
- *Part 23: Fire alarm devices – Visual alarms*

- *Part 24: Components of voice alarm systems – Loudspeakers*
- *Part 25: Components using radio links and system requirements*
- *Part 26: Point fire detectors using carbon monoxide sensors*
- *Part 27: Duct smoke detectors*
- *Part 28: Non-resettable (digital) line type heat detectors*
- *Part 29: Point detectors using a combination of smoke and heat sensors*
- *Part 30: Point detectors using a combination of carbon monoxide and heat sensors*
- *Part 31: Point detectors using a combination of smoke, carbon monoxide and optionally heat sensors*
- *Part 32: Guidelines for the planning, design, installation, commissioning, use and maintenance of voice alarm systems*

NOTE This list includes standards that are in preparation and other standards may be added. For current status of published standards refer to <http://www.cen.eu/Pages/default.aspx>.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

Introduction

Multi-sensor fire detectors combining smoke and heat sensors complying with this document are general purpose fire detectors. Multi-sensor fire detectors can be used to achieve

- a high stability against deceptive phenomena,
- a response to a broad range of fires.

Compared to the standards for single phenomenon detectors, additional environmental tests were included to demonstrate a higher stability.

The response to a broad range of fires is shown by including the test fires TF1 and TF8 in addition to the test fires TF2 to TF5 which are used for detectors complying with EN 54-7.

The performance of single sensor components of a multi-sensor fire detector need not comply with the standards for single phenomena fire detectors (EN 54-5, EN 54-7) however the combined performance does need to meet the requirements of this standard.

1 Scope

This European Standard specifies requirements, test methods and performance criteria for point-type multi-sensor fire detectors for use in fire detection systems installed in buildings (see EN 54-1:2011), incorporating in one mechanical enclosure at least one optical or ionization smoke sensor and at least one heat sensor. The overall fire detection performance is determined utilizing the combination of the detected phenomena.

This European Standard provides for the assessment and verification of constancy of performance (AVCP) of point detectors using a combination of smoke and heat sensors to this European Standard.

Point detectors using a combination of smoke and heat sensors having special characteristics suitable for the detection of specific fire risks are not covered by this European Standard. The performance requirements for any additional functions are beyond the scope of this European Standard (e.g. additional features or enhanced functionality for which this European Standard does not define a test or assessment method).

NOTE Certain types of detector contain radioactive materials. The national requirements for radiation protection differ from country to country and they are not specified in this European Standard.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 54-1:2011, *Fire detection and fire alarm systems - Part 1: Introduction*

EN 54-5:2000, *Fire detection and fire alarm systems - Part 5: Heat detectors - Point detectors*

EN 54-5:2000/A1:2002, *Fire detection and fire alarm systems - Part 5: Heat detectors - Point detectors*

EN 50130-4:2011, *Alarm systems - Part 4: Electromagnetic compatibility - Product family standard: Immunity requirements for components of fire, intruder, hold up, CCTV, access control and social alarm systems*

EN 60068-1:1994, *Environmental testing - Part 1: General and guidance (IEC 60068-1:1988)*

EN 60068-2-1:2007, *Environmental testing - Part 2-1: Tests - Test A: Cold (IEC 60068-2-1:2007)*

EN 60068-2-6:2008, *Environmental testing - Part 2-6: Tests - Test Fc: Vibration (sinusoidal) (IEC 60068-2-6:2008)*

EN 60068-2-27:2009, *Environmental testing - Part 2-27: Tests - Test Ea and guidance: Shock (IEC 60068-2-27:2009)*

EN 60068-2-30:2005, *Environmental testing - Part 2-30: Tests - Test Db: Damp heat, cyclic (12 h + 12 h cycle) (IEC 60068-2-30:2005)*

EN 60068-2-42:2003, *Environmental testing - Part 2-42: Tests - Test Kc: Sulphur dioxide test for contacts and connections (IEC 60068-2-42:2003)*

EN 60068-2-78:2013, *Environmental testing - Part 2-78: Tests - Test Cab: Damp heat, steady state (IEC 60068-2-78:2012)*

ISO 209:2007, *Aluminium and aluminium alloys — Chemical composition*