

# INTERNATIONAL STANDARD

## NORME INTERNATIONALE



**Live working – Phase comparators –  
Part 2: Resistive type to be used for voltages from 1 kV to 36 kV a.c.**

**Travaux sous tension – Compérateurs de phase –  
Partie 2: Type résistif pour usage sur des tensions alternatives de 1 kV à 36 kV**



## THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2014 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office  
3, rue de Varembe  
CH-1211 Geneva 20  
Switzerland

Tel.: +41 22 919 02 11  
Fax: +41 22 919 03 00  
[info@iec.ch](mailto:info@iec.ch)  
[www.iec.ch](http://www.iec.ch)

### About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

### About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

#### IEC Catalogue - [webstore.iec.ch/catalogue](http://webstore.iec.ch/catalogue)

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

#### IEC publications search - [www.iec.ch/searchpub](http://www.iec.ch/searchpub)

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

#### IEC Just Published - [webstore.iec.ch/justpublished](http://webstore.iec.ch/justpublished)

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

#### Electropedia - [www.electropedia.org](http://www.electropedia.org)

The world's leading online dictionary of electronic and electrical terms containing more than 30 000 terms and definitions in English and French, with equivalent terms in 14 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

#### IEC Glossary - [std.iec.ch/glossary](http://std.iec.ch/glossary)

More than 55 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

#### IEC Customer Service Centre - [webstore.iec.ch/csc](http://webstore.iec.ch/csc)

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: [csc@iec.ch](mailto:csc@iec.ch).

### A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

### A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

#### Catalogue IEC - [webstore.iec.ch/catalogue](http://webstore.iec.ch/catalogue)

Application autonome pour consulter tous les renseignements bibliographiques sur les Normes internationales, Spécifications techniques, Rapports techniques et autres documents de l'IEC. Disponible pour PC, Mac OS, tablettes Android et iPad.

#### Recherche de publications IEC - [www.iec.ch/searchpub](http://www.iec.ch/searchpub)

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

#### IEC Just Published - [webstore.iec.ch/justpublished](http://webstore.iec.ch/justpublished)

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

#### Electropedia - [www.electropedia.org](http://www.electropedia.org)

Le premier dictionnaire en ligne de termes électroniques et électriques. Il contient plus de 30 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans 14 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

#### Glossaire IEC - [std.iec.ch/glossary](http://std.iec.ch/glossary)

Plus de 55 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.

#### Service Clients - [webstore.iec.ch/csc](http://webstore.iec.ch/csc)

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: [csc@iec.ch](mailto:csc@iec.ch).

# INTERNATIONAL STANDARD

## NORME INTERNATIONALE



**Live working – Phase comparators –  
Part 2: Resistive type to be used for voltages from 1 kV to 36 kV a.c.**

**Travaux sous tension – Comparsateurs de phase –  
Partie 2: Type résistif pour usage sur des tensions alternatives de 1 kV à 36 kV**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

COMMISSION  
ELECTROTECHNIQUE  
INTERNATIONALE

PRICE CODE  
CODE PRIX

**XC**

ICS 13.260; 29.240.20; 29.260.99

ISBN 978-2-8322-1878-5

**Warning! Make sure that you obtained this publication from an authorized distributor.  
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

## CONTENTS

FOREWORD.....	6
INTRODUCTION.....	8
1 Scope.....	9
2 Normative references .....	9
3 Terms and definitions .....	10
4 Requirements .....	14
4.1 Indication.....	14
4.2 Functional requirements.....	14
4.2.1 Clear indication .....	14
4.2.2 Clear perceptibility.....	16
4.2.3 Temperature and humidity dependence of the indication.....	16
4.2.4 Frequency dependence .....	16
4.2.5 Response time.....	17
4.2.6 Power source dependability.....	17
4.2.7 Testing element.....	17
4.2.8 Time rating .....	17
4.3 Electrical requirements .....	17
4.3.1 Insulating material .....	17
4.3.2 Protection against bridging .....	17
4.3.3 Resistance against sparking.....	17
4.3.4 Resistive element .....	18
4.3.5 Insulating element of phase comparator as a complete device.....	18
4.3.6 Circuit current.....	18
4.3.7 Indicator casing .....	18
4.3.8 Insulation of the connecting lead .....	18
4.4 Mechanical requirements .....	18
4.4.1 General .....	18
4.4.2 Design .....	18
4.4.3 Dimensions, construction.....	20
4.4.4 Grip force and deflection .....	21
4.4.5 Vibration resistance .....	22
4.4.6 Drop resistance .....	22
4.4.7 Shock resistance .....	22
4.5 Marking.....	22
4.6 Instructions for use .....	22
4.7 Requirements in the case of reasonably foreseeable misuse during live working.....	23
4.7.1 Voltage selection .....	23
4.7.2 Frequency selection .....	23
5 Tests.....	23
5.1 General.....	23
5.1.1 Testing provisions .....	23
5.1.2 Atmospheric conditions.....	23
5.1.3 Tests under wet conditions .....	23
5.1.4 Type test .....	24
5.1.5 Test methods.....	25

5.2	Function tests .....	25
5.2.1	Description of the test set-up and general pass criteria.....	25
5.2.2	Clear indication .....	31
5.2.3	Electromagnetic compatibility (EMC) .....	33
5.2.4	Influence of electric interference fields.....	33
5.2.5	Clear perceptibility.....	36
5.2.6	Frequency dependence .....	40
5.2.7	Response time.....	40
5.2.8	Power source dependability .....	40
5.2.9	Check of testing element .....	41
5.2.10	Time rating .....	41
5.3	Dielectric tests .....	42
5.3.1	Insulating material for tubes and rods .....	42
5.3.2	Protection against bridging for indoor/outdoor type phase comparator .....	42
5.3.3	Protection against bridging for outdoor type phase comparator .....	47
5.3.4	Spark resistance.....	48
5.3.5	Leakage current for phase comparator as a complete device .....	49
5.3.6	Dielectric strength of connecting lead .....	52
5.3.7	Maximum current in case of misuse .....	53
5.4	Mechanical tests .....	53
5.4.1	Visual and dimensional inspection .....	53
5.4.2	Grip force and deflection for phase comparator as a complete device .....	54
5.4.3	Robustness of connecting lead and connections .....	54
5.4.4	Vibration resistance .....	56
5.4.5	Drop resistance .....	56
5.4.6	Shock resistance .....	57
5.4.7	Climatic resistance .....	58
5.4.8	Durability of markings .....	59
5.5	Test for reasonably foreseeable misuse during live working .....	59
5.5.1	Voltage selection (where relevant).....	59
5.5.2	Frequency selection (where relevant) .....	59
6	Conformity assessment of phase comparators having completed the production phase .....	60
7	Modifications .....	60
	Annex A (normative) Instructions for use .....	61
	Annex B (normative) Suitable for live working; double triangle (IEC 60417 – 5216 (2002-10)).....	63
	Annex C (normative) Chronology of type tests .....	64
	Annex D (normative) Classification of defects and tests to be allocated .....	66
	Annex E (informative) Information and guidelines on the use of the limit mark and of a contact electrode extension .....	68
	E.1 General.....	68
	E.2 Situation when using a phase comparator as a complete device .....	68
	E.3 Situation when using a phase comparator as a separate device.....	71
	Annex F (informative) Rationale for the classification of defects.....	74
	Annex G (informative) In-service care .....	76
	Bibliography.....	77

Figure 1 – Illustration of different elements of a phase comparator .....	20
Figure 2 – Location of allowed conductive parts within the minimum length of the insulating element of a pole of a phase comparator as a complete device.....	21
Figure 3 – Test set-up for clear indication with the ball electrode in front of its ring electrode .....	27
Figure 4 – Test set-up for clear indication with the ball electrode behind its ring electrode .....	28
Figure 5 – Example of positioning of a pole of the phase comparator in relation to a ball and ring test arrangement .....	30
Figure 6 – Examples of suitable means for ensuring appropriate contact between a contact electrode and the ball electrode.....	30
Figure 7 – Test set-up for clear perceptibility of visual indication .....	37
Figure 8 – Test set-up for clear perceptibility of audible indication .....	39
Figure 9 – Test arrangements and dimensions of the bars for protection against bridging .....	43
Figure 10 – Electrical connection of the bars .....	44
Figure 11 – Surface stress test.....	44
Figure 12 – Radial and surface stress test.....	45
Figure 13 – Bridging test on the connecting lead.....	46
Figure 14 – Test arrangement for testing bridging protection of outdoor type phase comparator .....	48
Figure 15 – Arrangement for leakage current test under dry conditions for phase comparator as a complete device.....	50
Figure 16 – Arrangement for leakage current tests under wet conditions for phase comparator as a complete device.....	51
Figure 17 – Test set up for pressure load application.....	52
Figure 18 – Test for grip force.....	54
Figure 19 – Test set-up for the robustness of connecting lead and connections .....	55
Figure 20 – Drop resistance test – Diagonal position .....	57
Figure 21 – Curve of test cycle for climatic resistance.....	58
Figure E.1 – Insulation element of a pole of a phase comparator as a complete device .....	68
Figure E.2 – Example of positioning of a pole of a phase comparator in contact with a live part without obstacles from other live parts.....	69
Figure E.3 – Example of incorrect positioning of a pole of a phase comparator with the limit mark between two live parts .....	70
Figure E.4 – Usual ways of managing the selection or the use of the phase comparator for maintaining the insulation distance between the limit mark and the hand guard .....	71
Figure E.5 – Usual ways of managing the use of the phase comparator as a separate device for assuring the appropriate insulation for the worker.....	73
Table 1 – Climatic condition ranges .....	16
Table 2 – Minimum length of the insulating element ( $L_i$ ) of a phase comparator as a complete device.....	20
Table 3 – Dimensioning of the ball and ring test set-up.....	29
Table 4 – Test series and conditions for clear indication .....	32
Table 5 – Test series and conditions for influence of electric interference fields.....	35
Table 6 – Distance $d_1$ for the bridging test set-up .....	43

Table 7 – Dimensions for the concentric rings and band electrodes .....	47
Table C.1 – Sequential order for performing type tests <sup>a</sup> .....	64
Table C.2 – Type tests out of sequence .....	65
Table D.1 – Classification of defects and associated requirements and tests .....	66
Table E.1 – Recommended minimum lengths from the limit mark to the contact electrode ( $A_i$ ) .....	71
Table F.1 – Rationale for the classification of defects .....	74
Table G.1 – In-service testing .....	76

This document is a preview generated by EVS

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

---

**LIVE WORKING –  
PHASE COMPARATORS –****Part 2: Resistive type to be used for voltages from 1 kV to 36 kV a.c.**

## FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61481-2 has been prepared by IEC technical committee 78: Live working.

This first edition, together with the first edition of IEC 61481-1, cancels and replaces the first edition of IEC 61481 published in 2001, Amendment 1:2002 and Amendment 2:2004. This edition constitutes a technical revision.

The major changes are:

- split of the standard in two parts;
- review of the requirements for indication;
- elimination of class C ( $\pm 110^\circ$ );
- introduction of a requirement for a new marking “LU” for limited use;
- increase of the specified range of voltage fluctuation in a network for clear indication;

- clarification of the design requirements by specifying a resistive element in each pole of the device;
- clarification of the test procedures in the case of additional contact electrodes, accessories and combination of accessories, as well as in the case of family of phase comparators;
- addition of requirements and tests for electromagnetic compatibility (EMC);
- clarification of the test provisions for the function tests;
- clarification of the test procedure for clear perceptibility of audible indication;
- preparation of the elements of evaluation of defects, and general application of IEC 61318:2007;
- revision of existing annexes;
- change of existing normative Annex C in two new Annexes D and F giving the classification of defects (normative) and the rationale for the classification of defects (informative);
- deletion of existing Annex D, not needed anymore following the specification of IEC 60068-2-75;
- deletion of existing Annex F, not applicable according to IEC 61318:2007;
- addition of a new informative Annex E giving additional information on the use of the limit mark and of a contact electrode extension.

The text of this standard is based on the following documents:

FDIS	Report on voting
78/1052/FDIS	78/1088/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

In this standard terms defined in Clause 3 appear in *italics*.

A list of all parts of the IEC 61481 series, published under the general title *Live working – Phase comparators*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

**IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.**

## INTRODUCTION

This International Standard has been prepared in accordance with the requirements of IEC 61477.

Taking into consideration the functioning principle of portable *phase comparators of resistive type* available on the market, the associated maximum a.c. *nominal voltage* is 36 kV.

The rationale for this maximum *nominal voltage* is:

- design of the *phase comparator* for operation by one person (see 4.4.2) – ergonomic consideration.  
With higher *nominal voltages*, the distance between phases of the installation increases and the positioning of the two poles of the *phase comparator* by one person becomes a limitation;
- correct performance of each component (including the connecting lead) under normal working conditions – performance consideration;
- possible contact of the connecting lead between the two poles of the *phase comparator* with a part of the installation at a phase or earth potential under normal working conditions.

The product covered by this standard may have an impact on the environment during some or all stages of its life cycle. These impacts can range from slight to significant, be short-term or long-term, and occur at the global, regional or local level.

In terms of environmental improvement, this standard includes neither requirements nor test provisions for the manufacturers of the product nor recommendations to the users of the product. However, all parties intervening in its design, manufacture, packaging, distribution, use, maintenance, repair, reuse, recovery and disposal are invited to take account of environmental considerations.

## LIVE WORKING – PHASE COMPARATORS –

### Part 2: Resistive type to be used for voltages from 1 kV to 36 kV a.c.

#### 1 Scope

This part of IEC 61481 is applicable to portable *phase comparators* of resistive type to be used on electrical systems for voltages from 1 kV a.c. to 36 kV a.c. and frequencies of 50 Hz and/or 60 Hz.

This standard is applicable to *phase comparators of resistive type* used in contact with the bare conductive parts to be compared:

- as a complete device including its *insulating element* or
- as a separate device, adaptable to an *insulating stick* which, as a separate tool, is not covered by this standard.

NOTE Some parts such as the *contact electrode* or the *insulating element* of a *phase comparator* as a complete device may be dismantled.

Some restrictions on their use are applicable in the case of factory-assembled switchgear and on overhead systems of electrified railways (see Annex A).

A device that is designed to provide other functions than phase comparison is a different device and is not covered by this standard. For example a device designed to be also used as a voltage detector is not covered by this standard (see Annex A).

Products designed and manufactured according to this standard contribute to the safety of the users provided they are used by persons trained for the work, in accordance with the hot stick working method and the instructions for use.

Except when otherwise specified, all the voltages defined in this standard refer to phase-to-phase voltages of three-phase systems. In other systems, the applicable phase-to-phase or phase-to-earth (ground) voltages should be used to determine the operating voltage.

#### 2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

CISPR 11, *Industrial, scientific and medical equipment – Radio-frequency disturbance characteristics – Limits and methods of measurement*

IEC 60060-1:2010, *High-voltage test techniques – Part 1: General definitions and test requirements*

IEC 60068-1, *Environmental testing – Part 1: General and guidance*

IEC 60068-2-6, *Environmental testing – Part 2-6: Tests – Test Fc: Vibration (sinusoidal)*

IEC 60068-2-14, *Environmental testing – Part 2-14: Tests – Test N: Change of temperature*

IEC 60068-2-31, *Environmental testing – Part 2-31: Tests – Test Ec: Rough handling shocks, primarily for equipment-type specimens*

IEC 60068-2-75, *Environmental testing – Part 2-75: Tests – Test Eh: Hammer tests*

IEC 60417, *Graphical symbols for use on equipment*. Available from: <http://www.graphical-symbols.info/equipment>

IEC 60942, *Electroacoustics – Sound calibrators*

IEC 61000-4-2, *Electromagnetic compatibility (EMC) – Part 4-2: Testing and measurement techniques – Electrostatic discharge immunity test*

IEC 61000-4-3, *Electromagnetic compatibility (EMC) – Part 4-3: Testing and measurement techniques – Radiated, radio-frequency, electromagnetic field immunity test*

IEC 61000-4-8, *Electromagnetic compatibility (EMC) – Part 4-8: Testing and measurement techniques – Power frequency magnetic field immunity test*

IEC 61260, *Electroacoustics – Octave-band and fractional-octave-band filters*

IEC 61318, *Live working – Conformity assessment applicable to tools, devices and equipment*

IEC 61326-1, *Electrical equipment for measurement, control and laboratory use – EMC requirements – Part 1: General requirements*

IEC 61477, *Live working – Minimum requirements for the utilization of tools, devices and equipment*

IEC 61672-1, *Electroacoustics – Sound level meters – Part 1: Specifications*

ISO 3744:2010, *Acoustics – Determination of sound power levels and sound energy levels of noise sources using sound pressure – Engineering methods for an essentially free-field over a reflecting plane*

CIE 15, *Colorimetry*

### 3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 61318 as well as the following apply.

#### 3.1

##### **accessory**

supplementary item not necessary for the functioning of the *phase comparator* and provided by the manufacturer to facilitate its use under certain operating conditions

Note 1 to entry: An *accessory* is not considered as a part of a device. Without the *accessory*, the device is still functional. An item that is required each time a device is used is not an *accessory* but a part of the device which may be disassembled.

Note 2 to entry: For example an *accessory* is used to lengthen the handle, to improve the efficiency of the *contact electrode*, to enable the *contact electrode* to reach the parts to be compared, etc.