

Bensiinijaamad. Osa 3: Ohutusnõuded sulgurventiilide valmistamisele ja jõudlusele

Petrol filling stations - Part 3: Safety requirements for construction and performance of shear valves

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 13617-3:2012 sisaldab Euroopa standardi EN 13617-3:2012 ingliskeelset teksti.	This Estonian standard EVS-EN 13617-3:2012 consists of the English text of the European standard EN 13617-3:2012.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 14.03.2012.	Date of Availability of the European standard is 14.03.2012.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 75.200

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:
Aru 10, 10317 Tallinn, Eesti; www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:
Aru 10, 10317 Tallinn, Estonia; www.evs.ee; phone 605 5050; e-mail info@evs.ee

English Version

Petrol filling stations - Part 3: Safety requirements for construction and performance of shear valves

Stations-service - Partie 3: Exigences de sécurité relatives à la construction et aux performances des raccords de sécurité

Tankstellen - Teil 3: Sicherheitstechnische Anforderungen an Bau- und Arbeitsweise von Abscherventilen

This European Standard was approved by CEN on 28 January 2012.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents

Page

Foreword.....	3
Introduction.....	4
1 Scope	5
2 Normative references	5
3 Terms and definitions	5
4 Explosion protection measures	6
5 Construction.....	6
5.1 General requirements.....	6
5.2 Specific requirements	7
5.3 Classes of construction	7
5.4 Threads	7
6 Physical properties.....	7
7 Operational requirements	8
8 Tests.....	8
8.1 General.....	8
8.2 Type tests	8
8.3 Production acceptance tests	8
8.4 Routine tests	9
9 Information for use	9
9.1 General.....	9
9.2 Marking and instruction	9
Annex A (normative) Instructions — Guide for items to be included in manufacturers' installation and user manual	11
Annex B (normative) Test methods.....	12
B.1 General requirements.....	12
B.2 Pressure test (routine test)	12
B.3 Main valve test (routine test)	12
B.4 Pressure relief valve test (routine test)	12
B.5 Fuel preconditioning (type test)	13
B.6 Pressure test (type test)	13
B.7 Main valve test (type test)	13
B.8 Check valve test (class I only) (type test)	13
B.9 Pressure relief valve test (class I only) (type test)	14
B.10 Thermal link test 1 (class I and class II only) (type test and production acceptance test)	14
B.11 Thermal link test 2 (class I and class II only) (type test and production acceptance test)	14
B.12 Main valve closure test (type test and production acceptance test).....	14
B.13 Main valve closure test (type test and production acceptance test).....	15
Annex C (informative) Environmental aspects.....	16
Annex ZA (informative) Relationship between this European Standard and the Essential Requirements of EU Directive 94/9/EC	18

Foreword

This document (EN 13617-3:2012) has been prepared by Technical Committee CEN/TC 393 "Equipment for tanks and filling stations", the secretariat of which is held by DIN.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by September 2012, and conflicting national standards shall be withdrawn at the latest by September 2012.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 13617-3:2004.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directive(s).

For relationship with EU Directive(s), see informative Annex ZA, which is an integral part of this document.

According to edition EN 13617-3:2004 the following fundamental changes are given:

- a new note at the end of the scope: 'Fuels other than of Explosion Group IIA are excluded from this European Standard' added;
- informative Annex C concerning environmental aspects added.

The present standard is composed of the following parts:

- *Part 1: Safety requirements for construction and performance of metering pumps, dispensers and remote pumping units;*
- *Part 2: Safety requirements for construction and performance of safe breaks for use on metering pumps and dispensers;*
- *Part 3: Safety requirements for construction and performance of shear valves;*
- *Part 4: Safety requirements for construction and performance of swivels for use on metering pumps and dispensers.*

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

Introduction

The function of the shear valve is to prevent continuous liquid or vapour release in the event of impact or fire

This document is a preview generated by EVS

1 Scope

This European Standard specifies safety and environmental requirements for the construction and performance of shear valves to be fitted to metering pumps, dispensers, and/or satellite delivery systems installed at petrol filling stations and used to dispense liquid fuels into the tanks of motor vehicles, boats and light aircraft and into portable containers at flow rates up to 200 l min⁻¹.

The requirements apply to shear valves at ambient temperatures from –20 °C to +40 °C with the possibility for an extended temperature range.

It pays particular attention to mechanical and hydraulic characteristics.

NOTE 1 This European Standard does not apply to equipment for use with liquefied petroleum gas (LPG) or liquefied natural gas (LNG) or compressed natural gas (CNG).

NOTE 2 Fuels other than of Explosion Group IIA are excluded from this European Standard.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 976–1, *Underground tanks of glass-reinforced plastics (GRP) — Horizontal cylindrical tanks for the non-pressure storage of liquid petroleum based fuels — Part 1: Requirements and test methods for single wall tanks*

EN 1127-1, *Explosive atmospheres — Explosion prevention and protection — Part 1: Basic concepts and methodology*

EN 13463–1:2009, *Non-electrical equipment for use in potentially explosive atmospheres — Part 1: Basic method and requirements*

EN 13617-1:2012, *Petrol filling stations — Part 1: Safety requirements for the construction and performance of metering pumps, dispensers and remote pumping units*

EN 60079-0, *Explosive atmospheres — Part 0: Equipment — General requirements*

EN ISO 1182, *Reaction to fire tests for products — Non-combustibility test (ISO 1182)*

ISO 7–1, *Pipe threads where pressure-tight joints are made on the threads — Part 1: Dimensions, tolerances and designations*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in prEN 13617–1:2010 and the following apply.

3.1

main valve (liquid)

normally open valve on the inlet side, closing when the shear valve operates

3.2

main valve (vapour)

normally open valve on the outlet side, closing when the shear valve operates