

**Valves for gas distribution systems with maximum
operating pressure less than or equal to 16 bar -
Performance requirements**

This document is a preview generated by EVS

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 13774:2013 sisaldab Euroopa standardi EN 13774:2013 ingliskeelset teksti.	This Estonian standard EVS-EN 13774:2013 consists of the English text of the European standard EN 13774:2013.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 20.02.2013.	Date of Availability of the European standard is 20.02.2013.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 23.060.01

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:
Aru 10, 10317 Tallinn, Eesti; www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:
Aru 10, 10317 Tallinn, Estonia; www.evs.ee; phone 605 5050; e-mail info@evs.ee

English Version

Valves for gas distribution systems with maximum operating pressure less than or equal to 16 bar - Performance requirements

Appareils de robinetterie pour les systèmes de distribution du gaz avec une pression maximale de service inférieure ou égale à 16 bar - Exigences de performance

Armaturen für Gasverteilungssysteme mit zulässigen Betriebsdrücken kleiner oder gleich 16 bar - Anforderungen an die Gebrauchstauglichkeit

This European Standard was approved by CEN on 28 December 2012.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents

Page

Foreword.....	4
1 Scope	5
2 Normative references	5
3 Terms and definitions	7
4 Symbols and abbreviations	8
5 Requirements, type tests and production tests	8
5.1 Type testing	8
5.1.1 Test samples	8
5.1.2 Test documents	8
5.1.3 Certification body	9
5.2 Materials	9
5.2.1 Shell	9
5.2.2 Obturator	10
5.2.3 Stem or shaft	10
5.2.4 Springs	11
5.2.5 Seals	11
5.2.6 Lubricants	11
5.3 Design	11
5.3.1 General	11
5.3.2 Strength design	12
5.3.3 Stems or shafts	12
5.3.4 Shell tappings	12
5.3.5 Bolt holes for assembly purposes	13
5.3.6 Manufacturing apertures	13
5.3.7 Sealing systems	13
5.3.8 Extended drain, vent and sealant lines	13
5.4 Dimensions	14
5.4.1 Threaded ends	14
5.4.2 End connections	15
5.4.3 End-to-end dimensions	15
5.5 Operability and endurance	15
5.5.1 Operability	15
5.5.2 Endurance	16
5.6 Strength of stops	16
5.7 Mechanical resistance against excessive actuating forces	16
5.8 Resistance of the obturator to static differential pressure	16
5.9 Shell strength	16
5.10 External leak tightness	17
5.11 Internal leak tightness	17
5.12 Resistance to wear (optional test)	17
5.13 Reference flow rate (optional test)	18
5.14 Cleanliness	18
5.15 Storage	18
6 Marking	18
Annex A (normative) Test methods for valves	20
A.1 Accuracy of measurements and stability	20
A.2 Test method 1: operability and operating forces test	20
A.2.1 General	20

A.2.2	Operability test	20
A.2.3	Endurance test	20
A.3	Test method 2: strength of stops	21
A.3.1	General	21
A.3.2	Procedure	21
A.4	Test method 3: resistance of the obturator to static differential pressure	21
A.5	Test method 4: wear test.....	21
A.5.1	General	21
A.5.2	Procedure	21
A.6	Test method 5: internal leak tightness test for DIB valves.....	22
A.6.1	General	22
A.6.2	Procedure	22
A.6.3	Test conditions.....	23
A.7	Test method 6: strength test on torque/thrust.....	23
A.7.1	General	23
A.7.2	Measured breakaway torque/thrust.....	23
A.7.3	Performance of test.....	24
A.7.4	Acceptance criteria	24
Annex B (informative)	European Standards for valves.....	25
Annex C (informative)	Summary of tests on product and type tests	26
Bibliography.....		29

Foreword

This document (EN 13774:2013) has been prepared by Technical Committee CEN/TC 69 "Industrial valves", the secretariat of which is held by AFNOR.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by August 2013, and conflicting national standards shall be withdrawn at the latest by August 2013.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 13774:2003.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association.

The following is a list of the main changes compared to the previous edition:

- a) the Scope has been modified;
- b) the Normative References (Clause 2) have been updated;
- c) requirements of type tests and production tests (Clause 5) have been completely revised, in particular:
 - 1) requirements for "strength design" (5.3.2), for "extended drain, vent and sealant lines" (5.3.8), for "end-to-end dimensions" (5.4.3), for "mechanical resistance against excessive actuating forces" (5.7) have been added;
 - 2) requirements for "resistance to wear" (5.12) and for "reference flow rate" (5.13) became optional;
 - 3) requirements for "bending resistance" and for "resistance to liquid agents" have been deleted;
- d) the annex on analysis of the technical file and recording of the initial conditions has been deleted;
- e) the annex on test methods for valves (Annex A) has been updated;
- f) the annex on additional characteristics on request from the purchaser has been deleted;
- g) the annex on resistance to bending moment applied via the stem or the shaft has been deleted;
- h) the annex providing the European Standards for valves (Annex B) has been updated;
- i) the annex giving a summary of tests on product and type tests (Annex C) has been added;
- j) the Bibliography has been updated.

According to the CEN/CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

1 Scope

This European Standard deals with metal isolating valves used for gas distribution systems with maximum operating pressure up to 16 bar, and which operate with fuel gases of the first, the second and the third family, in accordance with EN 437.

The types of isolating valves to be considered are: plug and ball valves, gate valves, globe valves and butterfly valves.

This standard does not apply to:

- valves for domestic installations;
- safety type pressure relief valves;
- wellhead valves.

In the case of power operated valves, the requirements for the power source are not covered by this European Standard.

The valves covered in this European Standard operate in the following classes of temperature:

- - 10 °C to 60 °C;
- - 20 °C to 60 °C;
- the range is stated by the purchaser for special design.

This European Standard gives additional requirements to the relevant products standards. (See Annex B.)

In case of contradictions between the standards mentioned in Annex B and this European Standard, EN 13774 prevails.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 19, *Industrial valves — Marking of metallic valves*

EN 377, *Lubricants for applications in appliances and associated controls using combustible gases except those designed for use in industrial processes*

EN 549, *Rubber materials for seals and diaphragms for gas appliances and gas equipment*

EN 558, *Industrial valves — Face-to-face and centre-to-face dimensions of metal valves for use in flanged pipe systems — PN and Class designated valves*

EN 682, *Elastomeric Seals — Materials requirements for seals used in pipes and fittings carrying gas and hydrocarbon fluids*

EN 736-1:1995, *Valves — Terminology — Part 1: Definition of types of valves*

EN 736-2:1997, *Valves — Terminology — Part 2: Definition of components of valves*

- EN 736-3:2008, *Valves — Terminology — Part 3: Definition of terms*
- EN 764-1:2004, *Pressure equipment — Part 1: Terminology — Pressure, temperature, volume, nominal size*
- EN 1092-1, *Flanges and their joints — Circular flanges for pipes, valves, fittings and accessories, PN designated — Part 1: Steel flanges*
- EN 1092-2, *Flanges and their joints — Circular flanges for pipes, valves, fittings and accessories, PN designated — Part 2: Cast iron flanges*
- EN 1092-3, *Flanges and their joints — Circular flanges for pipes, valves, fittings and accessories, PN designated — Part 3: Copper alloy flanges*
- EN 1555-1, *Plastics piping systems for the supply of gaseous fuels — Polyethylene (PE) — Part 1: General*
- EN 1555-2, *Plastics piping systems for the supply of gaseous fuels — Polyethylene (PE) — Part 2: Pipes*
- EN 1555-3, *Plastics piping systems for the supply of gaseous fuels — Polyethylene (PE) — Part 3: Fittings*
- EN 1759-1, *Flanges and their joint — Circular flanges for pipes, valves, fittings and accessories, Class designated — Part 1: Steel flanges, NPS 1/2 to 24*
- EN 1759-3, *Flanges and their joints — Circular flanges for pipes, valves, fittings and accessories, Class designated — Part 3: Copper alloy flanges*
- EN 10204, *Metallic products — Types of inspection documents*
- EN 10226-1, *Pipe threads where pressure tight joints are made on the threads — Part 1: Taper external threads and parallel internal threads — Dimensions, tolerances and designation*
- EN 12117, *Plastics piping systems — Fittings, valves and ancillaries — Determination of gaseous flow rate/pressure drop relationships*
- EN 12266-1:2012, *Industrial valves — Testing of metallic valves — Part 1: Pressure tests, test procedures and acceptance criteria — Mandatory requirements*
- EN 12516-1, *Industrial valves — Shell design strength — Part 1: Tabulation method for steel valve shells*
- EN 12516-2, *Industrial valves — Shell design strength — Part 2: Calculation method for steel valve shells*
- EN 12516-3, *Valves — Shell design strength — Part 3: Experimental method*
- EN 12516-4, *Industrial valves — Shell design strength — Part 4: Calculation method for valve shells manufactured in metallic materials other than steel*
- EN 12570, *Industrial valves — Method for sizing the operating element*
- EN 12627, *Industrial valves — Butt welding ends for steel valves*
- EN 12982, *Industrial valves — End-to-end and centre-to-end dimensions for butt welding end valves*
- EN 13942, *Petroleum and natural gas industries — Pipeline transportation systems — Pipeline valves (ISO 14313:2007 modified)*
- EN ISO 228-1, *Pipe threads where pressure-tight joints are not made on the threads — Part 1: Dimensions, tolerances and designation (ISO 228-1)*

EN ISO 8434-1, *Metallic tube connections for fluid power and general use — Part 1: 24 degree cone connectors (ISO 8434-1)*

ISO 272, *Fasteners — Hexagon products — Widths across flats*

ASME B1.20.1, *Pipe Threads, General Purpose (Inch)*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in EN 736-1:1995, EN 736-2:1997, EN 736-3:2008 and EN 764-1:2004 and the following apply.

3.1

gas distribution system

pipeline system including piping above and below ground and all other equipment necessary to supply the gas to the consumers

3.2

external tightness

shell tightness

tightness of the gas-containing envelope with respect to the atmosphere

3.3

internal tightness

seat tightness

tightness ensured between the valve inlet and outlet by the closure device in the closed position

3.4

volume rate of flow

volume of fluid discharged by the valve per time unit

3.5

reference flow rate

rate of the air flow in cubic metres per hour, as measured at 0 °C at the absolute pressure of 1 013 mbar, discharged by the valve and creating therein a specified pressure drop, at a specified air pressure upstream of the valve

3.6

maximum allowable pressure

p_{\max}

maximum pressure at which any part of a valve continuously operates at a specified operating temperature

3.7

maximum operating pressure

MOP

maximum pressure in a system operated continuously under normal operating conditions

Note 1 to entry: "Normal operating conditions" means no malfunctioning of the equipment or disruption to the gas flow.

3.8

maximum strength torque

maximum torque applied to the stem or the shaft, with the obturator either totally open or totally closed, which causes no alteration to the functional capability of the valve