

Hoonete küttesüsteemid. Kaetud vesi-pindkütte- ja -jahutussüsteemide projekteerimine. Osa 2: Projekteerimine, dimensioneerimine ja paigaldus

Heating systems in buildings - Design of embedded water based surface heating and cooling systems - Part 2: Design, dimensioning and installation

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

<p>Käesolev Eesti standard EVS-EN 15377-2:2008 sisaldab Euroopa standardi EN 15377-2:2008 ingliskeelset teksti.</p> <p>Standard on kinnitatud Eesti Standardikeskuse 18.08.2008 käskkirjaga ja jõustub sellekohase teate avaldamisel EVS Teatajas.</p> <p>Euroopa standardimisorganisatsioonide poolt rahvuslikele liikmetele Euroopa standardi teksti kättesaadavaks tegemise kuupäev on 25.06.2008.</p> <p>Standard on kättesaadav Eesti standardiorganisatsioonist.</p>	<p>This Estonian standard EVS-EN 15377-2:2008 consists of the English text of the European standard EN 15377-2:2008.</p> <p>This standard is ratified with the order of Estonian Centre for Standardisation dated 18.08.2008 and is endorsed with the notification published in the official bulletin of the Estonian national standardisation organisation.</p> <p>Date of Availability of the European standard text 25.06.2008.</p> <p>The standard is available from Estonian standardisation organisation.</p>
--	---

ICS 91.140.10, 91.140.30

Võtmesõnad:

Standardite reprodutseerimis- ja levitamiseõigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonilisse süsteemi või edastamine ükskõik millises vormis või millisel teel on keelatud ilma Eesti Standardikeskuse poolt antud kirjaliku loata.

Kui Teil on küsimusi standardite autorikaitse kohta, palun võtke ühendust Eesti Standardikeskusega:
Aru 10 Tallinn 10317 Eesti; www.evs.ee; Telefon: 605 5050; E-post: info@evs.ee

ICS 91.140.10; 91.140.30

English Version

Heating systems in buildings - Design of embedded water based surface heating and cooling systems - Part 2: Design, dimensioning and installation

Systèmes de chauffage dans les bâtiments - Conception des systèmes de chauffage et refroidissement par le sol, le mur et le plafond - Design, dimensionnement et installation

Heizungsanlagen in Gebäuden - Planung von eingebetteten Flächenheiz- und -kühlssystemen mit Wasser als Arbeitsmedium - Teil 2: Planung, Auslegung und Installation

This European Standard was approved by CEN on 22 May 2008.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: rue de Stassart, 36 B-1050 Brussels

Contents

Page

Foreword.....	3
Introduction	5
1 Scope	6
2 Normative references	6
3 Terms, definitions, symbols and units	6
4 Basic principles	6
4.1 Heating or cooling medium differential temperature	6
4.2 Performance characteristic curve	7
4.3 Field of system characteristic curves	7
4.4 Limit curves	7
5 Boundary conditions and limits	10
5.1 Supply pipes to adjacent rooms	10
5.2 Backing thermal insulation	10
6 Design	12
6.1 Design heat flow intensity	12
6.2 Required length of the heating or cooling circuit	13
6.3 Procedure for determining the design supply temperature	14
6.3.1 System only for heating	14
6.3.2 System only for cooling	16
6.4 Procedure for determining the design heating or cooling medium flow rate	16
7 Peripheral areas by floor heating	17
8 Installation	18
Annex A (informative) Installation	19
A.1 General.....	19
A.2 Equipment	19
A.2.1 General.....	19
A.2.2 Safety	19
A.2.3 Stop valves and balancing devices	19
A.2.4 Control	19
A.2.5 Piping (pipes and couplings).....	20
A.3 Installation of piping.....	20
A.3.1 Storage and transport	20
A.3.2 Bending radius.....	20
A.3.3 Couplings	20
A.3.4 Joints	20
A.3.5 Holes in the embedded surface.....	21
A.4 Leak test	21
A.5 Initial heating up	21
Annex B (informative) Recommended minimum thermal resistance for floor heating systems	22
Bibliography	23

Foreword

This document (EN 15377-2:2008) has been prepared by Technical Committee CEN/TC 228 "Heating systems in buildings", the secretariat of which is held by DS.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by December 2008, and conflicting national standards shall be withdrawn at the latest by December 2008.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document is based on EN 1264-3 and -4, but has been modified to include cooling and other surface systems than floor heating. When EN 1264-3 and -4 are revised, the present standard will be superseded by the revised EN 1264-3 and -4.

The subjects covered by CEN/TC 228 are the following:

- design of heating systems (water based, electrical, etc.);
- installation of heating systems;
- commissioning of heating systems;
- instructions for operation, maintenance and use of heating systems;
- methods for calculation of the design heat loss and heat loads;
- methods for calculation of the energy performance of heating systems;
- methods for design and dimensioning of embedded water based surface heating and cooling systems.

Heating systems also include the effect of attached systems such as hot water production systems.

All these standards are systems standards, i.e. they are based on requirements addressed to the system as a whole and not dealing with requirements to the products within the system.

Where possible, reference is made to other European or International Standards, a.o. product standards. However, use of products complying with relevant product standards is no guarantee of compliance with the system requirements.

The requirements are mainly expressed as functional requirements, i.e. requirements dealing with the function of the system and not specifying shape, material, dimensions or the like.

The guidelines describe ways to meet the requirements, but other ways to fulfil the functional requirements might be used if fulfilment can be proved.

Heating systems differ among the member countries due to climate, traditions and national regulations. In some cases requirements are given as classes so national or individual needs may be accommodated.

In cases where the standards contradict with national regulations, the latter should be followed.

EN 15377 *Heating systems in buildings — Design of embedded water based surface heating and cooling systems* consists of the following parts:

- *Part 1: Determination of the design heating and cooling capacity;*
- *Part 2: Design, dimensioning and installation;*
- *Part 3: Optimizing for use of renewable energy sources.*

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

Introduction

This European Standard specifies procedures and conditions for design, dimensioning and installation. Based on heating and cooling load calculations and determination of heating and cooling performance according to EN 15377-1 and EN 1264, respectively, the present part specifies the calculation of characteristic curves, which show the relationship between heat flow intensity and the determining variables.

The water flow rate is calculated using recommended values for the temperature difference between supply and return water temperature.

Special design considerations are given for systems which are used for both heating and cooling purposes. Further, requirements related to installation are included.

1 Scope

This European Standard is applicable to water based surface heating and cooling systems in buildings as defined in EN 15377-1.

Physiological limitations are taken into account when specifying the maximum and minimum surface temperature. The design is based on performance characteristic curves and limit curves calculated in accordance with EN 15377-1 and EN 1264.

Design considerations for heating and cooling systems are specified.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 1057, *Copper and copper alloys — Seamless, round copper tubes for water and gas in sanitary and heating applications*

EN 1254 (all parts), *Copper and copper alloys — Plumbing fittings*

EN 1264-2, *Water based surface embedded heating and cooling systems — Part 2: Floor heating: Prove methods for the determination of the thermal output of floor heating systems using calculation and test methods*

EN 12828, *Heating systems in buildings — Design for water-based heating systems*

EN 12831, *Heating systems in buildings — Method for calculation of the design heat load*

EN 15377-1:2008, *Heating systems in buildings — Design of embedded water based surface heating and cooling systems — Part 1: Determination of the design heating and cooling capacity*

EN ISO 13370, *Thermal performance of buildings — Heat transfer via the ground — Calculation methods (ISO 13370:2007)*

ISO 17455, *Plastics piping systems — Multilayer pipes — Determination of the oxygen permeability of the barrier pipe*

3 Terms, definitions, symbols and units

For the purposes of this document, the terms, definitions, symbols and units given in EN 15377-1:2008 apply.

4 Basic principles

4.1 Heating or cooling medium differential temperature

The heating or cooling medium differential temperature $\Delta\theta_H$ is calculated as follows (refer to EN 15377-1):