

This document is a preview generated by EVS

Electricity metering data exchange - The DLMS/COSEM Suite - Part 8-6: High speed PLC ISO/IEC 12139-1 profile for neighbourhood networks

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 62056-8-6:2017 sisaldab Euroopa standardi EN 62056-8-6:2017 ingliskeelset teksti.	This Estonian standard EVS-EN 62056-8-6:2017 consists of the English text of the European standard EN 62056-8-6:2017.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 30.06.2017.	Date of Availability of the European standard is 30.06.2017.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 17.220, 35.110, 91.140.50

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:
Koduleht www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:

Homepage www.evs.ee; phone +372 605 5050; e-mail info@evs.ee

EUROPEAN STANDARD

EN 62056-8-6

NORME EUROPÉENNE

EUROPÄISCHE NORM

June 2017

ICS 17.220; 35.110; 91.140.50

English Version

Electricity metering data exchange - The DLMS/COSEM suite -
Part 8-6: High speed PLC ISO/IEC 12139-1 profile for
neighbourhood networks
(IEC 62056-8-6:2017)

Échange des données de comptage de l'électricité - La
suite DLMS/COSEM - Partie 8-6: Profil CPL ISO/IEC
12139-1 à grande vitesse pour les réseaux de voisinage
(IEC 62056-8-6:2017)

Datenkommunikation der elektrischen Energiemessung -
DLMS/COSEM - Teil 8-6: Schnelles PLC-ISO/IC-12139-1-
Profil für Areal-Netze
(IEC 62056-8-6:2017)

This European Standard was approved by CENELEC on 2017-05-15. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

European foreword

The text of document 13/1730/FDIS, future edition 1 of IEC 62056-8-6, prepared by IEC/TC 13 "Electrical energy measurement and control" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 62056-8-6:2017.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2018-02-15
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2020-05-15

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association.

Endorsement notice

The text of the International Standard IEC 62056-8-6:2017 was approved by CENELEC as a European Standard without any modification.

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 When an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 62056-1-0	2014	Electricity metering data exchange - The DLMS/COSEM suite - Part 1-0: Smart metering standardisation framework	EN 62056-1-0	2015
IEC 62056-4-7	-	Electricity metering data exchange - The DLMS/COSEM suite -- Part 4-7: DLMS/COSEM transport layer for IP networks	EN 62056-4-7	-
IEC 62056-5-3	-	Electricity metering data exchange - The DLMS/COSEM suite - Part 5-3: DLMS/COSEM application layer	EN 62056-5-3	-
IEC 62056-6-1	-	Electricity metering data exchange - The DLMS/COSEM suite - Part 6-1: Object Identification System (OBIS)	EN 62056-6-1	-
IEC 62056-6-2	2016	Electricity metering data exchange - The DLMS/COSEM suite - Part 6-2: COSEM interface classes	EN 62056-6-2	2016
IEC 62056-7-6	-	Electricity metering data exchange - The DLMS/COSEM suite -- Part 7-6: The 3-layer, connection-oriented HDLC based communication profile	EN 62056-7-6	-
IEC 62056-9-7	-	Electricity metering data exchange - The DLMS/COSEM suite -- Part 9-7: Communication profile for TCP-UDP/IP networks	EN 62056-9-7	-
IEC 62056-46	-	Electricity metering - Data exchange for meter reading, tariff and load control -- Part 46: Data link layer using HDLC protocol	EN 62056-46	-
IEC/TS 62056-1-1	2016	Electricity metering data exchange - The DLMS/COSEM suite - Part 1-1: Template for DLMS/COSEM communication profile standards	-	-
ISO/IEC 12139-1	2009	Information technology - Telecommunications and information exchange between systems - Powerline communication (PLC) - High speed PLC medium access control (MAC) and physical layer (PHY) - Part 1: General requirements	-	-
ISO/IEC/IEEE 8802-3	2014	Standard for Ethernet	-	-
RFC 1144	-	Compressing TCP/IP Headers for Low-Speed Serial Links	-	-
RFC 2460	-	Internet Protocol, Version 6 (IPv6) Specification	-	-
RFC 2508	-	Compressing IP/UDP/RTP Headers for Low-Speed Serial Links	-	-

RFC 3095	-	RObust Header Compression (ROHC): Framework and four profiles: RTP, UDP, ESP, and uncompressed	-	-
RFC 791	-	Internet Protocol - DARPA Internet Program Protocol Specification	-	-

This document is a preview generated by EVS

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	7
2 Normative references	7
3 Terms, definitions and abbreviated terms	8
3.1 Terms and definitions.....	8
3.2 Abbreviated terms.....	8
4 Targeted communication environments.....	9
5 Use of the communication layers for this profile.....	10
5.1 Information related to the use of the standard specifying the lower layers	10
5.2 Structure of the communication profile	10
5.3 Lower protocol layers and their use.....	11
5.3.1 Overview	11
5.3.2 Physical layer	11
5.3.3 MAC layer.....	11
5.4 Service mapping and adaptation layers	11
5.4.1 Overview	11
5.4.2 CPAS	12
5.4.3 IP SSAS	12
5.4.4 HDLC SSAS	16
5.5 Registration and connection management.....	19
6 Identification and addressing schemes	19
7 Specific considerations for the application layer services.....	20
7.1 Overview.....	20
7.2 Application Association establishment and release: ACSE services	20
7.3 xDLMS services	20
7.4 Security mechanisms	21
7.5 Transferring long application messages	21
7.6 Media access, bandwidth and timing considerations	21
7.7 Other considerations.....	21
8 Communication configuration and management.....	21
9 The COSEM application process	21
10 Additional considerations for the use of this profile	21
Annex A (informative) Examples	22
A.1 IP-based communication examples	22
A.2 HDLC-based communication examples	25
A.2.1 Example 1: Data link layer connection establishment (SNRM-UA exchange).....	25
A.2.2 Example 2: Establishment of an AA (AARQ – AARE exchange).....	26
A.2.3 Example 3: Data communication (Get-request)	28
A.2.4 Example 4: Disconnection example with Releasing (DISC)	30
Annex B (normative) COSEM ICs for data exchange using HS-PLC ISO/IEC 12139-1 neighbourhood networks.....	32
B.1 General.....	32
B.2 Interface classes for setting up and managing DLMS/COSEM HS-PLC ISO/IEC 12139-1 networks.....	32

B.2.1	Overview	32
B.2.2	HS-PLC ISO/IEC 12139-1 MAC setup (class_id = 140, version = 0).....	32
B.2.3	HS-PLC ISO/IEC 12139-1 CPAS setup (class_id = 141, version = 0).....	33
B.2.4	HS-PLC ISO/IEC 12139-1 IP SSAS setup (class_id = 142, version = 0).....	34
B.2.5	HS-PLC ISO/IEC 12139-1 HDLC SSAS setup (class_id = 143, version = 0).....	35
B.3	Relation to OBIS	35
B.3.1	Use of value group C	35
B.3.2	Objects for data exchange using DLMS/COSEM HS-PLC ISO/IEC 12139-1 networks	36
Index	37
Figure 1	– Entities and interfaces of a smart metering system using the terminology of IEC 62056-1-0	9
Figure 2	– DLMS/COSEM High Speed PLC profile	10
Figure 3	– Adaptation layer architecture.....	11
Figure 4	– CPAS frame structure	12
Figure 5	– IP SSAS control packet	13
Figure 6	– IP SSAS data packet.....	13
Figure 7	– HDLC SSAS Frame.....	16
Figure 8	– Message configuration for response to HDLC addresses request	17
Table 1	– IP SSAS control packet format Inconsistencies! IP_Len	13
Table 2	– IP SSAS data packet format	14
Table 3	– Values for IP_Header_Comp_Type.....	15
Table 4	– Valid range of the Transmission_status value.....	16
Table 5	– HDLC SSAS Frame format	17
Table 6	– Usage of CMD and STA fields	17
Table 7	– Client and Server SAPs for the IP based communication	20
Table 8	– Client and Server SAPs for the HDLC based communication	20
Table B.1	– Use of value group C for abstract objects in the COSEM context	36

INTRODUCTION

As defined in IEC 62056-1-0, the IEC 62056 DLMS/COSEM suite provides specific communication profile standards for communication media relevant for smart metering.

Such communication profile standards specify how the COSEM data model and the DLMS/COSEM application layer can be used on the lower, communication media-specific protocol layers.

Communication profile standards refer to communication standards that are part of the IEC 62056 DLMS/COSEM suite or to any other open communication standard.

This document specifies the DLMS/COSEM profile for High Speed PLC (HS-PLC) technologies according to ISO/IEC 12139-1 for neighbourhood networks. The technology is based on Discrete Multi-Tone (DMT) modulation. It may be used in low voltage or on medium voltage distribution networks. The PHY rate of High Speed PLC is typically 24 Mbps, however the data throughput varies according to many aspects of low voltage or medium voltage power lines. Although High Speed PLC can be used both on low voltage and medium voltage networks, in this document HS-PLC on low voltage network is only considered.

When implementing advanced services based on DLMS/COSEM profiles such as complex tariff programs, data security measures, two-way consumption data exchange for demand response and so forth, the neighbourhood network may become a bottleneck. The HS-PLC technology minimizes such bottlenecks due to the high data rates available. Moreover, the HS-PLC technology can accommodate increased amounts of data thus it can additionally support other applications such as Internet of Things (IoT).

Using the high speed PLC technology specified in ISO/IEC 12139-1 may be subject to national regulations. However, this aspect is outside the Scope of this document.