

This document is a preview generated by EVS

Wind energy generation systems - Part 25-5:  
Communications for monitoring and control of wind  
power plants - Compliance testing

## EESTI STANDARDI EESSÕNA

## NATIONAL FOREWORD

See Eesti standard EVS-EN 61400-25-5:2017 sisaldab Euroopa standardi EN 61400-25-5:2017 ingliskeelset teksti.	This Estonian standard EVS-EN 61400-25-5:2017 consists of the English text of the European standard EN 61400-25-5:2017.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 15.12.2017.	Date of Availability of the European standard is 15.12.2017.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile [standardiosakond@evs.ee](mailto:standardiosakond@evs.ee).

ICS 27.180

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:  
Koduleht [www.evs.ee](http://www.evs.ee); telefon 605 5050; e-post [info@evs.ee](mailto:info@evs.ee)

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:

Homepage [www.evs.ee](http://www.evs.ee); phone +372 605 5050; e-mail [info@evs.ee](mailto:info@evs.ee)

English Version

Wind energy generation systems - Part 25-5: Communications  
for monitoring and control of wind power plants - Compliance  
testing  
(IEC 61400-25-5:2017)

Systèmes de production d'énergie éolienne - Partie 25-5:  
Communications pour la surveillance et la commande des  
centrales éoliennes - Essais de conformité  
(IEC 61400-25-5:2017)

Windenergieanlagen - Teil 25-5: Kommunikation für die  
Überwachung und Steuerung von Windenergieanlagen -  
Konformitätsprüfungen  
(IEC 61400-25-5:2017)

This European Standard was approved by CENELEC on 2017-10-25. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization  
Comité Européen de Normalisation Electrotechnique  
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

## European foreword

The text of document 88/643/FDIS, future edition 2 of IEC 61400-25-5, prepared by IEC/TC 88 "Wind energy generation systems" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 61400-25-5:2017.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2018-07-25
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2020-10-25

This document supersedes EN 61400-25-5:2007.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

## Endorsement notice

The text of the International Standard IEC 61400-25-5:2017 was approved by CENELEC as a European Standard without any modification.

## Annex ZA (normative)

### Normative references to international publications with their corresponding European publications

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 Where an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: [www.cenelec.eu](http://www.cenelec.eu).

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 61400-25-1	2006	Wind turbines - Part 25-1: Communications for monitoring and control of wind power plants - Overall description of principles and models	EN 61400-25-1	2007
IEC 61400-25	series	Wind turbines - Part 25: Communications for monitoring and control of wind power plants	EN 61400-25	series
IEC 61400-25-2	2015	Wind turbines - Part 25-2: Communications for monitoring and control of wind power plants - Information models	EN 61400-25-2	2015
IEC 61400-25-3	2015	Wind turbines - Part 25-3: Communications for monitoring and control of wind power plants - Information exchange models	EN 61400-25-3	2015
IEC 61400-25-4	2016	Wind energy generation systems - Part 25-4: Communications for monitoring and control of wind power plants - Mapping to communication profile	EN 61400-25-4	2017
IEC 61850-4	2011	Communication networks and systems for power utility automation - Part 4: System and project management	EN 61850-4	2011
IEC 61850-6	2009	Communication networks and systems for power utility automation - Part 6: Configuration description language for communication in electrical substations related to IEDs	EN 61850-6	2010
IEC 61850-7-1	2011	Communication networks and systems for power utility automation - Part 7-1: Basic communication structure - Principles and models	EN 61850-7-1	2011
IEC 61850-7-2	2010	Communication networks and systems for power utility automation - Part 7-2: Basic information and communication structure - Abstract communication service interface (ACSI)	EN 61850-7-2	2010
IEC 61850-7-3	2010	Communication networks and systems for power utility automation - Part 7-3: Basic communication structure - Common data classes	EN 61850-7-3	2011
IEC 61850-7-4	2010	Communication networks and systems for power utility automation - Part 7-4: Basic communication structure - Compatible logical node classes and data object classes	EN 61850-7-4	2010

IEC 61850-10	2012	Communication networks and systems for power utility automation - Part 10: Conformance testing	EN 61850-10	2013
ISO/IEC 9646	series	Information technology - Open Systems Interconnection - Conformance testing methodology and framework	EN ISO/IEC 9646	series

This document is a preview generated by EVS

## CONTENTS

FOREWORD.....	5
INTRODUCTION.....	7
1 Scope.....	8
2 Normative references .....	8
3 Terms and definitions .....	9
4 Abbreviated terms .....	12
5 Introduction to compliance testing .....	12
5.1 General.....	12
5.2 Compliance test procedures.....	13
5.3 Quality assurance and testing.....	14
5.3.1 General .....	14
5.3.2 Quality plan .....	14
5.4 Testing .....	15
5.4.1 General .....	15
5.4.2 Device testing.....	16
5.5 Documentation of compliance test report .....	17
6 Device related compliance testing .....	17
6.1 Test methodology .....	17
6.2 Compliance test procedures.....	18
6.2.1 General .....	18
6.2.2 Test procedure requirements .....	18
6.2.3 Test structure .....	19
6.2.4 Test cases to test a server device.....	19
6.2.5 Test cases to test a client device .....	38
6.2.6 Acceptance criteria .....	52
7 Performance tests .....	52
7.1 General.....	52
7.2 Communication latency – Transfer time test introduction.....	53
7.3 Time synchronisation and accuracy .....	54
7.3.1 Time Sync test introduction.....	54
7.3.2 Time Sync test methodology.....	55
7.3.3 Testing criteria.....	55
Annex A (informative) Examples of test procedure template.....	56
A.1 Example 1.....	56
A.2 Example 2.....	56
Figure 1 – Conceptual communication model of the IEC 61400-25 standard series .....	8
Figure 2 – Conceptual compliance assessment process.....	16
Figure 3 – Test procedure format.....	19
Figure 4 – Test system architecture to test a server device.....	20
Figure 5 – Test system architecture to test a client device .....	39
Figure 6 – Performance testing (black box principle).....	54
Figure 7 – Time synchronisation and accuracy test setup .....	55

Table 1 – Server documentation test cases.....	20
Table 2 – Server data model test cases .....	21
Table 3 – Association positive test cases .....	22
Table 4 – Association negative test cases.....	22
Table 5 – Server positive test cases .....	23
Table 6 – Server negative test cases .....	24
Table 7 – Data set positive test cases.....	25
Table 8 – Date set negative test cases .....	26
Table 9 – Substitution positive test cases .....	26
Table 10 – Unbuffered reporting positive test cases.....	27
Table 11 – Unbuffered reporting negative test cases .....	28
Table 12 – Buffered reporting positive test cases.....	29
Table 13 – Buffered reporting negative test cases.....	31
Table 14 – Log positive test cases .....	32
Table 15 – Log negative test cases.....	32
Table 16 – Control model test cases .....	33
Table 17 – DOns test cases .....	35
Table 18 – SBOs test cases.....	35
Table 19 – DOes test cases .....	36
Table 20 – SBOes test cases.....	37
Table 21 – Time positive test cases .....	38
Table 22 – Time negative test cases .....	38
Table 23 – Client documentation test case .....	39
Table 24 – Client data model test case.....	40
Table 25 – Association positive test cases.....	40
Table 26 – Association negative test cases.....	41
Table 27 – Server positive test cases.....	41
Table 28 – Server negative test cases .....	42
Table 29 – Data set positive test cases.....	43
Table 30 – Data set negative test cases.....	43
Table 31 – Substitution test cases .....	44
Table 32 – Unbuffered reporting positive test cases.....	44
Table 33 – Unbuffered reporting negative test cases .....	45
Table 34 – Buffered reporting positive test cases.....	46
Table 35 – Buffered reporting negative test cases.....	47
Table 36 – Log positive test cases .....	48
Table 37 – Log negative test cases.....	48
Table 38 – Control model positive test cases .....	49
Table 39 – Control model negative test cases.....	49
Table 40 – SBOes test cases.....	50
Table 41 – SBOs test cases.....	50
Table 42 – DOes test cases .....	51
Table 43 – DOns test cases.....	51

Table 44 – Time positive test cases .....	52
Table 45 – Time negative test cases .....	52

This document is a preview generated by EVS

## INTRODUCTION

The focus of IEC 61400-25 (all parts) is on the communications between wind power plant components such as wind turbines and actors such as SCADA Systems. Internal communication within wind power plant components is outside the scope of IEC 61400-25 (all parts).

IEC 61400-25 (all parts) is designed for a communication environment supported by a client-server model. Three areas are defined, that are modelled separately to ensure the scalability of implementations:

- a) wind power plant information models,
- b) information exchange model, and
- c) mapping of these two models to a standard communication profile.

The wind power plant information model and the information exchange model, viewed together, constitute an interface between client and server. In this conjunction, the wind power plant information model serves as an interpretation frame for accessible wind power plant data. The wind power plant information model is used by the server to offer the client a uniform, component-oriented view of the wind power plant data. The information exchange model reflects the whole active functionality of the server. IEC 61400-25 (all parts) enables connectivity between a heterogeneous combination of client and servers from different manufacturers and suppliers.

As depicted in Figure 1, IEC 61400-25 (all parts) defines a server with the following aspects:

- information provided by a wind power plant component, e. g., “wind turbine rotor speed” or “total power production of a certain time interval” is modelled and made available for access. The information modelled in the document is defined in IEC 61400-25-2,
- services to exchange values of the modelled information defined in IEC 61400-25-3,
- mapping to a communication profile, providing a protocol stack to carry the exchanged values from the modelled information (IEC 61400-25-4).

IEC 61400-25 (all parts) only defines how to model the information, information exchange and mapping to specific communication protocols. IEC 61400-25 (all parts) excludes a definition of how and where to implement the communication interface, the application program interface and implementation recommendations. However, the objective of IEC 61400-25 (all parts) is that the information associated with a single wind power plant component (such as the wind turbine) is accessible through a corresponding logical device.

The intended readers for the present document are device or system and/or system component manufacturers and test system developers/providers.

NOTE Abbreviations used in IEC 61400-25-5 are listed in Clauses 3 and 4 or can be found in other parts of IEC 61400-25 standard series that are relevant for compliance testing.