

**PLAHVATUSOHTLIKUD KESKKONNAD. OSA 0:
SEADMED. ÜLDNÕUDED**

**Explosive atmospheres - Part 0: Equipment - General
requirements (IEC 60079-0:2017 + COR1:2020)**

EESTI STANDARDI EESSÕNA**NATIONAL FOREWORD**

See Eesti standard EVS-EN IEC 60079-0:2018 sisaldab Euroopa standardi EN IEC 60079-0:2018 ja selle paranduse AC:2020 ingliskeelset teksti.	This Estonian standard EVS-EN IEC 60079-0:2018 consists of the English text of the European standard EN IEC 60079-0:2018 and its corrigendum AC:2020.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas. Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 06.07.2018.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation. Date of Availability of the European standard is 06.07.2018.
Parandusega AC lisatud või muudetud teksti algus ja lõpp on tekstis ära märgitud märgenditega AC AC . Selles standardis on rahvusvahelise standardi ühismuudatused tähistatud püstkriipsuga teksti välimisel veerisel. Standard on kättesaadav Eesti Standardikeskusest.	The start and finish of text introduced or altered by amendment AC is indicated in the text by symbols AC AC . Common modifications have been incorporated into this international standard and changes have been marked by a vertical line on the outer row of the page. The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 29.260.20

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega: Koduleht www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:

Homepage www.evs.ee; phone +372 605 5050; e-mail info@evs.ee

English Version

**Explosive atmospheres - Part 0: Equipment - General requirements
(IEC 60079-0:2017 + COR1:2020)**

Atmosphères explosives - Partie 0: Matériel - Exigences
générales
(IEC 60079-0:2017 + COR1:2020)

Explosionsgefährdete Bereiche - Teil 0: Betriebsmittel -
Allgemeine Anforderungen
(IEC 60079-0:2017 + COR1:2020)

This European Standard was approved by CENELEC on 2017-12-04. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

European foreword

The text of document (31/1345/FDIS), future edition 7 of IEC 60079-0, prepared by IEC/TC 31 "Equipment for explosive atmospheres" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 60079-0:2018.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2019-01-06
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2021-07-06

This document supersedes EN 60079-0:2012.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directive(s).

For the relationship with EU Directive(s) see informative Annex ZZ, which is an integral part of this document.

Endorsement notice

The text of the International Standard IEC 60079-0:2017 was approved by CENELEC as a European Standard without any modification.

This document is a preview generated by EVS

CONTENTS

FOREWORD	9
1 Scope	16
2 Normative references	17
3 Terms and definitions	19
4 Equipment grouping	37
4.1 General	37
4.2 Group I	37
4.3 Group II	37
4.4 Group III	37
4.5 Equipment for a particular explosive gas atmosphere	38
5 Temperatures	38
5.1 Environmental influences	38
5.1.1 Ambient temperature	38
5.1.2 External source of heating or cooling	38
5.2 Service temperature	38
5.3 Maximum surface temperature	39
5.3.1 Determination of maximum surface temperature	39
5.3.2 Limitation of maximum surface temperature	39
5.3.3 Small component temperature for Group I or Group II electrical equipment	40
5.3.4 Component temperature of smooth surfaces for Group I or Group II electrical equipment	41
6 Requirements for all equipment	42
6.1 General	42
6.2 Mechanical strength of equipment	42
6.3 Opening times	42
6.4 Circulating currents in enclosures (e.g. of large electric machines)	43
6.5 Gasket retention	43
6.6 Electromagnetic and ultrasonic energy radiating equipment	43
6.6.1 General	43
6.6.2 Radio frequency sources	43
6.6.3 Ultrasonic sources	44
6.6.4 Lasers, luminaires, and other non-divergent continuous wave optical sources	45
7 Non-metallic enclosures and non-metallic parts of enclosures	45
7.1 General	45
7.1.1 Applicability	45
7.1.2 Specification of materials	45
7.2 Thermal endurance	46
7.2.1 Tests for thermal endurance	46
7.2.2 Material selection	46
7.2.3 Alternative qualification of elastomeric sealing O-rings	47
7.3 Resistance to ultraviolet light	47
7.4 Electrostatic charges on external non-metallic materials	47
7.4.1 Applicability	47
7.4.2 Avoidance of a build-up of electrostatic charge for Group I or Group II	48

7.4.3	Avoidance of a build-up of electrostatic charge for Group III	50
7.5	Attached external conductive parts	51
8	Metallic enclosures and metallic parts of enclosures	52
8.1	Material composition	52
8.2	Group I	52
8.3	Group II	52
8.4	Group III	53
8.5	Copper Alloys	53
9	Fasteners	53
9.1	General.....	53
9.2	Special fasteners	54
9.3	Holes for special fasteners.....	54
9.3.1	Thread engagement.....	54
9.3.2	Tolerance and clearance	54
9.4	Hexagon socket set screws.....	55
10	Interlocking devices	55
11	Bushings	55
12	(Reserved for future use).....	55
13	Ex Components	55
13.1	General.....	55
13.2	Mounting.....	56
13.3	Internal mounting	56
13.4	External mounting	56
13.5	Ex Component certificate	56
14	Connection facilities	56
14.1	General.....	56
14.2	Type of protection	56
14.3	Creepage and clearance	57
15	Connection facilities for earthing or bonding conductors	57
15.1	Equipment requiring earthing or bonding.....	57
15.1.1	Internal earthing	57
15.1.2	External bonding.....	57
15.2	Equipment not requiring earthing	57
15.3	Size of protective earthing conductor connection	57
15.4	Size of equipotential bonding conductor connection	58
15.5	Protection against corrosion.....	58
15.6	Secureness of electrical connections	58
15.7	Internal earth continuity plate.....	58
16	Entries into enclosures	58
16.1	General.....	58
16.2	Identification of entries.....	59
16.3	Cable glands.....	59
16.4	Blanking elements.....	59
16.5	Thread adapters	60
16.6	Temperature at branching point and entry point	60
16.7	Electrostatic charges of cable sheaths	60
17	Supplementary requirements for electric machines	61

17.1	General.....	61
17.2	Ventilation.....	61
17.2.1	Ventilation openings	61
17.2.2	Materials for external fans	61
17.2.3	Cooling fans of rotating electric machines.....	61
17.2.4	Auxiliary motor cooling fans	62
17.2.5	Room ventilating fans	62
17.3	Bearings	63
18	Supplementary requirements for switchgear	63
18.1	Flammable dielectric	63
18.2	Disconnectors	63
18.3	Group I – Provisions for locking	64
18.4	Doors and covers.....	64
19	Reserved for future use	64
20	Supplementary requirements for external plugs, socket outlets and connectors for field wiring connection	64
20.1	General.....	64
20.2	Explosive gas atmospheres	65
20.3	Explosive dust atmospheres	65
20.4	Energized plugs	65
21	Supplementary requirements for luminaires	65
21.1	General.....	65
21.2	Covers for luminaires of EPL Mb, EPL Gb, or EPL Db	65
21.3	Covers for luminaires of EPL Gc or EPL Dc	66
21.4	Sodium lamps	66
22	Supplementary requirements for caplights and handlights	66
22.1	Group I caplights	66
22.2	Group II and Group III caplights and handlights	66
23	Equipment incorporating cells and batteries.....	67
23.1	General.....	67
23.2	Interconnection of cells to form batteries.....	67
23.3	Cell types.....	67
23.4	Cells in a battery.....	70
23.5	Ratings of batteries.....	70
23.6	Interchangeability	70
23.7	Charging of primary batteries	70
23.8	Leakage.....	70
23.9	Connections.....	70
23.10	Orientation	70
23.11	Replacement of cells or batteries	71
23.12	Replaceable battery pack.....	71
24	Documentation	71
25	Compliance of prototype or sample with documents.....	71
26	Type tests	71
26.1	General.....	71
26.2	Test configuration	71
26.3	Tests in explosive test mixtures	72
26.4	Tests of enclosures.....	72

26.4.1	Order of tests	72
26.4.2	Resistance to impact	74
26.4.3	Drop test	75
26.4.4	Acceptance criteria	76
26.4.5	Degree of protection (IP) by enclosures	76
26.5	Thermal tests	77
26.5.1	Temperature measurement	77
26.5.2	Thermal shock test	79
26.5.3	Small component ignition test (Group I and Group II)	79
26.6	Torque test for bushings	80
26.6.1	Test procedure	80
26.6.2	Acceptance criteria	81
26.7	Non-metallic enclosures or non-metallic parts of enclosures	81
26.7.1	General	81
26.7.2	Test temperatures	81
26.8	Thermal endurance to heat	81
26.9	Thermal endurance to cold	82
26.10	Resistance to UV light	82
26.10.1	General	82
26.10.2	Light exposure	83
26.10.3	Acceptance criteria	83
26.11	Resistance to chemical agents for Group I equipment	83
26.12	Earth continuity	84
26.13	Surface resistance test of parts of enclosures of non-metallic materials	85
26.14	Measurement of capacitance	86
26.14.1	General	86
26.14.2	Test procedure	86
26.15	Verification of ratings of ventilating fans	87
26.16	Alternative qualification of elastomeric sealing O-rings	87
26.17	Transferred charge test	87
26.17.1	Test equipment	87
26.17.2	Test sample	88
26.17.3	Test procedure	88
27	Routine tests	89
28	Manufacturer's responsibility	90
28.1	Conformity with the documentation	90
28.2	Certificate	90
28.3	Responsibility for marking	90
29	Marking	90
29.1	Applicability	90
29.2	Location	90
29.3	General	90
29.4	Ex marking for explosive gas atmospheres	91
29.5	Ex marking for explosive dust atmospheres	93
29.6	Combined types (or levels) of protection	96
29.7	Multiple types of protection	96
29.8	Ga equipment using two independent Gb types (or levels) of protection	96
29.9	Boundary wall	96

29.10	Ex Components	97
29.11	Small Ex Equipment and small Ex Components	97
29.12	Extremely small Ex Equipment and extremely small Ex Components	97
29.13	Warning markings	98
29.14	Cells and batteries	98
29.15	Electric machines operated with a converter	98
29.16	Examples of marking	99
30	Instructions	102
30.1	General	102
30.2	Cells and batteries	103
30.3	Electric machines	104
30.4	Ventilating fans	104
30.5	Cable glands	105
Annex A	(normative) Supplementary requirements for cable glands	106
A.1	General	106
A.2	Constructional requirements	106
A.2.1	Cable sealing	106
A.2.2	Filling compounds	107
A.2.3	Clamping	107
A.2.4	Lead-in of cable	107
A.2.5	Release by a tool	108
A.2.6	Fixing	108
A.2.7	Degree of protection	108
A.3	Type tests	108
A.3.1	Tests of clamping of non-armoured and braided cables	108
A.3.2	Tests of clamping of armoured cables	111
A.3.3	Type test for resistance to impact	112
A.3.4	Test for degree of protection (IP) of cable glands	113
A.4	Marking	114
A.4.1	Marking of cable glands	114
A.4.2	Identification of cable-sealing rings	114
A.5	Instructions	114
Annex B	(normative) Requirements for Ex Components	116
Annex C	(informative) Example of rig for resistance to impact test	119
Annex D	(informative) Electric machines connected to converters	120
Annex E	(informative) Temperature evaluation of electric machines	121
Annex F	(informative) Guidance flowchart for tests of non-metallic enclosures or non-metallic parts of enclosures (26.4)	124
Annex G	(informative) Guidance flowchart for tests of cable glands	125
Annex H	(informative) Shaft voltages resulting in motor bearing or shaft brush sparking Discharge energy calculation	126
H.1	General	126
H.2	Assessment of the risk of ignition using ignition energy calculation	126
H.3	Shaft voltage determination for a rotating machine	127
H.4	Capacitance "C" calculation for a rotating machine	127
H.5	Energy "E" calculation for a rotating machine	130
H.6	Assessment using reference curves	130

Annex ZA (normative) Normative references to international publications with their corresponding European publications	132
Annex ZY (informative) Additional Information relating to the European ATEX Directive 2014/34/EU	135
Annex ZZ (informative) Relationship between this European Standard and the Essential Requirements of 2014/34/EU [2014 OJ L96] aimed to be covered	144
Bibliography.....	146
Figure 1 – Typical battery examples.....	21
Figure 2 – Typical battery compartment	23
Figure 3 – Typical replaceable battery pack	23
Figure 4 – Tolerances and clearance for threaded fasteners	54
Figure 5 – Contact surface under head of fastener with a reduced shank	55
Figure 6 – Cable gland.....	60
Figure 7 – Conduit entry	60
Figure 8 – Assembly of test sample for earth-continuity test.....	85
Figure 9 – Test piece with painted electrodes	86
Figure 10 – Compression set of an O-ring.....	87
Figure A.1 – Illustration of the terms used for cable glands	107
Figure A.2 – Rounded edge of the point of entry of the flexible cable	108
Figure A.3 – Example of rig for resistance to impact test.....	113
Figure C.1 – Example of rig for resistance to impact test	119
Figure F.1 – Non-metallic enclosures or non-metallic parts of enclosures	124
Figure H.1 – Capacitance stored in bearing clearance of sleeve bearing Between journal and outer bearing housing	129
Figure H.2 – Air-gap between stator and rotor.....	129
Figure H.3 – Typical surfaces that form capacitors from the motor shaft to ground	130
Figure H.4 – Capacitive ignition curves	131
Table 1 – Ambient temperatures in service and additional marking	38
Table 2 – Classification of maximum surface temperatures for Group II electrical equipment.....	39
Table 3 – Assessment of temperature classification according to component size.....	41
Table 4 – Assessment of temperature classification Component surface area $\geq 20 \text{ mm}^2$	41
Table 5 – Threshold power	44
Table 6 – Threshold energy	44
Table 7 – Limitation of surface areas	49
Table 8 – Maximum diameter or width.....	49
Table 9 – Limitation of thickness of non-metallic layer	50
Table 10 – Maximum acceptable transferred charge	50
Table 11 – Maximum capacitance of unearthed conductive parts	52
Table 12 – Minimum cross-sectional area of PE conductors.....	58
Table 13 – Primary cells	67
Table 14 – Secondary cells.....	69

Table 15 – Tests for resistance to impact.....	75
Table 16 – Torque to be applied to the stem of bushing used for connection facilities	80
Table 17 – Thermal endurance test.....	81
Table 18 – Text of warning markings	98
Table 19 – Example of type-test converter parameters.....	104
Table B.1 – Applicability of clauses to Ex Components	116
Table H.1 – Maximum permitted energy	127
Table ZY.1	135
Table ZY.2 – Significant changes with respect to EN 60079-0:2012+A11:.....	136
Table ZZ.1 – Correspondence between this European Standard and Annex II of Directive 2014/34/EU [2014 OJ L96]	144

This document is a preview generated by EVS

INTERNATIONAL ELECTROTECHNICAL COMMISSION

EXPLOSIVE ATMOSPHERES –

Part 0: Equipment – General requirements

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60079-0 has been prepared by IEC technical committee 31: Equipment for explosive atmospheres.

This seventh edition cancels and replaces the sixth edition, published in 2011. This edition constitutes a technical revision.

The significance of the changes between IEC Standard, IEC 60079-0, Edition 6 (2011) and IEC 60079-0, Edition 7 (2017) are as listed below:

Explanation of the significance of the changes	Clause	Type		
		Minor and editorial changes	Extension	Major technical changes
Throughout document, "electrical equipment" replaced by "equipment" where appropriate.	Multiple	X		
Scope List of "Type of "Protection" and "Product" standards combined into one list.	1	X		
Definitions used in multiple sub-parts added. Definitions harmonized across sub-parts and added to 60079-0 where appropriate. Battery definitions updated	3	X		
Clarification of the way that information on process temperature influences can be expressed.	5.1.2	X		
Clarification regarding the determination of service temperatures when dust layers are present	5.2	X		
Clarification on the need to provide service temperature information for Ex Components in the Schedule of Limitations	5.2	X		
Relocation of EPL Da dust layer requirements from IEC 60079-18 & IEC 60079-31	5.3.2.3.1	A1		
Clarified that for EPL Db, a maximum specified dust layer of greater than 200 mm is not permitted as thicker layers have no additional effect on maximum surface temperature.	b)	X		
Added for EPL Db, a dust layer in a specified orientation, marked as T_L	c)		X	
Clarified that for EPL Dc, no dust layer tests are required.	5.3.2.3.3	X		
Clarified that the "temperature" is the temperature of the air surrounding the component	5.3.3	X		
Subdivided section dealing with higher permitted surface temperatures for "smooth" surfaces. Corrected area from 1 000 mm ² to 10 000 mm ² .	5.3.4	X		
Clarified that the "Ex" requirements of IEC 60079 supplement those of the relevant industrial standards.	6.1	X		
Added requirement that where an adhesive is used to secure a gasket, it shall be used within its COT and shall comply with the requirements for cements.	6.5			C1
Requirements relocated to IEC 60079-28	former 6.6.2	A2		
Ultrasonic requirements updated based on latest research work	6.6.3		X	
Added reference to IEC 60079-28	6.6.4	A2		
Material identification parameters have been revised to reflect reasonably obtainable information	7.1.2.2	X		
"RTI-mechanical" has been clarified to include "RTI-mechanical strength" and "RTI-mechanical impact"	7.1.2.2	X		
Material identification parameters have been revised to reflect reasonably obtainable information	7.1.2.3	X		
Relocated information on "cements" from Clause 12.	7.1.2.4	X		
"RTI-mechanical" has been clarified to include "RTI-mechanical strength" and "RTI-mechanical impact". Requirements for cements aligned with the requirements for elastomers.	7.2.2	X		

Explanation of the significance of the changes	Clause	Type		
		Minor and editorial changes	Extension	Major technical changes
Relocation of 10 K margin for EPL Gc or Dc from IEC 60079-15, IEC 60079-18 & IEC 60079-31	7.2.2	A3		
Added clarification with respect to gaskets and seals where only the outer edge is potentially exposed to light.	7.3	X		
Clarification added that one or more of the described techniques may be used	7.4.2	X		
Added additional relaxation for the case where a surface is in contact with an earthed surface on only two of four sides.	7.4.2 b)		X	
Added reference to IEC 60243-1 and IEC 60243-2 for test method to require a 4 kV DC test..	7.4.2.c)			C2
Additional guidance added with respect to the possible Specific Conditions of Use	7.4.2 e)	X		
New option added for portable, mains-powered equipment with earth-connected guard	7.4.2 f)		X	
Added option for determination of maximum transferred charge.	7.4.2 g) Table 10		X	
Added missing limits (same as 7.4.2)	7.4.3 a)	X		
Clarified that it is a dc test that is conducted	7.4.3 b)	X		
Clarified that this requirement is not applied to personal or portable equipment	7.5	X		
Clarified Group I limits	8.2	X		
Clarified Group II, EPL Ga limits	8.3	X		
Added limitation for external surfaces of >65% copper	8.5			C3
Added clarification as to what is considered a tool	9.1	X		
Clarified that the tolerance class of the set screw is not critical, only that it not protrude from the threaded hole after tightening.	9.4	X		
Information on cements transferred to Clause 7	12	X		
Required that Ex Component Certificates require a Schedule of Limitations in all cases	13.5		X	
Revised to clarified that all connection facilities may not be a "Compartment".	14	X		
Sub-clause split to separate the requirements for protective earthing and equipotential bonding into separate sections	15.3 15.4	X		
Section split to separate secureness of electrical connections from the internal earth continuity plate.	15.6 15.7	X		
Non-threaded Group I cable glands are no longer required to be Ex Components.	16.3		X	
Non-threaded Group I blanking elements are no longer required to be Ex Components.	16.4		X	
Scope of Clause 17 clarified to define applicability	17	X		
Additional guidance notes added to address bearings	17.3	X		
Clarified applicability to disconnectors, interlocks, and maintenance switches.	18.2	X		
Fuse requirements deleted as they are addressed in the individual sub-parts	19	X		
Added requirements for EPL Gc and Dc	20.1			C4

Explanation of the significance of the changes	Clause	Type		
		Minor and editorial changes	Extension	Major technical changes
The test circuit requirements for a flameproof connection have been removed as they are more completely specified in IEC 60079-1.	20.2	X		
The impact test requirements for luminaires are relocated to Table 15	21.1 Table 15	X		
Clarified interlock switch operation for flameproof luminaires	21.2	X		
Clarified that some Types of Protection permit connection of cells in parallel	23.2	X		
New cell types and data added based on latest available data	Table 13		X	
New cell types and data added based on latest available data	Table 14			C5
Clarification of what documentation is to be prepared regarding the explosion safety aspects of the equipment	24	X		
Clarification that the type tests are to take into consideration the installation instructions	26.2	X		
Clarification that the "glass" requirements also apply to "ceramic" parts	26.4.1.1	X		
Added a permission to interchange the order of tests at the "lower test temperature" and the "upper test temperature".	26.4.1.2.2 26.4.1.2.3	X		
Clarified the construction of the impact test fixture	26.4.2	X		
Clarified the impact tests for glass parts	26.4.2	X		
Added clarification to deal with the new IPX9 ratings	26.4.5.1		X	
Clarified the test voltage for maximum surface temperature	26.5.1.3	X		
Relocation of EPL Da dust layer requirements from IEC 60079-18 & IEC 60079-31	26.5.1.3	A1		
Relocation of EPL Db specified dust layer requirements from IEC 60079-31	26.5.1.3	A4		
Added for EPL Db, a dust layer in a specified orientation, marked as T_L	26.5.1.3		B1	
Clarified that for EPL Dc, the testing is conducted without a dust layer.	26.5.1.3	X		
Relocation of thermal endurance to heat 10K relaxation for Gc equipment from IEC 60079-15, IEC 60079-18, & IEC 60079-31	Table 17	X		
Clarification of a consistent way to address elastomeric materials exposed to ultraviolet light	26.10	X		
Replacement of "oil No. 2" with the revised designation of "oil IRM 902".	26.11	X		
Option added for testing at lower voltages when low resistance materials are encountered	26.13		X	
Transferred charge test added based on IEC TS 60079-32-2	26.17		X	
The reference to a specific instruction document instead of an "X" condition relocated to e) instead of a note giving a permission	29.3 e)	X		

Explanation of the significance of the changes	Clause	Type		
		Minor and editorial changes	Extension	Major technical changes
Updated to reflect the additional levels of protection already shown in the sub-parts: "da", "dc", "eb", "ec", "oc", "op is", "op pr", "op sh", "pxb", "pyb", "pzc", "qb", "sa", "sb", and "sc".	29.4 b)	X		
Text added to address marking of "Ex associated equipment"	29.4		X	
Updated to reflect the additional levels of protection already shown in the sub-parts: "ic", "op is", "op pr", "op sh", "pxb", "pyb", "pzc", "sa", "sb", and "sc".	29.5 b)	X		
Clarified marking of EPL Da, EPL Db with no dust layer, EPL Db with a specified dust layer, and EPL Dc.	29.5 d)	X		
Introduced marking for EPL Db with a dust layer in a specified orientation	29.5 d)		X	
Text added to address marking of "Ex associated equipment"	29.5		X	
Text added to address marking of equipment intended to be installed in a boundary wall.	29.9		X	
The marking of Ex Component enclosure was aligned with the marking requirements of IEC 60079-1 and IEC 60079-7	29.10	X		
The alternate marking of EPL has been deleted.	former 29.13			C6
Marking for electric machines operated with a converter clarified	29.15	X		
Instruction material guidance clarified	30.1	X		
Additional instruction material for electric machines added	30.3			C7
Additional instruction material for cable glands added	30.5 A.5			C8
Allow ISO 10807 hose assemblies to be used with cable glands.	A.1		X	
Clarify testing with stainless steel mandrels	A.3	X		
Reduction of the time / slippage permitted	A.3.1.1		X	
Clarify impact testing of cable glands	A.3.3 Figure A.3	X		
Clarified the order of tests	A.3.4	X		
Clarified remarks	Annex B	X		
Aligned Figure with text	Figure C.1	X		
Clarified operation of electric machines from converters	Annex D (informative)	X		
Clarified temperature testing of electric machines	Annex E (informative)	X		
Flowchart for Cable Gland testing	Annex G (informative)	X		
Guidance of electric machine shaft voltages	Annex H (informative)	X		

NOTE The technical changes referred to include the significance of technical changes in the revised IEC Standard, but they do not form an exhaustive list of all modifications from the previous version. More guidance may be found by referring to the Redline Version of the standard.

Explanations:**A) Definitions****Minor and editorial changes**

clarification
 decrease of technical requirements
 minor technical change
 editorial corrections

These are changes which modify requirements in an editorial or a minor technical way. They include changes of the wording to clarify technical requirements without any technical change, or a reduction in level of existing requirement.

Extension

addition of technical options

These are changes which add new or modify existing technical requirements, in a way that new options are given, but without increasing requirements for equipment that was fully compliant with the previous standard. Therefore, these will not have to be considered for products in conformity with the preceding edition.

Major technical changes

addition of technical requirements
 increase of technical requirements

These are changes to technical requirements (addition, increase of the level or removal) made in a way that a product in conformity with the preceding edition will not always be able to fulfil the requirements given in the later edition. These changes have to be considered for products in conformity with the preceding edition. For these changes additional information is provided in clause B) below.

NOTE These changes represent current technological knowledge. However, these changes should not normally have an influence on equipment already placed on the market.

B) Information about the background of changes

- A1 The dust layer requirements for EPL Da are unchanged from what previously existed in IEC 60079-18, Ed 4 and IEC 60079-31, Ed 2, but have been relocated to IEC 60079-0 to allow consistent application in all Types of Protection.
- A2 IEC 60079-28 now includes all requirements for optical radiation for all EPLs.
- A3 The COT requirements for EPL Gc or Dc are unchanged from what previously existed in IEC 60079-15, Ed 4, IEC 60079-18, Ed 4, and IEC 60079-31, Ed 2, but have been relocated to IEC 60079-0 to allow consistent application in all Types of Protection.
- A4 The dust layer requirements for EPL Db with a specified dust layer depth are unchanged from what previously existed in IEC 60079-31, Ed 2, but have been relocated to IEC 60079-0 to allow consistent application in all Types of Protection.
- B1 Dust layer requirements for EPL Db with a dust layer in a specified orientation have been added.
- C1 It is recognized that the new requirements were, in many cases, already applied. The change is to ensure that they are uniformly and consistently applied.
- C2 Require that the test be conducted at 4 kV DC.
- C3 The limitation applies to external surfaces of other than cable glands, blanking elements, thread adapters and bushings.
- C4 The added requirements for tool securing and marking are consistent with the approach in IEC 60079-15

- C5 Voltage values were changed following additional research due to the complicated assessment and sometimes unspecified construction of Li/Ion-cells. It was found that some voltage values previously stated were too low.
- C6 The now required EPL marking may be other than that permitted by the Level of Protection to account for limiting restrictions of material or plastic material surface area.
- C7 Additional instruction material for electric machines required to facilitate selection, installation, and maintenance.
- C8 Additional instruction material for cable glands required to facilitate selection and installation.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
31/1345/FDIS	31/1356/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the IEC 60079 series, under the general title *Explosive atmospheres*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

The contents of the interpretation sheet 1 of April 2019 and interpretation sheet 2 of June 2019 have been included in this copy.

The contents of the corrigendum of January 2020 have been included in this copy.

EXPLOSIVE ATMOSPHERES –

Part 0: Equipment – General requirements

1 Scope

This part of IEC 60079 specifies the general requirements for construction, testing and marking of Ex Equipment and Ex Components intended for use in explosive atmospheres.

The standard atmospheric conditions (relating to the explosion characteristics of the atmosphere) under which it may be assumed that Ex Equipment can be operated are:

- temperature -20 °C to $+60\text{ °C}$;
- pressure 80 kPa (0,8 bar) to 110 kPa (1,1 bar); and
- air with normal oxygen content, typically 21 % v/v.

This part of IEC 60079 and other standards supplementing this standard specify additional test requirements for Ex Equipment operating outside the standard temperature range, but further additional consideration and additional testing may be required for Ex Equipment operating outside the standard atmospheric pressure range and standard oxygen content. Such additional testing may be particularly relevant with respect to Types of Protection that depend on quenching of a flame such as 'flameproof enclosures "d"' (IEC 60079-1) or limitation of energy, 'intrinsic safety "i"' (IEC 60079-11).

NOTE 1 Although the standard atmospheric conditions above give a temperature range for the atmosphere of -20 °C to $+60\text{ °C}$, the normal ambient temperature range for the Ex Equipment is -20 °C to $+40\text{ °C}$, unless otherwise specified and marked. See 5.1.1. It is considered that -20 °C to $+40\text{ °C}$ is appropriate for many items of Ex Equipment and that to manufacture all Ex Equipment to be suitable for a standard atmosphere upper ambient temperature of $+60\text{ °C}$ would place unnecessary design constraints.

NOTE 2 Requirements given in this standard result from an ignition hazard assessment made on equipment. The ignition sources taken into account are those found associated with this type of equipment, such as hot surfaces, electromagnetic radiation, mechanically generated sparks, mechanical impacts resulting in thermite reactions, electrical arcing and static electric discharge in normal industrial environments.

NOTE 3 Where an explosive gas atmosphere and a combustible dust atmosphere are, or can be, present at the same time, the simultaneous presence of both often warrants additional protective measures. Additional guidance on the use of Ex Equipment in hybrid mixtures (mixture of a flammable gas or vapour with a combustible dust or combustible flyings) is given in IEC 60079-14.

IEC 60079 does not specify requirements for safety, other than those directly related to the explosion risk.

Ignition sources like adiabatic compression, shock waves, exothermic chemical reaction, self-ignition of dust, naked flames and hot gases/liquids, are not addressed by this standard.

NOTE 4 Although outside the scope of this standard, such equipment would typically be subjected to a hazard analysis that identifies and lists all of the potential sources of ignition by the equipment and the measures to be applied to prevent them becoming effective. See ISO/IEC 80079-36.

This document is supplemented or modified by the following parts and technical specifications:

- IEC 60079-1: Gas – Flameproof enclosures "d";
- IEC 60079-2: Gas and dust – Pressurized enclosure "p";
- IEC 60079-5: Gas – Powder filling "q";
- IEC 60079-6: Gas – Liquid immersion "o";
- IEC 60079-7: Gas – Increased safety "e";

- IEC 60079-11: Gas and dust – Intrinsic safety "i";
- IEC 60079-13: Gas and dust – Equipment protection by pressurized room "p" & artificially ventilated room "v";
- IEC 60079-15: Gas – Type of protection "n";
- IEC 60079-18: Gas and dust – Encapsulation "m";
- IEC 60079-25: Gas and dust – Intrinsically safe electrical systems
- IEC 60079-26: Gas – Equipment with equipment protection level (EPL) Ga
- IEC 60079-28: Gas and dust – Protection of equipment and transmission systems using optical radiation
- IEC 60079-29-1: Gas detectors – Performance requirements of detectors for flammable gases
- IEC 60079-29-4: Gas detectors – Performance requirements of open path detectors for flammable gases
- IEC/IEEE 60079-30-1: Gas and dust – Electrical resistance trace heating – General and testing requirements.
- IEC 60079-31: Dust – Protection by enclosure "t"
- IEC 60079-33: Gas and dust – Special protection "s"
- IEC 60079-35-1: Caplights for use in mines susceptible to firedamp – General requirements – Construction and testing in relation to the risk of explosion
- IEC TS 60079-39: Gas – Intrinsically safe systems with electronically controlled spark duration limitation
- IEC TS 60079-40: Gas – Requirements for process sealing between flammable process fluids and electrical systems
- ISO 80079-36: Gas and dust – Non-electrical equipment for explosive atmospheres – Basic method and requirements

This document, along with the additional parts of IEC 60079 mentioned above, is not applicable to the construction of

- electromedical apparatus,
- shot-firing exploders,
- test devices for exploders, and
- shot-firing circuits.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60034-1, *Rotating electrical machines – Part 1: Rating and performance*

IEC 60034-5, *Rotating electrical machines – Part 5: Degrees of protection provided by the integral design of rotating electrical machines (IP code) – Classification*

IEC 60079-1, *Explosive atmospheres – Part 1: Equipment protection by flameproof enclosures "d"*

IEC 60079-20-1, *Explosive atmospheres – Part 20-1: Material characteristics for gas and vapour classification – Test methods and data*

IEC 60079-26, *Explosive atmospheres – Part 26: Equipment with Equipment Protection Level (EPL) Ga*

IEC 60079-35-1, *Explosive atmospheres – Part 35-1: Caplights for use in mines susceptible to firedamp – General requirements – Construction and testing in relation to the risk of explosion*

IEC 60086-1, *Primary batteries – Part 1: General*

IEC 60192, *Low-pressure sodium vapour lamps – Performance specifications*

IEC 60216-1, *Electrical insulating materials – Thermal endurance properties – Part 1: Ageing procedures and evaluation of test results*

IEC 60216-2, *Electrical insulating materials – Thermal endurance properties – Part 2: Determination of thermal endurance properties of electrical insulating materials – Choice of test criteria*

IEC 60243-1, *Electric strength of insulating materials – Test methods – Part 1: Tests at power frequencies*

IEC 60423, *Conduit systems for cable management – Outside diameters of conduits for electrical installations and threads for conduits and fittings*

IEC 60529, *Degrees of protection provided by enclosures (IP Code)*

IEC 60662, *High-pressure sodium vapour lamps – Performance specifications*

IEC 60664-1, *Insulation coordination for equipment within low-voltage systems – Part 1: Principles, requirements and tests*

IEC 60947-1, *Low-voltage switchgear and controlgear – Part 1: General rules*

IEC 62626-1, *Low-voltage switchgear and controlgear enclosed equipment – Part 1: Enclosed switch-disconnectors outside the scope of IEC 60947-3 to provide isolation during repair and maintenance work*

ISO 48, *Rubber, vulcanized or thermoplastic – Determination of hardness (hardness between 10 IRHD and 100 IRHD)*

ISO 178, *Plastics – Determination of flexural properties*

ISO 179 (all parts), *Plastics – Determination of Charpy impact properties*

ISO 262, *ISO general-purpose metric screw threads – Selected sizes for screws, bolts and nuts*

ISO 273, *Fasteners – Clearance holes for bolts and screws*

ISO 527-2, *Plastics – Determination of tensile properties – Part 2: Test conditions for moulding and extrusion plastics*

ISO 965-1, *ISO general-purpose metric screw threads – Tolerances – Part 1: Principles and basic data*

ISO 965-3, *ISO general-purpose metric screw threads – Tolerances – Part 3: Deviations for constructional screw threads*

ISO 3601-1, *Fluid power systems – O-rings – Part 1: Inside diameters, cross-sections, tolerances and designation codes*

ISO 3601-2, *Fluid power systems – O-rings – Part 2: Housing dimensions for general applications*

ISO 4014, *Hexagon head bolts – Product grades A and B*

ISO 4017, *Hexagon head screws – Product grades A and B*

ISO 4026, *Hexagon socket set screws with flat point*

ISO 4027, *Hexagon socket set screws with cone point*

ISO 4028, *Hexagon socket set screws with dog point*

ISO 4029, *Hexagon socket set screws with cup point*

ISO 4032, *Hexagon nuts, style 1 – Product grades A and B*

ISO 4762, *Hexagon socket head cap screws*

ISO 4892-2, *Plastics – Methods of exposure to laboratory light sources – Part 2: Xenon-arc lamps*

ISO 7380, *Hexagon socket button head screws*

ISO 14583, *Hexalobular socket pan head screws*

ANSI/UL 746B, *Polymeric Materials – Long-Term Property Evaluations*

ANSI/UL 746C, *Polymeric Materials – Used in Electrical Equipment Evaluations*

ASTM D5964, *Standard practice for rubber IRM 901, IRM 902, and IRM 903 replacement oils for ASTM No. 1, ASTM No. 2, and ASTM No. 3*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

NOTE Additional definitions applicable to explosive atmospheres can be found in IEC 60050-426.

3.1

ambient temperature

temperature of the air or other media, in the immediate vicinity of the equipment or component

Note 1 to entry: This does not refer to the temperature of any process media, unless the equipment or component is totally immersed in the process media. See 5.1.1.