

NÕUDED MAJAPIDAMIS- JA MUUDES TAOLISTES
PAIGALDISTES KASUTATAVATE KAITSELÜLITITE NING
LIIGVOOLUVABASTIGA JA LIIGVOOLUVABASTITA
RIKKEVOOLUKAITSELÜLITITE AUTOMAATSETELE
TAASLÜLITUSSEADISTELE

Requirements for automatic reclosing devices (ARDs)
for circuit-breakers, RCBOs and RCCBs for household
and similar uses

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 63024:2018 sisaldab Euroopa standardi EN 63024:2018 ingliskeelset teksti.	This Estonian standard EVS-EN 63024:2018 consists of the English text of the European standard EN 63024:2018.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 27.04.2018.	Date of Availability of the European standard is 27.04.2018.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 29.120.50

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:

Koduleht www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:

Homepage www.evs.ee; phone +372 605 5050; e-mail info@evs.ee

English Version

Requirements for automatic reclosing devices (ARDs) for circuit-breakers, RCBOs and RCCBs for household and similar uses (IEC 63024:2017)

Exigences pour les dispositifs à refermeture automatique
(DRA) pour disjoncteurs, ID et DD, pour usages
domestiques et analogues
(IEC 63024:2017)

Anforderungen an automatische
Wiedereinschaltvorrichtungen für Leitungsschutzschalter,
RCBOs, RCCBs für Hausinstallationen und ähnliche
Zwecke
(IEC 63024:2017)

This European Standard was approved by CENELEC on 2018-01-17. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

European foreword

The text of document 23E/1037/FDIS, future edition 1 of IEC 63024, prepared by IEC/SC 23E "Circuit-breakers and similar equipment for household use" of IEC/TC 23 "Electrical accessories" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 63024:2018.

A draft amendment, which covers common modifications to IEC 63024 (23E/1037/FDIS), was prepared by CLC/TC 23E "Circuit breakers and similar devices for household and similar applications" and approved by CENELEC.

The following dates are fixed:

- latest date by which this document has to (dop) 2019-01-17
be implemented at national level by
publication of an identical national
standard or by endorsement
- latest date by which the national (dow) 2021-01-17
standards conflicting with this document
have to be withdrawn

This document supersedes EN 50557:2011.

Clauses, subclauses, notes, tables, figures and annexes which are additional to those in IEC 63024:2017 are prefixed "Z".

This standard covers the Principle Elements of the Safety Objectives for Electrical Equipment Designed for Use within Certain Voltage Limits (LVD - 2014/35/EU).

This document has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directive(s).

For the relationship with EU Directive(s) see informative Annex ZZA and Annex ZZB, which are integral parts of this document.

Endorsement notice

The text of the International Standard IEC 63024:2017 was approved by CENELEC as a European Standard with agreed common modifications.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 60085	NOTE Harmonized as EN 60085.
IEC 60112:2003	NOTE Harmonized as EN 60112:2003 (not modified).
IEC 60112:2003/AMD1:2009	NOTE Harmonized as EN 60112:2003/A1:2009 (not modified).
IEC 60364-6:2006	NOTE Harmonized as HD 60364-6:2007 (modified).
IEC 60384-14:2013	NOTE Harmonized as EN 60384-14:2013 (not modified).
IEC 60695-2-10:2013	NOTE Harmonized as EN 60695-2-10:2013 (not modified).
IEC 60998-2-3	NOTE Harmonized as EN 60998-2-3.
IEC 61000-3-2	NOTE Harmonized as EN 61000-3-2.
IEC 61000-3-3	NOTE Harmonized as EN 61000-3-3.
IEC 62423	NOTE Harmonized as EN 62423

Common modifications

4 Classification

Add a new subclause after 4.7:

4.Z1 According to the range of ambient air temperature (only for ARD according to 4.2.2 and 4.2.3)

4.Z1.1 ARD for use at ambient air temperatures between -5 °C and +40 °C;

4.Z1.2 ARD for use at ambient air temperatures between -25 °C and +40 °C.

6 Marking and other product information

6.1 Standard marking

Add the following new item:

p) for ARD classified according to 4.Z1.2, ambient air temperature with the symbol (the value -25 included in the snow flake symbol according to ISO 7000:2014, Figure 0027). For devices according to 4.1.2, the information of the ambient air temperature shall not be visible after assembly.

8 Requirements for construction and operation

8.1 Mechanical design

8.1.1 General

Add at the end of the subclause the following new text:

“ARD shall be assembled only with main MPDs having a higher or equal range of ambient air temperature (see 4.Z1).”

Add a new subclause after 8.15:

8.Z1 Behaviour at low ambient air temperature

ARD classified according to 4.2.2 and 4.2.3 for use in the range of -25 °C to +40 °C shall operate reliably at low temperatures.

For the ARD+MPD, the relevant subclauses of the MPD standard applies:

- a) EN 61008-1:2004, 8.Z1, for ARD classified according to 4.2.2 (RCCBs);
- b) EN 61009-1:2004, 8.Z1, for ARD classified according to 4.2.3 (RCBOs).

Compliance is checked by the test of 9.18.

9 Tests

9.18 Verification of the operating characteristics

9.18.3 Verification of the reclosing subordinated to the measurements of the resistance between live parts

Add at the end of Subclause 9.18.3 the following new text:

RCDs classified in according with 4.Z1.2 shall also perform the test with an ambient temperature of $(-25 \pm 2) ^\circ\text{C}$.

9.22.5 Electromagnetic emission of ARDs

Add at the end of the clause the following text:

The text on the statistical evaluation of mass produced products in Clause 7 of CISPR 14-1 does not apply.

This document is a preview generated by EVS

Table D.1 - Test sequences

Add a new row at the end of to the table as follows:

I	6.1 p) 9.18.3 (last paragraph)	Verification of the correct operation at low ambient air temperatures for RCCBs for use at temperatures between -25 °C and +40 °C
---	---	---

Add the following annexes:

Annex ZA (normative) Normative references to international publications with their corresponding European publications

Annex ZZA (informative) Relationship between this European standard and the essential requirements of Directive 2014/30/EU [2014 OJ L96] aimed to be covered

Annex ZZB (informative) Relationship between this European standard and the safety objectives of Directive 2014/35/EU [2014 OJ L96] aimed to be covered

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 Where an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60065 (mod)	2014	Audio, video and similar electronic apparatus - Safety requirements	EN 60065	2014
IEC 60384	Series	Fixed capacitors for use in electronic equipment - Part 9: Sectional specification: Fixed capacitors of ceramic dielectric, Class 2	EN 60384	Series
IEC 60664-1	2007	Insulation coordination for equipment within low-voltage systems - Part 1: Principles, requirements and tests	EN 60664-1	2007
IEC 60664-3	-	Insulation coordination for equipment within low-voltage systems - Part 3: Use of coating, potting or moulding for protection against pollution	EN 60664-3	2017
IEC 60898-1	2015	Electrical accessories - Circuit-breakers for overcurrent protection for household and similar installations - Part 1: Circuit-breakers for a.c. operation	-	-
IEC 60898-2	2016	Circuit-breakers for overcurrent protection for household and similar installations - Part 2: Circuit-breakers for a.c. and d.c. operation	-	-
IEC 60947-5-1	-	Low-voltage switchgear and controlgear - Part 5-1: Control circuit devices and switching elements - Electromechanical control circuit devices	EN 60947-5-1	2016
IEC 60950-1 (mod)	-	Information technology equipment - Safety - Part 1: General requirements	EN 60950-1	2006
IEC 61000-4-2	-	Electromagnetic compatibility (EMC) - Part 4-2: Testing and measurement techniques - Electrostatic discharge immunity test	EN 61000-4-2	2009
IEC 61000-4-3	-	Electromagnetic compatibility (EMC) - Part 4-3: Testing and measurement techniques - Radiated, radio-frequency, electromagnetic field immunity test	EN 61000-4-3	2006

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 61000-4-4	-	Electromagnetic compatibility (EMC) - Part 4-4: Testing and measurement techniques - Electrical fast transient/burst immunity test	EN 61000-4-4	2012
IEC 61000-4-5	-	Electromagnetic compatibility (EMC) - Part 4-5: Testing and measurement techniques - Surge immunity test	EN 61000-4-5	2014
IEC 61000-4-6	-	Electromagnetic compatibility (EMC) - Part 4-6: Testing and measurement techniques - Immunity to conducted disturbances, induced by radio-frequency fields	EN 61000-4-6	2014
IEC 61000-4-16	-	Electromagnetic compatibility (EMC) - Part 4-16: Testing and measurement techniques - Test for immunity to conducted, common mode disturbances in the frequency range 0 Hz to 150 kHz	EN 61000-4-16	2016
IEC 61008-1 (mod)	2010	Residual current operated circuit-breakers without integral overcurrent protection for household and similar uses (RCCB's) - Part 1: General rules	EN 61008-1	2012
+A1 (mod)	2012		+A1	2014
+A2 (mod)	2013		+A2	2014
IEC 61009-1 (mod)	2010	Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBOs) - Part 1: General rules	EN 61009-1	2012
+A1 (mod)	2012		+A1	2014
+A2 (mod)	2013		+A2	2014
IEC 61189-2	-	Test methods for electrical materials, printed boards and other interconnection structures and assemblies - Part 2: Test methods for materials for interconnection structures	EN 61189-2	2006
IEC 61543	1995	Residual current-operated protective devices (RCDs) for household and similar use - Electromagnetic compatibility	EN 61543	1995
+A1	2004		+ A11	2003
+A2	2005		+A2	2006
IEC 61558	Series	Safety of transformers, reactors, power supply units and combinations thereof	EN 61558	Series
IEC 62019	-	Electrical accessories - Circuit-breakers and similar equipment for household use - Auxiliary contact units	EN 62019	1999
CISPR 14-1	-	Electromagnetic compatibility - Requirements for household appliances, electric tools and similar apparatus - Part 1: Emission	EN 55014-1	2017
ISO 7000	2014	Graphical symbols for use on equipment - Registered symbols	-	-

Annex ZZA (informative)

Relationship between this European standard and the essential requirements of Directive 2014/30/EU [2014 OJ L96] aimed to be covered

This European standard has been prepared under the European Commission standardisation request C(2016) 7641 final of 30.11.2016¹, ('M/552'), as regards harmonised standards in support of Directive 2014/30/EU relating to electromagnetic compatibility, to provide one voluntary means of conforming to essential requirements of Directive 2014/30/EU of the European Parliament and of the Council of 26 February 2014 on the harmonisation of the laws of the Member States relating to electromagnetic compatibility [2014 OJ L96].

Once this standard is cited in the Official Journal of the European Union under that Directive, compliance with the normative clauses of this standard given in Table ZZA.1 confers, within the limits of the scope of this standard, a presumption of conformity with the corresponding essential requirements of that Directive, and associated EFTA regulations.

Table ZZA.1 – Correspondence between this European standard and the Essential Requirements set out in Directive 2014/30/EU [2014 OJ L96]

Essential requirements of Directive 2014/30/EU	Clause(s) / sub-clause(s) of this EN	Remarks / Notes
Annex I. 1(a) (electromagnetic disturbances)	9.22.5	For CISPR 14-1, the text on the statistical evaluation of mass produced products in Clause 7 does not apply.
Annex I. 1(b) (electromagnetic immunity)	8.15-9.22	

WARNING 1: Presumption of conformity stays valid only as long as a reference to this European standard is maintained in the list published in the Official Journal of the European Union. Users of this standard should consult frequently the latest list published in the Official Journal of the European Union.

WARNING 2: Other Union legislation may be applicable to the product(s) falling within the scope of this standard.

¹ COMMISSION IMPLEMENTING DECISION C(2016) 7641 final of 30.11.2016 on a standardisation request to the European Committee for Standardisation, to the European Committee for Electrotechnical Standardisation and to the European Telecommunications Standards Institute as regards harmonised standards in support of Directive 2014/30/EU of the European Parliament and of the Council of 26 February 2014 on the harmonisation of the laws of the Member States relating to electromagnetic compatibility.

Annex ZZB (informative)

Relationship between this European standard and the safety objectives of Directive 2014/35/EU [2014 OJ L96] aimed to be covered

This European Standard has been prepared under a Commission's standardization request relating to harmonized standards in the field of the Low Voltage Directive, M/511, to provide one voluntary means of conforming to safety objectives of Directive 2014/35/EU of the European Parliament and of the Council of 26 February 2014 on the harmonization of the laws of the Member States relating to the making available on the market of electrical equipment designed for use within certain voltage limits [2014 OJ L96].

Once this standard is cited in the Official Journal of the European Union under that Directive, compliance with the normative clauses of this standard given in Table ZZB.1 confers, within the limits of the scope of this standard, a presumption of conformity with the corresponding essential requirements of that Directive, and associated EFTA regulations.

Table ZZB.1 – Correspondence between this European standard and Article 3 of Directive 2014/35/EU [2014 OJ L153]

Safety Objectives of Directive 2014/35/EU	Clause(s) / sub-clause(s) of this EN	Remarks / Notes
(1)(a)	1, 2, 3, 4, 5, 6 - 9.4	
(1)(b)	6.2, 8.1.1, 8.1.2.1, 8.1.2.2 and 9.5.1	
(1)(c)	7, 8.1.2.8, 8.10, 8.11, 8.15, 9.5.2, 9.5.4, 9.7.4, 9.13, 9.18.1, 9.18.2, 9.18.3, 9.19.1, 9.19.2 and 9.22	
(2) (a)	8.2, 8.5, 9.3, 8.10.8, 8.11, 8.13, 8.14, 9.1, 9.7.4, 9.13, 9.18.4, 9.19.1, 9.19.2, 9.20 and 9.21	
(2) (b)	8.1.5, 8.1.6, 8.4, 9.8, 9.9 and 9.12	
(2) (c)	8.1.2.3, 8.1.2.4, 8.1.2.5, 9.5.2 and 9.5.3	
(2) (d)	8.1.3, 8.1.4, 8.3, 9.6, 9.7 and 9.11	
(3) (a)	8.7 - 9.15	
(3) (b)	8.8, 8.9, 8.15, 9.16, 9.17 and 9.22	
(3) (c)	8.6, 8.12, 9.14 and 9.17	

WARNING 1 — Presumption of conformity stays valid only as long as a reference to this European standard is maintained in the list published in the Official Journal of the European Union. Users of this standard should consult frequently the latest list published in the Official Journal of the European Union.

WARNING 2 — Other Union legislation may be applicable to the product(s) falling within the scope of this standard.

CONTENTS

FOREWORD.....	6
INTRODUCTION.....	8
1 Scope.....	9
2 Normative references	9
3 Terms and definitions	11
4 Classification.....	13
4.1 According to the method of construction	13
4.2 According to the associated MPD.....	13
4.3 According to the type of assessment means	13
4.4 According to the safety means during the assessment.....	14
4.5 According to the connection to FE.....	14
4.6 According to maximum number of reclosing operations	14
4.7 According to mechanical interlock between MPD operating means and ARD enabling/disabling system	14
5 Characteristics	14
5.1 Summary of characteristics.....	14
5.2 Rated quantities	14
5.2.1 Rated voltage	14
5.2.2 Rated operational voltage (U_e).....	15
5.2.3 Rated frequency.....	15
5.2.4 Rated non-operating resistance to earth (R_{d0}).....	15
5.2.5 Rated operating resistance to earth (R_d)	15
5.2.6 Rated non-operating resistance between live parts (R_{CC0}).....	15
5.2.7 Rated operating resistance between live parts (R_{CC})	16
6 Marking and other product information	16
6.1 Standard marking.....	16
6.2 Instructions for assembly and operation	17
7 Standard conditions for operation in service.....	18
7.1 General.....	18
7.2 Conditions of installation	18
7.3 Pollution degree	18
8 Requirements for construction and operation	18
8.1 Mechanical design	18
8.1.1 General	18
8.1.2 Mechanism	19
8.1.3 Clearances and creepage distances	20
8.1.4 Clearances and creepage distances for electronic circuits connected between live parts or between live parts and the earth.....	20
8.1.5 Screws, current-carrying parts and connections	22
8.1.6 Terminals for external conductors	22
8.2 Protection against electric shock.....	22
8.3 Dielectric properties and isolating capability.....	23
8.4 Temperature rise.....	23
8.5 Mechanical and electrical endurance	23
8.6 Performance at short-circuit currents	23
8.7 Resistance to mechanical shock and impact.....	23

8.8	Resistance to heat.....	23
8.9	Resistance to abnormal heat and to fire	24
8.10	Operating characteristics.....	24
8.11	Assessment means for ARD according to 4.3.2.....	25
8.11.1	General	25
8.11.2	Assessment means operating by limitation of the test voltage	25
8.11.3	Assessment means operating by limitation of the test current	25
8.12	Safety in blocked condition	26
8.13	Test device	26
8.14	Ageing	26
8.15	Electromagnetic compatibility (EMC).....	26
9	Tests	26
9.1	General.....	26
9.2	Test condition	26
9.3	Measurement of the reclosing time after the tripping of the MPD	27
9.4	Test of indelibility of marking	27
9.5	Verification of the non-influence of the ARD on the correct operation of the MPD	27
9.5.1	Verification of the operating characteristics of the MPD	27
9.5.2	Verification of the impossibility of the activation of the ARD when the MPD has been manually opened.....	28
9.5.3	Verification of the enabling/disabling system of the ARD.....	28
9.5.4	Verification of the maximum number of consecutive reclosings	28
9.6	Tests of creepage distances and clearances for electronic circuits (abnormal conditions)	29
9.7	Requirements for capacitors, specific resistors and inductors used in electronic circuits	32
9.7.1	General	32
9.7.2	Capacitors	32
9.7.3	Resistors	32
9.7.4	Inductors and windings	33
9.8	Test of reliability of screws, current-carrying parts and connections	33
9.9	Test of reliability of terminals for external conductors.....	33
9.10	Verification of protection against electric shock.....	33
9.11	Test of dielectric properties and isolating capability	33
9.12	Temperature rise	34
9.13	Verification of the mechanical and electrical endurance – Verification of the reclosing system of the ARD	34
9.13.1	General test conditions	34
9.13.2	Test procedure	34
9.13.3	Condition of the ARD after the test	34
9.14	Short-circuit test	35
9.14.1	General conditions for short-circuit test.....	35
9.14.2	Test circuit and test quantities	35
9.14.3	Test procedure	35
9.14.4	Condition of the ARD after the test	35
9.15	Resistance to mechanical shock and impact	36
9.16	Test of resistance to heat.....	36
9.17	Resistance to abnormal heat and to fire	36
9.18	Verification of the operating characteristics.....	36

9.18.1	General	36
9.18.2	Verification of the reclosing subordinated to the measurements of the resistance to earth	36
9.18.3	Verification of the reclosing subordinated to the measurements of the resistance between live parts.....	37
9.18.4	Verification of the influence of the distributed capacities in the installation on the operating characteristic	37
9.18.5	Verification of the maximum current in FE under normal condition	37
9.19	Verification of the safety during the assessment	38
9.19.1	Verification of the limitation of the voltage	38
9.19.2	Verification of the limitation of the test current	38
9.19.3	Verification of the safety in blocked condition	38
9.20	Verification of the operation of the test device at the limits of rated voltage.....	39
9.21	Verification of ageing	39
9.22	Electromagnetic compatibility.....	39
9.22.1	General	39
9.22.2	Low-frequency electromagnetic phenomena	39
9.22.3	High-frequency immunity	40
9.22.4	Electrostatic discharges.....	41
9.22.5	Electromagnetic emission of ARDs	41
9.22.6	Performance criteria	41
Annex A (informative)	Classification of ARDs according to 4.3.1	48
Annex B (informative)	Classification of ARDs according to 4.3.2.1 a) and/or 4.3.2.2 a)	49
Annex C (informative)	Classification of ARDs according to 4.3.2.1 b) and/or 4.3.2.2 b)	50
Annex D (normative)	Test sequences and number of samples to be submitted for verification of conformity	51
Bibliography	54
Figure 1	– Minimum creepage distances and clearances measured	42
Figure 2	– Minimum creepage distances and clearances as a function of peak value of operating voltage	43
Figure 3	– Verification of the reclosing subordinated to the measurements of the resistance to earth for ARD without functional earthing (9.18.2 a), 9.18.2 b) and 9.19.2)	44
Figure 4	– Verification of the reclosing subordinated to the measurements of the resistance to earth for ARD with functional earthing (9.18.2 a), 9.18.2 b) and 9.19.2)	45
Figure 5	– Verification of the reclosing subordinated to the measurements of the resistance between live parts (9.18.3 a) and 9.18.3 b))	46
Figure 6	– Test circuit for the verification of the maximum current in FE under normal condition	47
Figure A.1	– Classification of ARDs according to 4.3.1.....	48
Figure B.1	– Classification of ARDs according to 4.3.2.1 a) and/or 4.3.2.2 a).....	49
Figure C.1	– Classification of ARDs according to 4.3.2.1 b) and/or 4.3.2.2 b).....	50
Table 1	– Minimum admissible R_d values	15
Table 2	– Minimum clearances and creepage distances	21
Table 3	– Behaviour of the ARD in enable condition	25
Table 4	– Maximum permissible temperatures under abnormal conditions	31
Table 5	– Low frequency immunity test conditions	40