

Heating boilers. Part 4: Heating boilers with forced draught burners - Special requirements for boilers with forced draught oil burners with outputs up to 70 kW and a maximum operating pressure of 3 bar - Terminology, special requirements, testing and marking

Heating boilers - Part 4: Heating boilers with forced draught burners - Special requirements for boilers with forced draught oil burners with outputs up to 70 kW and a maximum operating pressure of 3 bar - Terminology, special requirements, testing and marking

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

<p>Käesolev Eesti standard EVS-EN 303-4:2001 sisaldab Euroopa standardi EN 303-4:1999 ingliskeelset teksti.</p> <p>Käesolev dokument on jõustatud 18.06.2001 ja selle kohta on avaldatud teade Eesti standardiorganisatsiooni ametlikus väljaandes.</p> <p>Standard on kättesaadav Eesti standardiorganisatsioonist.</p>	<p>This Estonian standard EVS-EN 303-4:2001 consists of the English text of the European standard EN 303-4:1999.</p> <p>This document is endorsed on 18.06.2001 with the notification being published in the official publication of the Estonian national standardisation organisation.</p> <p>The standard is available from Estonian standardisation organisation.</p>
--	---

<p>Käsitlusala: This standard is applicable to heating boilers with forced draught oil burners up to a nominal heat output of 70 kW. They are operated, either with negative pressure (natural draught boiler) or with positive pressure (pressurised boiler) in the combustion chamber, in accordance with the boiler manufacturer's instructions.</p>	<p>Scope: This standard is applicable to heating boilers with forced draught oil burners up to a nominal heat output of 70 kW. They are operated, either with negative pressure (natural draught boiler) or with positive pressure (pressurised boiler) in the combustion chamber, in accordance with the boiler manufacturer's instructions.</p>
--	--

ICS 01.040.91, 91.140.10

Võtmesõnad: boilers, cast iron, central heating, chemical composition, copper, definitions, dimensions, equipment specification, marking, materials, mechanical properties, performance evaluation, production control, specifications, steels, tests, welded joints, welding

English version

Heating boilers

Part 4: Heating boilers with forced draught burners – Special requirements for boilers with forced draught oil burners with outputs up to 70 kW and a maximum operating pressure of 3 bar – Terminology, special requirements, testing and marking

Chaudières de chauffage – Partie 4:
Chaudières avec brûleurs à air soufflé –
Exigences spécifiques pour chaudières
avec brûleurs fioul à air soufflé avec
une puissance utile jusqu'à 70 kW et
une pression de service maximale de
3 bar – Terminologie, prescriptions
spéciales, essais et marquage

Heizkessel – Teil 4: Heizkessel mit
Gebläsebrenner – Spezielle
Anforderungen an Heizkessel mit
Ölgebläsebrenner mit einer Leistung
von 70 kW und einem maximalen
Betriebsdruck von 3 bar – Begriffe,
besondere Anforderungen, Prüfung
und Kennzeichnung

This European Standard was approved by CEN on 1998-06-06.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CEN member.

The European Standards exist in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the Central Secretariat has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, the Czech Republic, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, the Netherlands, Norway, Portugal, Spain, Sweden, Switzerland, and the United Kingdom.

CEN

European Committee for Standardization
Comité Européen de Normalisation
Europäisches Komitee für Normung

Central Secretariat: rue de Stassart 36, B-1050 Brussels

Contents

	Page
Foreword	2
1 Scope	3
2 Normative references	3
3 Definitions	5
4 Requirements	6
5 Tests	20
6 Marking	23
7 Technical documentation, scope of supply	24
Annex A (normative) Special requirements for boilers with atomizing oil burners	24
Annex B (normative) Test	25
Annex C (informative) A-deviations	29

Foreword

This European Standard has been prepared by Technical Committee CEN/TC 57 "Central heating boilers", the secretariat of which is held by DIN.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by July 1999, and conflicting national standards shall be withdrawn at the latest by July 1999.

The following structure is intended for the standards for heating boilers:

prEN 303-1

Heating boilers – Part 1: Heating boilers with forced draught burners – Terminology, general requirements, testing and marking

prEN 303-2

Heating boilers – Part 2: Heating boilers with forced draught burners – Special requirements for boilers with atomizing oil burners

prEN 303-3

Heating boilers – Part 3: Gas fired central heating boilers – Assembly comprising a boiler body and a forced draught burner

prEN 303-4

Heating boilers – Part 4: Heating boilers with forced draught burners – Special requirements for boilers with forced draught oil burners with outputs up to 70 kW and a maximum operating pressure of 3 bar – Terminology, special requirements, testing and marking

prEN 303-5

Heating boilers – Part 5: Heating boilers for solid fuels, hand and automatically fired, with a nominal heat output of up to 300 kW – Terminology, requirements, testing and marking

EN 304

Heating boilers – test code for heating boilers for atomizing oil burners

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and the United Kingdom.

1 Scope

This standard is applicable to heating boilers with forced draught oil burners up to a nominal heat output of 70 kW. They are operated, either with negative pressure (natural draught boiler) or with positive pressure (pressurised boiler) in the combustion chamber, in accordance with the boiler manufacturer's instructions.

This standard specifies the necessary terminology, the requirements on the materials and testing of them, and marking requirements for heating boilers.

The boilers are suitable for open vented systems up to a maximum allowable pressure of 1 bar (class 1 pressure) and open and closed water systems up to a maximum allowable pressure of 3 bar (class 2 pressure).

The boilers are capable of operating with either conventional flues or low level discharge flues as specified by the boiler manufacturer.

The boilers are provided as matched units with factory fitted burners for burning kerosene or gas oil. When using a low level flue gas discharge only kerosene may be used (see annex B).

The requirements of this standard apply to heating boilers which are tested on an authorised test rig in accordance with EN 304 and annex B of this standard.

Boilers in accordance with this standard are designed for the heating of central heating installations in which the heat carrier is water, and the temperature of which is restricted to 95 °C at normal operating conditions. For boilers with a built-in or attached water heater (storage or continuous flow heater) this standard only applies to the parts of the water heater which are necessarily subject to the operating conditions of the heating boiler (heating part).

This standard does not apply to gas boilers with atmospheric burners, boilers for solid fuels, oil or gas fired condensation boilers, boilers with oil vaporisation burners and low temperature boilers. For these boilers there are further requirements.

NOTE: Low temperature boilers are those operating with a (water) variable temperature up to 40 °C or less, or those which cannot be set at a temperature higher than 55 °C.

2 Normative references

This European Standard incorporates by dated or undated reference, provisions from other publications. These normative references are cited at the appropriate places in the text and the publications are listed hereafter. For dated references, subsequent amendments to or revisions of any of these publications apply to this European Standard only when incorporated in it by amendment or revision. For undated references the latest edition of the publication referred to applies.

EN 226

Atomizing oil burners – connecting dimensions between burners and heat generators

EN 287-1

Approval testing of welders – fusion welding – Part 1: steels

EN 287-2

Approval testing of welders – fusion welding – Part 2: aluminium and aluminium alloys

EN 303-2

Heating boilers – Part 2: Heating boilers with forced draught burner – Special requirements for boilers with atomizing oil burners

EN 304 : 1992

Heating boilers – test code for heating boilers for atomizing oil burners

EN 304 : 1992/prA1

Heating boilers – Test code for heating boilers for atomizing oil burners (Amendment 1)

EN 10003-1

Metallic materials – Brinell hardness test – Part 1: Test method

EN 10021

General technical delivery requirements for steel and iron products

EN 10025

Hot rolled products of non-alloy structural steels - technical delivery conditions (includes amendment A1 : 1993)

EN 10027-2

Designation systems for steels - Part 2: Numerical system

EN 10028-2

Flat products made of steels for pressure purposes; part 2: non-alloy and alloy steels with specified elevated temperature properties

EN 10029

Hot-rolled steel plates 3 mm thick or above - tolerances on dimensions, shape and mass

EN 10088-2

Stainless steels – Part 2: Technical delivery conditions for sheet/plate and strip for general purposes

EN 10120

Steel sheet and strip for welded gas cylinders

EN 24063

Welding, brazing, soldering and braze welding of metals - nomenclature of processes and reference numbers for symbolic representation on drawings (ISO 4063 : 1990)

EN 60335-1

Safety of household and similar electrical appliances – Part 1: General requirements (IEC 335-1 : 1991, modified)

EN 60529

Degrees of protection provided by enclosures (IP-Code) (IEC 529:1989)

EN 60730-2-9

Automatic electrical controls for household and similar use – Part 2: Particular requirements for temperature sensing controls (IEC 730-2-9: 1992, modified)

ISO 7-1

Pipe threads where pressure-tight joints are made on the threads – Part 1: Dimensions, tolerances and designation

ISO 7-2

Pipe threads where pressure-tight joints are made on the threads – Part 2: Verification by means of limit gauges

ISO 185

Grey cast iron - classification

ISO 228/1

Pipe threads where pressure-tight joints are not made on the threads – Part 1: Dimensions, tolerances and designation

ISO 228/2

Pipe threads where pressure-tight joints are not made on the threads – Part 2: Verification by means of limit gauges

ISO 857

Welding, brazing and soldering processes - vocabulary

ISO 2553

Welded, brazed and soldered joints - symbolic representation on drawings

ISO 7005-1

Metallic flanges - Part 1: Steel flanges

ISO 7005-2
Metallic flanges - Part 2: cast iron flanges

ISO 7005-3
Metallic flanges - Part 3: copper alloy and composite flanges

3 Definitions

For the purposes of this standard, the following definitions apply.

3.1 operating pressure: the maximum allowable pressure at which the boiler is to be normally operated. The operating pressure is less than the test pressure and the type test pressure [prEN 303-1].

3.2 test pressure: pressure to which all boilers and their parts are subjected during production in the works of the manufacturer or during setting up by the installer [prEN 303-1].

3.3 type test pressure: pressure to which the pre-production heating boiler(s) and associated parts are subjected before start of mass production in the manufacturing works [prEN 303-1].

3.4 operating temperature: the maximum allowable temperature at which the boiler can be operated under normal operating conditions at the maximum setting of the boiler's water temperature controller [prEN 303-1].

3.5 heat output Q , heat output range: is the amount of heat transferred to the heat carrier (water) per unit of time [prEN 303-1].

The heat output range is the span of output below the nominal heat output specified by the manufacturer over which the boiler meets the requirements of this standard and over which it can be used [prEN 303-1].

3.6 nominal heat output Q_N : is the continuous output specified by the manufacturer in accordance with the requirements of this standard. It is the maximum useful quantity of heat transferred to the heat carrier per hour [prEN 303-1].

3.7 heat input Q_B : is the amount of heat in unit time which is supplied to the furnace of the heating boiler by the fuel based on its net calorific value H_i [prEN 303-1].

3.8 boiler efficiency η_K : is the ratio of the heat output (Q) to the heat input (Q_B) supplied by the fuel [prEN 303-1].

$$\eta_K = \frac{Q}{Q_B}$$

3.9 Draught: Is the pressure differential between the static air pressure in the place of installation and the static pressure of the exhaust gases, as measured in the exhaust gas measuring section, which is required for correct operation of the boiler at nominal output [prEN 303-1].

3.10 gas side resistance: is the pressure differential between the combustion chamber and the boiler exit [prEN 303-1].

3.11 soundness of combustion system: is the soundness of the combustion circuit through which the exhaust gases flow [prEN 303-1].

3.12 exit flue temperature t_A : is the temperature measured at the flue exit of the boiler [prEN 303-1].

3.13 flue gas loss: is the quantity of heat per unit time which leaves the flue gas exit of the boiler unused [prEN 303-1].

3.14 combustion circuit: comprises the combustion chamber, the heat exchanger, the air supply circuit and the combustion product circuit up to the flue exit [prEN 303-1].

3.15 standby loss q_B : is the quantity of heat which is necessary to maintain the boiler at a given temperature when no heat output is used. It is stated as q_B in relation to the heat input Q_B [prEN 303-1].

3.16 water side resistance: is the pressure loss across the boiler measured at the flow and return connections of the boiler, with a volume flow corresponding to the nominal heat output [prEN 303-1].

3.17 control thermostat: a device enabling the water temperature to be kept automatically, within a given range, at a predetermined value [prEN 303-1].