

---

ICS 33.100.10

English Version

**Electromagnetic compatibility (EMC) - Part 3-3: Limits -  
Limitation of voltage changes, voltage fluctuations and flicker in  
public low-voltage supply systems, for equipment with rated  
current  $\leq 16$  A per phase and not subject to conditional  
connection  
(IEC 61000-3-3:2013/A2:2021/COR1:2022)**

Compatibilité électromagnétique (CEM) - Partie 3-3: Limites  
- Limitation des variations de tension, des fluctuations de  
tension et du papillotement dans les réseaux publics  
d'alimentation basse tension, pour les matériels ayant un  
courant assigné  $\leq 16$  A par phase et non soumis à un  
raccordement conditionnel  
(IEC 61000-3-3:2013/A2:2021/COR1:2022)

Elektromagnetische Verträglichkeit (EMV) - Teil 3-3:  
Grenzwerte - Begrenzung von Spannungsänderungen,  
Spannungsschwankungen und Flicker in öffentlichen  
Niederspannungs-Versorgungsnetzen für Geräte mit einem  
Bemessungsstrom  $\leq 16$  A je Leiter, die keiner  
Sonderanschlussbedingung unterliegen  
(IEC 61000-3-3:2013/A2:2021/COR1:2022)

This corrigendum becomes effective on 28 January 2022 for incorporation in the English language version of the EN.



European Committee for Electrotechnical Standardization  
Comité Européen de Normalisation Electrotechnique  
Europäisches Komitee für Elektrotechnische Normung

**CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels**

## **Endorsement notice**

The text of the corrigendum IEC 61000-3-3:2013/A2:2021/COR1:2022 was approved by CENELEC as EN 61000-3-3:2013/A2:2021/AC:2022-01 without any modification.

INTERNATIONAL ELECTROTECHNICAL COMMISSION  
COMMISSION ÉLECTROTECHNIQUE INTERNATIONALE

---

**IEC 61000-3-3:2013/AMD2:2021**  
Edition 3.0 2013-05

**IEC 61000-3-3:2013/AMD2:2021**  
Édition 3.0 2013-05

**ELECTROMAGNETIC COMPATIBILITY (EMC) –**

**Part 3-3: Limits – Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated current  $\leq 16$  A per phase and not subject to conditional connection**

**COMPATIBILITÉ ÉLECTROMAGNÉTIQUE (CEM) –**

**Partie 3-3: Limites – Limitation des variations de tension, des fluctuations de tension et du papillotement dans les réseaux publics d'alimentation basse tension, pour les matériels ayant un courant assigné  $\leq 16$  A par phase non soumis à un raccordement conditionnel**

## **C O R R I G E N D U M 1**

Corrections to the French version appear after the English text.

Les corrections à la version française sont données après le texte anglais.

### **A.16 Coffee machines and tea machines**

*Replace the sixth and seventh paragraphs (i.e. the last two paragraphs) with the following:*

For machines, which are designed to prepare exclusively complete pots for a number of cups, during the 10 min measuring period for the  $P_{st}$  complete pots are prepared one after the other with 1 min separation between consecutive pots.

$P_{lt}$  shall not be evaluated.

In any situation where it is necessary to verify the original measurement the measuring method originally chosen shall be used in order to ensure consistency of the results.