

English Version

Gas-fired heating boilers - Part 1: General requirements and tests

Chaudières de chauffage central utilisant les
combustibles gazeux - Partie 1: Exigences générales et
essais

Heizkessel für gasförmige Brennstoffe - Teil 1:
Allgemeine Anforderungen und Prüfungen

This corrigendum becomes effective on 7 September 2022 for incorporation in the official English version of the EN



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents

1 Deletion in 9.1.2 3

2 Modification in 8.1.2.1 3

1 Deletion in 9.1.2

In 9.1.2, delete the following sentence:

"The temperature of the room shall be $20^{\circ}\text{C} \pm 1^{\circ}\text{C}$ "

2 Modification in 8.1.2.1

Under 8.1.2.1, change the existing text:

"which has an ambient temperature of (20 ± 5) K."

as follows:

"which has an ambient temperature of (20 ± 5) °C."