
**Gaseous hydrogen — Fuelling
stations —**

**Part 3:
Valves**

*Carburant d'hydrogène gazeux — Stations-service —
Partie 3: Vannes*



This document is a preview generated by EMS



COPYRIGHT PROTECTED DOCUMENT

© ISO 2018

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Fax: +41 22 749 09 47
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Contents

	Page
Foreword	vii
Introduction	viii
1 Scope	1
2 Normative references	1
3 Terms and definitions	1
4 General requirements	3
4.1 General.....	3
4.2 Intended use	3
4.3 Material requirements.....	3
4.4 Product quality	4
5 General test methods	4
5.1 General.....	4
5.2 Test conditions.....	4
5.2.1 Test sample	4
5.2.2 Pressure.....	5
5.2.3 Normal test temperature.....	5
5.2.4 Specified test temperature.....	5
5.2.5 Test media	5
5.2.6 Test sequence.....	5
5.3 Hydrogen gas pressure cycle test	5
5.3.1 General.....	5
5.3.2 Test method	5
5.4 Leakage.....	6
5.4.1 General.....	6
5.4.2 External leakage test.....	6
5.4.3 Internal leakage test	6
5.5 Worst case fault pressure cycle test.....	6
5.6 Proof pressure test.....	6
5.7 Hydrostatic strength test.....	7
5.7.1 Test pressure.....	7
5.7.2 Test method	7
5.8 Excess torque resistance test.....	7
5.9 Bending moment test.....	7
5.10 Non-metallic materials test.....	9
5.10.1 General.....	9
5.10.2 Test method	9
5.11 Cold gas in warm valve test	9
6 Check valves	10
6.1 Applicability	10
6.2 Hydrogen gas pressure cycle test	10
6.3 External leakage test	10
6.4 Internal leakage test.....	10
6.5 Worst case fault pressure cycle test.....	11
6.6 Proof pressure test.....	11
6.7 Hydrostatic strength test.....	11
6.8 Excess torque resistance test.....	11
6.9 Bending moment test.....	11
6.10 Non-metallic material test	11
7 Excess flow valves	11
7.1 General.....	11
7.2 Tests.....	11
7.2.1 Classification	11

7.2.2	Applicability.....	11
7.2.3	Hydrogen gas pressure cycle test.....	12
7.2.4	External leakage test.....	12
7.2.5	Internal leakage test.....	12
7.2.6	Worst case fault pressure test.....	12
7.2.7	Proof pressure test.....	12
7.2.8	Hydrostatic strength test.....	12
7.2.9	Excess torque resistance test.....	12
7.2.10	Bending moment test.....	12
7.2.11	Non-metallic material test.....	13
7.2.12	Operation cycle test.....	13
7.2.13	Operation test.....	13
7.2.14	Pressure impulse test.....	13
8	Flow control valves.....	13
8.1	General.....	13
8.2	Tests.....	13
8.2.1	Applicability.....	13
8.2.2	Hydrogen gas pressure cycle test.....	14
8.2.3	External leakage test.....	14
8.2.4	Worst case fault pressure test.....	14
8.2.5	Proof pressure test.....	14
8.2.6	Hydrostatic strength test.....	14
8.2.7	Excess torque resistance test.....	14
8.2.8	Bending moment test.....	14
8.2.9	Non-metallic material test.....	14
8.2.10	Operation test under full pressure load.....	14
9	Hose breakaway devices.....	15
9.1	Specific design requirements.....	15
9.1.1	General.....	15
9.1.2	Electrical conductivity.....	15
9.1.3	Containment of/controlled relieving of hydrogen when uncoupled.....	15
9.1.4	Separation.....	15
9.2	Tests.....	15
9.2.1	Applicability.....	15
9.2.2	Hydrogen gas pressure cycle test.....	16
9.2.3	External leakage test.....	16
9.2.4	Worst case fault pressure test.....	16
9.2.5	Proof pressure test.....	16
9.2.6	Hydrostatic strength test.....	17
9.2.7	Excess torque resistance test.....	17
9.2.8	Bending moment test.....	17
9.2.9	Non-metallic material test.....	17
9.2.10	Separation test.....	17
9.2.11	Impact test (Applicable to rigid-mount devices).....	18
9.2.12	Drop test.....	19
9.2.13	Twisting test.....	20
9.2.14	Cold gas in warm valve test.....	20
10	Manual valves.....	21
10.1	Construction and assembly.....	21
10.2	Tests.....	21
10.2.1	Applicability.....	21
10.2.2	Hydrogen gas pressure cycle test.....	21
10.2.3	External leakage test.....	21
10.2.4	Internal leakage test.....	21
10.2.5	Worst case fault pressure test.....	21
10.2.6	Proof pressure test.....	21
10.2.7	Hydrostatic strength test.....	22

10.2.8	Excess torque resistance test.....	22
10.2.9	Bending moment test.....	22
10.2.10	Non-metallic material test.....	22
10.2.11	Maximum flow shut-off test.....	22
10.2.12	Operation test.....	22
10.2.13	Excess torque operation test.....	22
11	Pressure safety valves (PSV).....	23
11.1	Applicability.....	23
11.2	Hydrogen gas pressure cycle test.....	23
11.3	PSV leakage tests.....	23
11.3.1	External leakage test.....	23
11.3.2	Seat leakage test.....	23
11.4	Worst case fault pressure test.....	24
11.5	Proof pressure test.....	24
11.6	Hydrostatic strength test.....	24
11.7	Excess torque resistance test.....	24
11.8	Bending moment test.....	24
11.9	Non-metallic material test.....	24
11.10	Operation test.....	24
12	Shut-off valves.....	25
12.1	Classification.....	25
12.2	Construction and assembly.....	25
12.3	Tests.....	25
12.3.1	Applicability.....	25
12.3.2	Hydrogen gas pressure cycle test.....	26
12.3.3	External leakage test.....	26
12.3.4	Internal leakage test.....	26
12.3.5	Worst case fault pressure test.....	26
12.3.6	Proof pressure test.....	26
12.3.7	Hydrostatic strength test.....	27
12.3.8	Excess torque resistance test.....	27
12.3.9	Bending moment test.....	27
12.3.10	Non-metallic material test.....	27
12.3.11	Operation test under full pressure load.....	27
12.3.12	Maximum flow shut-off test.....	27
12.3.13	Cold gas in warm valve test.....	27
13	Marking.....	28
13.1	Marking information.....	28
13.2	Marking method.....	28
14	Component literature.....	28
	Bibliography.....	30

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see the following URL: www.iso.org/iso/foreword.html.

This document was prepared by ISO/TC 197, *Hydrogen technologies*.

A list of all parts in the ISO 19880 series can be found on the ISO website.

Introduction

Over the course of several years, international efforts have been initiated for the development of regulations, codes and standards that are required for the introduction of hydrogen energy systems. Hydrogen has unique properties and therefore presents unique safety concerns.

One of the many hydrogen energy applications is the automobile sector for which commercialization begun recently. For the success of this application, however, hydrogen infrastructure for fuelling vehicles is as essential as the hydrogen vehicles themselves. Thus, the development of safety standards for fuelling stations and components is of paramount importance.

This document provides safety performance requirements and test methods for valves to be used in gaseous hydrogen environment. Valves are critical to the safety of hydrogen fuelling stations, because they control the flow of gaseous hydrogen, shut it down in an emergency and, at the same time, may become a potential source of hydrogen release or leakage.

This document will facilitate the development of hydrogen infrastructure that is needed to pave a way for the widespread deployment of hydrogen-fuelled vehicles. Benefits to be gained by the implementation of this document include: the establishment of a certain level of safety performance for valves, a safety-critical component; the streamlining of the design and construction processes for fuelling stations by providing standardized components; and the promotion of public acceptance of hydrogen stations through the transparency of the international standardization processes.

This document is based on the Canadian Standards Association references CSA HGV3.1-2013, ANSI/CSA HGV 4.4-2013, ANSI/CSA HGV 4.6-2013 and ANSI/CSA HGV 4.7-2013.

This document is not intended to exclude any specific technologies that meet the performance requirements herein.

This document is to be applied in conjunction with other International Standards relevant to hydrogen fuelling stations and components.

Gaseous hydrogen — Fuelling stations —

Part 3: Valves

1 Scope

This document provides the requirements and test methods for the safety performance of high pressure gas valves that are used in gaseous hydrogen stations of up to the H70 designation.

This document covers the following gas valves:

- check valve;
- excess flow valve;
- flow control valve;
- hose breakaway device;
- manual valve;
- pressure safety valve;
- shut-off valve.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60079-0, *Explosive atmospheres — Part 0: Equipment — General requirements*

3 Terms and definitions

For the purpose of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <https://www.iso.org/obp>

3.1

allowable temperature range

minimum and maximum temperatures for which the manufacturer has designed the equipment (or any part to which the term is referred) when handling the specified fluid at the specified pressure

3.2

component pressure rating

maximum allowable pressure at which it is permissible to operate a component as specified by the manufacturer at a specified temperature

Note 1 to entry: Further guidance on dispenser pressure terminology is found in ISO 19880-1.