

# INTERNATIONAL STANDARD

**IEC**  
**60269-1**

Fourth edition  
2006-11

---

---

## Low-voltage fuses –

### Part 1: General requirements

*This **English-language** version is derived from the original **bilingual** publication by leaving out all French-language pages. Missing page numbers correspond to the French-language pages.*



Reference number  
IEC 60269-1:2006(E)

## Publication numbering

As from 1 January 1997 all IEC publications are issued with a designation in the 60000 series. For example, IEC 34-1 is now referred to as IEC 60034-1.

## Consolidated editions

The IEC is now publishing consolidated versions of its publications. For example, edition numbers 1.0, 1.1 and 1.2 refer, respectively, to the base publication, the base publication incorporating amendment 1 and the base publication incorporating amendments 1 and 2.

## Further information on IEC publications

The technical content of IEC publications is kept under constant review by the IEC, thus ensuring that the content reflects current technology. Information relating to this publication, including its validity, is available in the IEC Catalogue of publications (see below) in addition to new editions, amendments and corrigenda. Information on the subjects under consideration and work in progress undertaken by the technical committee which has prepared this publication, as well as the list of publications issued, is also available from the following:

- **IEC Web Site** ([www.iec.ch](http://www.iec.ch))

- **Catalogue of IEC publications**

The on-line catalogue on the IEC web site ([www.iec.ch/searchpub](http://www.iec.ch/searchpub)) enables you to search by a variety of criteria including text searches, technical committees and date of publication. On-line information is also available on recently issued publications, withdrawn and replaced publications, as well as corrigenda.

- **IEC Just Published**

This summary of recently issued publications ([www.iec.ch/online\\_news/justpub](http://www.iec.ch/online_news/justpub)) is also available by email. Please contact the Customer Service Centre (see below) for further information.

- **Customer Service Centre**

If you have any questions regarding this publication or need further assistance, please contact the Customer Service Centre:

Email: [custserv@iec.ch](mailto:custserv@iec.ch)  
Tel: +41 22 919 02 11  
Fax: +41 22 919 03 00

# INTERNATIONAL STANDARD

**IEC**  
**60269-1**

Fourth edition  
2006-11

---

---

## Low-voltage fuses –

### Part 1: General requirements

© IEC 2006 Copyright - all rights reserved

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

International Electrotechnical Commission, 3, rue de Varembe, PO Box 131, CH-1211 Geneva 20, Switzerland  
Telephone: +41 22 919 02 11 Telefax: +41 22 919 03 00 E-mail: inmail@iec.ch Web: www.iec.ch



Commission Electrotechnique Internationale  
International Electrotechnical Commission  
Международная Электротехническая Комиссия

PRICE CODE **XC**

*For price, see current catalogue*

## CONTENTS

FOREWORD.....	9
INTRODUCTION.....	13
1 General .....	15
1.1 Scope and object.....	15
1.2 Normative references .....	17
2 Terms and definitions .....	19
2.1 Fuses and their component parts .....	19
2.2 General terms.....	21
2.3 Characteristic quantities .....	27
3 Conditions for operation in service .....	33
3.1 Ambient air temperature ( $T_a$ ).....	33
3.2 Altitude.....	33
3.3 Atmospheric conditions.....	33
3.4 Voltage.....	35
3.5 Current.....	35
3.6 Frequency, power factor and time constant .....	35
3.7 Conditions of installation.....	35
3.8 Utilization category .....	35
3.9 Discrimination of fuse-links .....	37
4 Classification .....	37
5 Characteristics of fuses .....	37
5.1 Summary of characteristics.....	37
5.2 Rated voltage .....	39
5.3 Rated current .....	39
5.4 Rated frequency (see 6.1 and 6.2) .....	39
5.5 Rated power dissipation of a fuse-link and rated acceptable power dissipation of a fuse-holder .....	41
5.6 Limits of time-current characteristics.....	41
5.7 Breaking range and breaking capacity.....	45
5.8 Cut-off current and $I^2t$ characteristics.....	47
6 Markings.....	47
6.1 Markings of fuse-holders .....	47
6.2 Markings of fuse-links.....	49
6.3 Marking symbols.....	49
7 Standard conditions for construction .....	49
7.1 Mechanical design.....	49
7.2 Insulating properties and suitability for isolation.....	51
7.3 Temperature rise, power dissipation of the fuse-link and acceptable power dissipation of a fuse-holder .....	53
7.4 Operation .....	55
7.5 Breaking capacity .....	57
7.6 Cut-off current characteristic.....	57
7.7 $I^2t$ characteristics .....	57
7.8 Overcurrent discrimination of fuse-links .....	59
7.9 Protection against electric shock.....	59

7.10	Resistance to heat.....	65
7.11	Mechanical strength.....	65
7.12	Resistance to corrosion .....	65
7.13	Resistance to abnormal heat and fire .....	65
7.14	Electromagnetic compatibility.....	65
8	Tests.....	67
8.1	General .....	67
8.2	Verification of the insulating properties and of the suitability for isolation .....	77
8.3	Verification of temperature rise and power dissipation .....	81
8.4	Verification of operation .....	87
8.5	Verification of the breaking capacity.....	97
8.6	Verification of the cut-off current characteristics.....	109
8.7	Verification of $I^2t$ characteristics and overcurrent discrimination .....	109
8.8	Verification of the degree of protection of enclosures .....	111
8.9	Verification of resistance to heat.....	111
8.10	Verification of non-deterioration of contacts .....	111
8.11	Mechanical and miscellaneous tests .....	113
	Annex A (informative) Measurement of short-circuit power factor .....	139
	Annex B (informative) Calculation of pre-arcing $I^2t$ values for "gG", "gM", "gD" and "gN" fuse-links and calculation of operating $I^2t$ values at reduced voltage.....	145
	Annex C (informative) Calculation of cut-off current-time characteristic.....	149
	Annex D (informative) Effect of change of ambient temperature and surroundings on the performance of fuse-links .....	157
	Figure 1 – Diagram illustrating the means of verification of the time-current characteristic, using the results of the tests at the "gate" currents (example).....	121
	Figure 2 – Overload curve and time-current characteristic for "a" fuse-links .....	123
	Figure 3 – Time current zone for aM fuses.....	125
	Figure 4 – General presentation of the cut-off characteristics for a series of a.c. fuse-links.....	127
	Figure 5 – Typical diagram of the circuit used for breaking capacity test (see 8.5).....	129
	Figure 6 – Interpretation of oscillograms taken during the a.c. breaking-capacity tests (see 8.5.7) .....	131
	Figure 7 – Interpretation of oscillograms taken during the d.c. breaking-capacity tests (see 8.5.7) .....	133
	Figure 8 – Glow-wire and position of the thermocouple .....	135
	Figure 9 – Test apparatus (example) .....	137
	Figure A.1 – Determination of circuit-impedance for calculation of power factor in accordance with method I.....	143
	Figure C.1 – Cut-off current characteristic as a function of actual pre-arcing time .....	155

Table 1 – Standard values of a.c. rated voltages for fuses .....	39
Table 2 – Conventional time and current for "gG" and "gM" fuse-links .....	43
Table 3 – Gates for specified pre-arcing times of "gG" and "gM" fuse-links <sup>a</sup> .....	43
Table 4 – Gates for "aM" fuse-links (all rated currents).....	45
Table 5 – Temperature rise limits $\Delta T = (T - T_a)$ for contacts and terminals .....	53
Table 6 – Maximum arc voltage .....	57
Table 7 – Pre-arcing $I^2t$ values at 0,01 s for "gG" and "gM" fuse-links .....	59
Table 8 – Rated impulse withstand voltage .....	61
Table 9 – Minimum clearances in air .....	61
Table 10 – Minimum creepage distances .....	63
Table 11 – Survey of complete tests on fuse-links and number of fuse-links to be tested .....	71
Table 12 – Survey of tests on fuse-links of smallest rated current of homogeneous series and number of fuse-links to be tested.....	73
Table 13 – Survey of tests on fuse-links of rated currents between the largest and the smallest rated current of a homogeneous series and number of fuse-links to be tested .....	75
Table 14 – Survey of complete tests on fuse-holders and number of fuse-holders to be tested .....	75
Table 15 – Test voltage .....	79
Table 16 – Test voltage across the poles for the verification of the suitability for isolation .....	81
Table 17 – Cross-sectional area of copper conductors for tests corresponding to Subclauses 8.3 and 8.4 .....	85
Table 18 – Cross-section areas of the copper conductors for the test of "aM" fuses .....	91
Table 19 – Table for test in Subclause 8.4.3.5 .....	95
Table 20 – Values for breaking-capacity tests on a.c. fuses .....	101
Table 21 – Values for breaking capacity tests on d.c. fuses .....	103

# INTERNATIONAL ELECTROTECHNICAL COMMISSION

## LOW-VOLTAGE FUSES –

### Part 1: General requirements

#### FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60269-1 has been prepared by subcommittee 32B: Low-voltage fuses, of IEC technical committee 32: Fuses.

This fourth edition cancels and replaces the third edition published in 1998 and amendment 1 (2005), as well as parts of IEC 60269-2 (1986) and IEC 60269-3 (1987) and constitutes a minor revision.

The general re-organization of the IEC 60269 series has led to the creation of this new edition.

The text of this standard is based on following documents:

FDIS	Report on voting
32B/483/FDIS	32B/490/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

IEC 60269 consists of the following parts, under the general title *Low-voltage fuses*:

**Part 1: General requirements**

NOTE This part includes IEC 60269-1 (third edition, 1998) and parts of IEC 60269-2 (second edition, 1986) and IEC 60269-3 (second edition, 1987).

**Part 2: Supplementary requirements for fuses for use by authorized persons (fuses mainly for industrial application) – Examples of standardized systems of fuses A to I**

NOTE This part includes parts of IEC 60269-2 (second edition, 1986) and all of IEC 60269-2-1 (fourth edition, 2004).

**Part 3: Supplementary requirements for fuses for use by unskilled persons (fuses mainly for household or similar application) – Examples of standardized systems of fuses A to F**

NOTE This part includes parts of IEC 60269-3 (second edition, 1987) and all of IEC 60269-3-1 (second edition, 2004).

**Part 4: Supplementary requirements for fuse-links for the protection of semiconductor devices**

NOTE This part includes IEC 60269-4 (third edition, 1986) and IEC 60269-4-1 (first edition, 2002).

**Part 5: Guidance for the application of low-voltage fuses**

NOTE Currently IEC/TR 61818 (2003).

For reasons of convenience, when a part of this publication has come from other publications, a remark to this effect has been inserted in the text.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

## INTRODUCTION

A reorganization of the different parts of the IEC 60269 series has been carried out, in order to simplify its use, especially by the laboratories which test the fuses.

IEC 60269-1, IEC 60269-2, IEC 60269-3 and IEC 60269-3-1 have been integrated into either the new part 1 or the new parts 2 or 3, according to the subjects considered, so that the clauses which deal exclusively with “fuses for authorized persons” are separated from the clauses dealing with “fuses for unauthorized persons”.

As far as IEC 60269-4 and IEC 60269-4-1 are concerned, they have been integrated into the new part 4 which deals with the fuse-links used for semiconductor protection.

This document is a preview generated by EVS

## LOW-VOLTAGE FUSES –

### Part 1: General requirements

#### 1 General

##### 1.1 Scope and object

This part of IEC 60269 is applicable to fuses incorporating enclosed current-limiting fuse-links with rated breaking capacities of not less than 6 kA, intended for protecting power-frequency a.c. circuits of nominal voltages not exceeding 1 000 V or d.c. circuits of nominal voltages not exceeding 1 500 V.

Subsequent parts of this standard, referred to herein, cover supplementary requirements for such fuses intended for specific conditions of use or applications.

Fuse-links intended to be included in fuse-switch combinations according to IEC 60947-3 should also comply with the following requirements.

NOTE 1 For "a" fuse-links, details of performance (see 2.2.4) on d.c. circuits should be subject to agreement between user and manufacturer.

NOTE 2 Modifications of, and supplements to, this standard required for certain types of fuses for particular applications – for example, certain fuses for rolling stock, or fuses for high-frequency circuits – will be covered, if necessary, by separate standards.

NOTE 3 This standard does not apply to miniature fuses, these being covered by IEC 60127.

The object of this standard is to establish the characteristics of fuses or parts of fuses (fuse-base, fuse-carrier, fuse-link) in such a way that they can be replaced by other fuses or parts of fuses having the same characteristics provided that they are interchangeable as far as their dimensions are concerned. For this purpose, this standard refers in particular to

- the following characteristics of fuses:
  - their rated values;
  - their insulation;
  - their temperature rise in normal service;
  - their power dissipation and acceptable power dissipation;
  - their time/current characteristics;
  - their breaking capacity;
  - their cut-off current characteristics and their  $I^2t$  characteristics.
- type test for verification of the characteristics of fuses;
- the marking of fuses.

## 1.2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60038:1983, *IEC standard voltages*

IEC 60050(441):1984, *International Electrotechnical Vocabulary (IEV) – Chapter 441: Switchgear, controlgear and fuses*  
Amendment 1 (2000)

IEC 60269-2, *Low-voltage fuses – Part 2: Supplementary requirements for fuses for use by authorized persons (fuses mainly for industrial application) – Examples of standardized systems of fuses A to I)*

IEC 60269-3, *Low-voltage fuses – Part 3: Supplementary requirements for fuses for use by unskilled persons (fuses mainly for household or similar application) – Examples of standardized systems of fuses A to F*

IEC 60269-4, *Low-voltage fuses – Part 4: Supplementary requirements for fuse-links for the protection of semiconductor devices*

IEC 60269-5, *Low-voltage fuses – Part 5: Guidance for the application of low-voltage fuses*

IEC 60364-3:1993, *Electrical installations of buildings – Part 3: Assessment of general characteristics*

IEC 60364-5-52:2001, *Electrical installations of buildings – Part 5-52: Selection and erection of electrical equipment – Wiring system*

IEC 60529:1989, *Degrees of protection provided by enclosures (Code IP)*

IEC 60584-1:1995, *Thermocouples – Part 1: Reference tables*

IEC 60617, *Graphical symbols for diagrams*

IEC 60664-1:2002, *Insulation coordination for equipment within low-voltage systems – Part 1: Principles, requirements and tests*

IEC 60695-2-1/0:1994, *Fire hazard testing – Part 2: Test methods – Section 1/sheet 0: Glow-wire test methods – General*

IEC 60695-2-1/1:1994, *Fire hazard testing – Part 2: Test methods – Section 1/sheet 1: Glow-wire end-product test and guidance*

IEC 60695-2-1/2:1994, *Fire hazard testing – Part 2: Test methods – Section 1/sheet 2: Glow-wire flammability test on materials*

IEC 60695-2-1/3:1994, *Fire hazard testing – Part 2: Test methods – Section 1/sheet 3: Glow-wire ignitability test on materials*

ISO 3:1973, *Preferred numbers – Series of preferred numbers*

ISO 478:1974, *Paper – Untrimmed stock sizes for the ISO-A series – ISO primary range*

ISO 593:1974, *Paper – Untrimmed stock size for the ISO-A series – ISO supplementary range*

ISO 4046:1978, *Paper, board, pulp and related terms – Vocabulary – Bilingual edition*

## 2 Terms and definitions

NOTE For general definitions concerning fuses, see also IEC 60050-441.

For the purposes of this document, the following terms and definitions apply.

### 2.1 Fuses and their component parts

#### 2.1.1

##### **fuse**

device that by the fusing of one or more of its specially designed and proportioned components opens the circuit in which it is inserted by breaking the current when this exceeds a given value for a sufficient time. The fuse comprises all the parts that form the complete device

[IEV 441-18-01]

#### 2.1.2

##### **fuse-holder**

combination of the fuse-base with its fuse-carrier

NOTE Where, in this standard, the term "fuse-holder" is used, it covers fuse-bases and/or fuse-carriers, if no clearer distinction is necessary.

[IEV 441-18-14]

#### 2.1.2.1

##### **fuse-base (fuse-mount)**

fixed part of a fuse provided with contacts and terminals

[IEV 441-18-02]

NOTE Where applicable, covers are considered as part of the fuse-base.

#### 2.1.2.2

##### **fuse-carrier**

movable part of a fuse designed to carry a fuse-link

[IEV 441-18-13]

#### 2.1.3

##### **fuse-link**

part of a fuse including the fuse-element(s), intended to be replaced after the fuse has operated

[IEV 441-18-09]

#### 2.1.4

##### **fuse-contact**

two or more conductive parts designed to ensure circuit continuity between a fuse-link and the corresponding fuse-holder