

Jõutrafode, elektrivarustusseadmete ja muude taoliste seadmete ohutus. Osa 2-6: Erinõuded üldkasutatavatele kaitseeraldustrafodele

Safety of transformers, reactors, power supply units and similar products for voltages up to 1100 V -- Part 2-6: Particular requirements and tests for safety isolating transformers and power supply units incorporating safety isolating transformers

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

Käesolev Eesti standard EVS-EN 61558-2-6:2009 sisaldab Euroopa standardi EN 61558-2-6:2009 ingliskeelset teksti.

Standard on kinnitatud Eesti Standardikeskuse 30.10.2009 käskkirjaga ja jõustub sellekohase teate avaldamisel EVS Teatajas.

Euroopa standardimisorganisatsioonide poolt rahvuslikele liikmetele Euroopa standardi teksti kättesaadavaks tegemise kuupäev on 12.08.2009.

Standard on kättesaadav Eesti standardiorganisatsioonist.

This Estonian standard EVS-EN 61558-2-6:2009 consists of the English text of the European standard EN 61558-2-6:2009.

This standard is ratified with the order of Estonian Centre for Standardisation dated 30.10.2009 and is endorsed with the notification published in the official bulletin of the Estonian national standardisation organisation.

Date of Availability of the European standard text 12.08.2009.

The standard is available from Estonian standardisation organisation.

ICS 29.180

Standardite reprodutseerimis- ja levitamiseõigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonilisse süsteemi või edastamine ükskõik millises vormis või millisel teel on keelatud ilma Eesti Standardikeskuse poolt antud kirjaliku loata.

Kui Teil on küsimusi standardite autorikaitse kohta, palun võtke ühendust Eesti Standardikeskusega:
Aru 10 Tallinn 10317 Eesti; www.evs.ee; Telefon: 605 5050; E-post: info@evs.ee

Right to reproduce and distribute Estonian Standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without permission in writing from Estonian Centre for Standardisation.

If you have any questions about standards copyright, please contact Estonian Centre for Standardisation:
Aru str 10 Tallinn 10317 Estonia; www.evs.ee; Phone: +372 605 5050; E-mail: info@evs.ee

English version

**Safety of transformers, reactors, power supply units
and similar products for supply voltages up to 1 100 V -
Part 2-6: Particular requirements and tests
for safety isolating transformers and power supply units
incorporating safety isolating transformers
(IEC 61558-2-6:2009)**

Sécurité des transformateurs,
bobines d'inductance, blocs d'alimentation
et produits analogues pour des tensions
d'alimentation jusqu'à 1 100 V -
Partie 2-6: Règles particulières et essais
pour les transformateurs de sécurité
et les blocs d'alimentation incorporant
des transformateurs de sécurité
(CEI 61558-2-6:2009)

Sicherheit von Transformatoren, Drosseln,
Netzgeräten und dergleichen
für Versorgungsspannungen bis 1 100 V -
Teil 2-6: Besondere Anforderungen
und Prüfungen
an Sicherheitstransformatoren
und Netzgeräte,
die Sicherheitstransformatoren enthalten
(IEC 61558-2-6:2009)

This European Standard was approved by CENELEC on 2009-07-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: Avenue Marnix 17, B - 1000 Brussels

Foreword

The text of document 96/317/FDIS, future edition 2 of IEC 61558-2-6, prepared by IEC TC 96, Transformers, reactors, power supply units and similar products for low voltage up to 1 100 V, was submitted to the IEC-CENELEC parallel vote and was approved by CENELEC as EN 61558-2-6 on 2009-07-01.

This European Standard supersedes EN 61558-2-6:1997.

The main changes consist of updating EN 61558-2-6:1997, in accordance with EN 61558-1:2005, and increasing the supply voltages up to 1 100 V to be in line with the standards of TC 14.

The following dates were fixed:

- | | | |
|--|-------|------------|
| – latest date by which the EN has to be implemented at national level by publication of an identical national standard or by endorsement | (dop) | 2009-10-01 |
| – latest date by which the national standards conflicting with the EN have to be withdrawn | (dow) | 2012-07-01 |

This standard is to be used in conjunction with EN 61558-1 and its amendments. It is based on EN 61558-1:2005.

This Part 2-6 supplements or modifies the corresponding clauses in EN 61558-1, so as to convert that publication into the European Standard: *Particular requirements and tests for safety isolating transformers and power supply units incorporating safety isolating transformers*.

When a particular subclause of Part 1 is not mentioned in this part, that subclause applies as far as is reasonable. Where this standard states "addition", "modification" or "replacement", the relevant text of Part 1 is to be adapted accordingly.

In this part, the following print types are used:

- requirements proper: in roman type;
- *test specifications: in italic type;*
- explanatory matter: in smaller roman type.

In the text of this standard, the words in **bold** are defined in Clause 3.

Subclauses, notes, figures and tables additional to those in Part 1 are numbered starting from 101; supplementary annexes are entitled AA, BB, etc.

Annex ZA has been added by CENELEC.

Endorsement notice

The text of the International Standard IEC 61558-2-6:2009 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following note has to be added for the standard indicated:

IEC 61558-2-16 NOTE Harmonized as EN 61558-2-16:200X (not modified).

Annex ZA
(normative)

**Normative references to international publications
with their corresponding European publications**

Addition to Annex ZA of EN 61558-1:

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 61558-1	2005	Safety of power transformers, power supplies, reactors and similar products - Part 1: General requirements and tests	EN 61558-1 + corr. August	2005 2006

This document is a preview generated by EVS

CONTENTS

FOREWORD.....	3
1 Scope.....	5
2 Normative references	6
3 Terms and definitions	6
4 General requirements	6
5 General notes on tests	6
6 Ratings.....	6
7 Classification.....	7
8 Marking and other information	7
9 Protection against electric shock	7
10 Change of input voltage setting	7
11 Output voltage and output current under load	7
12 No-load output voltage	7
13 Short-circuit voltage	8
14 Heating	8
15 Short-circuit and overload protection	8
16 Mechanical strength	9
17 Protection against harmful ingress of dust, solid objects and moisture.....	9
18 Insulation resistance, dielectric strength and leakage current	9
19 Construction.....	9
20 Components	11
21 Internal wiring.....	11
22 Supply connection and other external flexible cable or cords	11
23 Terminals for external conductors.....	11
24 Provisions for protective earthing	11
25 Screws and connections.....	11
26 Creepage distances, clearances and distances through insulation.....	12
27 Resistance to heat, fire and tracking.....	12
28 Resistance to rusting.....	12
Annexes	13
Annex C Creepage distances (cr), clearances (cl) and distances through insulation (dti) Material group II ($400 \leq \text{CTI} < 600$)	13
Annex D Creepage distances (cr), clearances (cl) and distances through insulation (dti) Material group I ($\text{CTI} \geq 600$).....	13
Annex R Explanations of the application of 4.2 of IEC 60664-1:2007 (see IEC 61558-1 Subclause 26.2).....	13
Bibliography.....	14
Table 101 – Output voltage difference	8

SAFETY OF TRANSFORMERS, REACTORS, POWER SUPPLY UNITS AND SIMILAR PRODUCTS FOR SUPPLY VOLTAGES UP TO 1 100 V –

Part 2-6: Particular requirements and tests for safety isolating transformers and power supply units incorporating safety isolating transformers

1 Scope

Replacement:

This part of IEC 61558 deals with the safety of **safety isolating transformers** for general applications and **power supply units** incorporating **safety isolating transformers** for general applications. **Transformers** incorporating **electronic circuits** are also covered by this standard.

NOTE 1 Safety includes electrical, thermal and mechanical aspects.

Unless otherwise specified, from here onward, the term **transformer** covers **safety isolating transformers** for general applications and **power supply units** incorporating **safety isolating transformers** for general applications.

NOTE 2 For **power supply units** (linear) this part is applicable. For **switch mode power supply units**, IEC 61558-2-16 is applicable together with this part.

This part is applicable to **stationary** or **portable**, single-phase or polyphase, air-cooled (natural or forced) **independent** or **associated dry- type transformers**. The windings may be encapsulated or non-encapsulated.

The **rated supply voltage** does not exceed 1 100 V a.c., and the **rated supply frequency** and the **internal operating frequencies** do not exceed 500 Hz.

The **rated output** does not exceed:

- 10 kVA for single-phase **transformers**;
- 16 kVA for polyphase **transformers**.

This part is applicable to **transformers** without limitation of the **rated output** subject to an agreement between the purchaser and the manufacturer.

NOTE 3 **Transformers** intended to supply distribution networks are not included in the scope.

The **no-load output voltage** or the **rated output voltage** does not exceed 50 V a.c. or 120 V ripple-free d.c.

This part is not applicable to external circuits and their components intended to be connected to the input terminals and output terminals of the **transformers**.

Transformers covered by this part are used in applications where **double or reinforced insulation** between circuits is required by the installation rules or by the end product standard.

NOTE 4 Attention is drawn to the following:

- for **transformers** intended to be used in vehicles, on board ships, and aircraft, additional requirements (from other applicable standards, national rules, etc.) may be necessary;

- measures to protect the **enclosure** and the components inside the enclosure against external influences such as fungus, vermin, termites, solar-radiation, and icing should also be considered;
- the different conditions for transportation, storage, and operation of the **transformers** should also be considered;
- additional requirements in accordance with other appropriate standards and national rules may be applicable to **transformers** intended for use in special environments.

NOTE 5 Future technological development of **transformers** may necessitate a need to increase the upper limit of the frequencies, until then this part may be used as a guidance document.

2 Normative references

This clause of Part 1 is applicable except as follows.

Addition:

IEC 61558-1 :2005, *Safety of power transformers, power supplies, reactors and similar products – Part 1: General requirements and tests*

3 Terms and definitions

This clause of Part 1 is applicable.

4 General requirements

This clause of Part 1 is applicable.

5 General notes on tests

This clause of Part 1 is applicable.

6 Ratings

This clause of Part 1 is applicable except as follows.

Addition:

6.101 The **rated output voltage** shall not exceed 50 V a.c. or 120 V ripple-free d.c.

6.102 The **rated output** shall not exceed:

- 10 kVA for single-phase **transformers**;
- 16 kVA for polyphase **transformers**.

Transformers without limitation of the **rated output** shall be subject to agreement between the purchaser and the manufacturer.

6.103 The **rated supply frequency** and the **internal operating frequencies** shall not exceed 500 Hz.

6.104 The **rated supply voltage** shall not exceed 1 100 V a.c.

Compliance with the requirements of 6.101 to 6.104 is checked by inspection of the marking.