
**Resilient and laminate floor
coverings — Determination
of indentation and residual
indentation —**

**Part 3:
Indentation of resilient semi-flexible/
vinyl composition tiles**

*Revêtements de sol résilients et stratifiés — Détermination du
poinçonnement et du poinçonnement rémanent —*

*Partie 3: Poinçonnement de carreaux semi-flexibles/carreaux de
composition vinylique résilients*



This document is a preview generated by EMS



COPYRIGHT PROTECTED DOCUMENT

© ISO 2018

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Fax: +41 22 749 09 47
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Contents

	Page
Foreword	iv
1 Scope	1
2 Normative references	1
3 Terms and definitions	1
4 Principle	1
5 Apparatus	1
6 Atmosphere for conditioning and testing	2
7 Sampling and selection of specimens	3
8 Test procedure	3
9 Calculation and expression of results	3
10 Test report	3
Bibliography	4

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see the following URL: www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 219, *Floor coverings*.

This second edition cancels and replaces the first edition (ISO 24343-3:2011), which has been technically revised.

The main changes compared to the previous edition are as follows:

- [Clause 2](#) has been added;
- former Clause 9 (“Precision statement”) has been removed;
- some minor technical and editorial changes have been made for clarity.

A list of all parts in the ISO 24343 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

Resilient and laminate floor coverings — Determination of indentation and residual indentation —

Part 3:

Indentation of resilient semi-flexible/vinyl composition tiles

1 Scope

This document describes a method for determining the short-term indentation resistance of resilient semi-flexible/vinyl composition tile (VCT) floor covering after the application of constant load.

2 Normative references

There are no normative references in this document.

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <http://www.electropedia.org/>

3.1

indentation

difference between the initial thickness and the thickness measured after removal of the load

3.2

thickness

distance between two parallel plates where the floor covering is inserted under a specific load

4 Principle

Test pieces are subjected to static loading at room temperature, the thickness being measured before and during loading at specified dwell periods.

5 Apparatus

5.1 Water bath capable of maintaining a temperature of $(23 \pm 2,0)$ °C.

NOTE This is optional.

5.2 Indenter, consisting of a straight, steel cylinder with the following characteristics:

- diameter of the indenter: $(6,35 \pm 0,01)$ mm;
- hemispherical foot;
- weight of the indenter: $(0,90 \pm 0,05)$ kg.