

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**High-voltage switchgear and controlgear –
Part 209: Cable connections for gas-insulated metal-enclosed switchgear for
rated voltages above 52 kV – Fluid-filled and extruded insulation cables – Fluid-
filled and dry-type cable terminations**

**Appareillage à haute tension –
Partie 209: Raccordement de câbles pour appareillage sous enveloppe
métallique à isolation gazeuse de tension assignée supérieure à 52 kV – Câbles
remplis d'un fluide ou à isolation extrudée – Extrémité de câble de type sec ou
remplie d'un fluide**



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2019 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 000 terminological entries in English and French, with equivalent terms in 16 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

67 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Recherche de publications IEC - webstore.iec.ch/advsearchform

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et une fois par mois par email.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: sales@iec.ch.

Electropedia - www.electropedia.org

Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22 000 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 16 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Glossaire IEC - std.iec.ch/glossary

67 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**High-voltage switchgear and controlgear –
Part 209: Cable connections for gas-insulated metal-enclosed switchgear for
rated voltages above 52 kV – Fluid-filled and extruded insulation cables – Fluid-
filled and dry-type cable terminations**

**Appareillage à haute tension –
Partie 209: Raccordement de câbles pour appareillage sous enveloppe
métallique à isolation gazeuse de tension assignée supérieure à 52 kV – Câbles
remplis d'un fluide ou à isolation extrudée – Extrémité de câble de type sec ou
remplie d'un fluide**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 29.130.10

ISBN 978-2-8322-6405-8

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	4
1 Scope.....	6
2 Normative references	6
3 Terms and definitions	7
4 Normal and special service conditions	8
4.1 General.....	8
4.2 Normal service conditions	8
4.3 Special service conditions.....	8
5 Ratings.....	8
5.1 General.....	8
5.2 Rated voltage of the equipment of the cable connection (U_{RM}).....	9
5.3 Rated insulation level (U_d , U_p , U_s).....	9
5.4 Rated frequency (f_r).....	9
5.5 Rated continuous current (I_r)	9
5.6 Rated short-time withstand current (I_k)	9
5.7 Rated peak withstand current (I_p)	9
5.8 Rated duration of short circuit (t_k).....	9
6 Design and construction	10
6.1 Gas and vacuum tightness	10
6.101 Limits of supply.....	10
6.101.1 General	10
6.101.2 Over-voltage protection and earthing.....	10
6.102 Filling pressure of insulating gas in the cable connection enclosure	11
6.103 Pressure withstand requirements	11
6.104 Mechanical forces on cable terminations.....	11
6.105 Switchgear connection interface and cable termination connection interface.....	12
7 Type tests	12
7.1 General.....	12
7.2 Electrical type tests of cable terminations	12
7.2.1 General	12
7.2.2 Electrical type test of cable terminations in a single-phase enclosure	12
7.2.3 Electrical type test of cable termination in a three-phase enclosure	12
7.2.4 Additional electrical type tests on the insulator to be installed by switchgear manufacturer (plug in cable termination)	13
7.3 Pressure test on the insulator of a cable termination	13
7.4 Leak rate type test on the insulator of a cable termination.....	14
8 Routine tests	14
8.1 General.....	14
8.2 Pressure test	14
8.3 Visual inspection.....	14
9 Standard dimensions	14
9.1 General.....	14
9.2 Fluid-filled cable terminations	14
9.3 Dry-type cable terminations	15
9.4 Three-phase cable connection enclosure	15

10	Information to be given with enquiries, tenders and orders	15
11	Rules for transport, storage, erection, service and maintenance	15
11.1	General.....	15
11.2	Tests after cable system installation	16
12	Safety practices and constraints during installation of cable connection to switchgear	16
13	Influence of the product on the environment	16
Annex A (informative) Mechanical forces applied on the flange of the cable connection enclosure		21
A.1	General.....	21
A.2	Recommendation when connecting cable systems to switchgear	21
Bibliography.....		23
Figure 1 – Operating pressure of the SF ₆ gas insulation in the cable connection enclosure		11
Figure 2 – Fluid-filled cable connection assembly – Typical arrangement.....		17
Figure 3 – Fluid-filled cable connection – Assembly dimensions		18
Figure 4 – Dry-type cable connection assembly – Typical arrangement.....		19
Figure 5 – Dry-type cable connection assembly – Assembly dimensions.....		20
Table 1 – Test voltages for additional electrical type tests according to 7.2.4.....		13
Table A.1 – Moment and forces applied on the flange of the cable connection enclosure attached to the cable termination during normal operation		22

INTERNATIONAL ELECTROTECHNICAL COMMISSION

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –**Part 209: Cable connections for gas-insulated metal-enclosed switchgear for rated voltages above 52 kV – Fluid-filled and extruded insulation cables – Fluid-filled and dry-type cable terminations**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62271-209 has been prepared by subcommittee 17C: Assemblies, of IEC technical committee 17: High-voltage switchgear and controlgear.

This second edition cancels and replaces the first edition published in 2007. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) New numbering in accordance with ISO/IEC directives, Part 2 (2016) and to IEC 62271-1:2017;
- b) Clause 3: addition of a definition for plug-in cable termination, filling pressure and minimum function pressure for insulation;

- c) Clause 7: An additional dielectric type test for plug-in cable termination was added; also a pressure type test as well as a leak rate test on the insulator of a cable termination was implemented;
- d) Clause 12: New clause about safety practices;
- e) Clause 13: New clause about influence of the product on the environment;
- f) New informative Annex A: Mechanical forces applied on the flange of the cable connection enclosure.

The text of this standard is based on the following documents:

FDIS	Report on voting
17C/696/FDIS	17C/701/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

This standard is to be read in conjunction with IEC 62271-1:2017, to which it refers and which is applicable unless otherwise specified in this standard. In order to simplify the indication of corresponding requirements, the same numbering of clauses and subclauses is used as in IEC 62271-1. Amendments to these clauses and subclauses are given under the same references whilst additional subclauses are numbered from 101.

A list of all parts in the IEC 62271 series, published under the general title *High-voltage switchgear and controlgear*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 209: Cable connections for gas-insulated metal-enclosed switchgear for rated voltages above 52 kV – Fluid-filled and extruded insulation cables – Fluid-filled and dry-type cable terminations

1 Scope

This part of IEC 62271 covers the connection assembly of fluid-filled and extruded cables to gas-insulated metal enclosed switchgear (GIS), in single- or three-phase arrangements where the cable terminations are fluid-filled or dry-type and there is a separating insulating barrier between the cable insulation and the gas insulation of the switchgear.

The purpose of this document is to establish electrical and mechanical interchangeability between cable terminations and the gas-insulated metal-enclosed switchgear and to determine the limits of supply. It complements and amends, if applicable, the relevant IEC standards. For the purpose of this document the term "switchgear" is used for "gas-insulated metal enclosed switchgear".

It does not cover directly immersed cable terminations, as described in CIGRE brochure 89 [4]¹.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60038, *IEC standard voltages*

IEC 60068-2-17:1994, *Basic environmental testing procedures – Part 2-17:Tests – Test Q: Sealing*

IEC 60141 (all parts), *Tests on oil-filled and gas-pressure cables and their accessories*

IEC 60376, *Specification of technical grade sulphur hexafluoride (SF₆) and complementary gases to be used in its mixtures for use in electrical equipment*

IEC 60480, *Guidelines for the checking and treatment of sulphur hexafluoride (SF₆) taken from electrical equipment and specification for its re-use*

IEC 60840, *Power cables with extruded insulation and their accessories for rated voltages above 30 kV (U_m = 36 kV) up to 150 kV (U_m = 170 kV) – Test methods and requirements*

IEC 62067, *Power cables with extruded insulation and their accessories for rated voltages above 150 kV (U_m = 170 kV) up to 500 kV (U_m = 550 kV) – Test methods and requirements*

¹ Numbers in square brackets refer to the Bibliography.

IEC 62271-1:2017, *High-voltage switchgear and controlgear – Part 1:Common specifications for alternating current switchgear and controlgear*

IEC 62271-203:2011, *High-voltage switchgear and controlgear – Part 203:Gas-insulated metal-enclosed switchgear for rated voltages above 52 kV*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

3.1

cable termination

equipment fitted to the end of a cable to ensure electrical connection with other parts of the system and to maintain the insulation up to the point of connection

3.1.1

fluid-filled cable termination

cable termination which comprises a separating insulating barrier between the cable insulation and the gas insulation of switchgear, including a fluid

3.1.2

dry-type cable termination

cable termination which comprises an elastomeric electrical stress control component in direct contact with a separating insulating barrier (insulator) between the cable insulation and the gas insulation of the switchgear, not requiring any fluid

3.2

main circuit end terminal

part of the main circuit of a gas-insulated metal enclosed switchgear forming part of the connection interface

3.3

cable connection enclosure

part of the gas-insulated metal-enclosed switchgear which houses the cable termination and the main circuit end terminal

3.4

cable connection assembly

combination of a cable termination, a cable connection enclosure and a main circuit end terminal, which mechanically and electrically connects the cable to the gas-insulated metal enclosed switchgear

3.5

plug-in cable termination

cable termination where cable/stress cone assembly can be engaged into the insulator assembly that is already installed into switchgear enclosure

3.6

design pressure

pressure used to determine the design of the enclosure and the components of the cable termination subjected to that pressure