

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Nuclear power plants – Instrumentation, control and electrical power systems –
Requirements for static uninterruptible DC and AC power supply systems**

**Centrales nucléaires de puissance – Systèmes d'instrumentation, de contrôle-
commande et d'alimentation électrique – Exigences pour les systèmes
d'alimentation en courant alternatif et en courant continu statiques sans
interruption**



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2019 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 000 terminological entries in English and French, with equivalent terms in 16 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

67 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Recherche de publications IEC -

webstore.iec.ch/advsearchform

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et une fois par mois par email.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: sales@iec.ch.

Electropedia - www.electropedia.org

Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22 000 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 16 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Glossaire IEC - std.iec.ch/glossary

67 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Nuclear power plants – Instrumentation, control and electrical power systems –
Requirements for static uninterruptible DC and AC power supply systems**

**Centrales nucléaires de puissance – Systèmes d'instrumentation, de contrôle-
commande et d'alimentation électrique – Exigences pour les systèmes
d'alimentation en courant alternatif et en courant continu statiques sans
interruption**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 27.120.20

ISBN 978-2-8322-6382-2

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	8
2 Normative references	8
3 Terms and definitions	9
4 Abbreviated terms	11
5 System requirements.....	11
5.1 General.....	11
5.2 Function and description	12
5.2.1 Preamble.....	12
5.2.2 Designations.....	14
5.2.3 Direct current systems.....	14
5.2.4 Alternating current systems	14
5.3 System divisions.....	15
5.4 System boundaries	15
6 Functional requirements for static uninterruptible power supplies	15
6.1 Static uninterruptible power supplies for systems important to safety	15
6.2 Batteries and battery chargers.....	16
6.3 Inverters and bypass switches	17
6.4 UPS.....	18
6.5 Converters used for voltage stabilization.....	18
6.6 I&C power supply using DC/DC-converters and AC/DC-converters	19
7 Requirements for distribution systems	19
7.1 System aspects	19
7.2 Load allocation	19
7.3 Electrical aspects.....	21
7.4 Earthing.....	22
8 Effects of loads on supply quality.....	22
8.1 General.....	22
8.2 Electromagnetic interference.....	22
8.3 Transients.....	22
8.4 Load current	23
8.5 Power supplies to loads of lower safety classification.....	23
9 Monitoring and protection	23
9.1 General.....	23
9.2 Monitoring.....	24
9.3 Electrical protection	24
10 Qualification of equipment	25
11 Design to cope with ageing.....	25
12 Testing	25
13 Maintenance.....	26
Annex A (informative) Examples of voltage input variations	27
Annex B (informative) Examples of specifications	29
B.1 Example 1: Specification for an DC power supply for equipment requiring a non-interruptible supply.....	29

B.2 Example 2: Specification for AC power supply for equipment requiring a non-interruptible supply 30

B.3 Example 3: Specification for DC power supply with DC/DC converter for equipment..... 31

B.4 Human factor engineering programme 31

Bibliography..... 33

Figure 1 – System boundary 13

Figure 2 – Example of one division of an uninterruptible power supply system 20

Figure 3 – Example of I&C uninterruptible AC power supply system..... 21

Figure A.1 – Example of voltage variations on the on-site AC power system during clearing of a transmission system fault 27

Figure A.2 – Example of on-site voltage profile after loss of load (transfer to house load operation)..... 27

Figure A.3 – Example of simulated safety bus voltages, double open phase condition in the 400 kV line to the unit transformer..... 28

Table B.1 – Example 1 29

Table B.2 – Example 2..... 30

Table B.3 – Example 3..... 31

is a preview generated by EVS

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**NUCLEAR POWER PLANTS – INSTRUMENTATION, CONTROL AND
ELECTRICAL POWER SYSTEMS – REQUIREMENTS FOR STATIC
UNINTERRUPTIBLE DC AND AC POWER SUPPLY SYSTEMS****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61225 has been prepared by subcommittee 45A: Instrumentation, control and electrical power systems of nuclear facilities, of IEC technical committee 45: Nuclear instrumentation.

This third edition cancels and replaces the second edition published in 2005. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) the principal objective of this edition is to address the requirements on the static uninterruptible power supplies in nuclear power plants;
- b) in addition to Instrumentation and Control (I&C) power supplies include all static uninterruptible power supplies;

- c) emphasize that the static uninterruptible power supplies shall protect the connected equipment (loads) from transients on the on-site AC distribution system (the immunity concept);
- d) in accordance with the defence-in-depth concept, this standard applies to static uninterruptible power supplies for all equipment, not only for equipment important to safety, with a graded approach to verification and validation;
- e) addition of the requirement that, when batteries are connected in parallel under abnormal operating conditions, they shall be properly protected with isolation devices to avoid any failure that may impair more than one division of the uninterruptible power supply.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
45A/1235/FDIS	45A/1250/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

a) Technical background, main issues and organization of the standard

The 1993 issue of IEC 61225 was developed for specifying the requirements relevant to the design of electrical supplies for I&C systems in nuclear power plants. Considering the experience gathered worldwide on this subject, in 2003 working group A2 recommended a revision to this standard so that a new revision, IEC 61225 Ed. 2 (2005), could be consistently integrated into the SC 45A standard series. In 2015, working group A11 recommended a revision to this standard following the publication of the revision of IAEA SSG-34 and that the scope of the standard should cover static uninterruptible power supplies for all types of connected equipment.

International operating experience with electrical supply systems in nuclear power plants has highlighted a number of supply voltage variations and malfunctions, such as:

- voltage perturbations due to disturbances on the internal AC distribution system (with origin off-site or on-site);
- voltage overshoot on loss of grid;
- open phase conditions (one or two phases);
- asymmetrical faults.

These types of perturbations can degrade the performance of static uninterruptible power supplies and ultimately result in failure of connected equipment.

One of the objectives of the uninterruptible power supplies is to protect the connected equipment from voltage variations on the on-site AC distribution system (the immunity concept). The power supplies shall also guarantee an output voltage with specified magnitude and waveform (in case of AC) to connected loads. The power supplies shall have the capacity to supply the relevant loads during a specified time regardless of any voltage variations on the on-site AC distribution system.

Examples of voltage and frequency variations in the incoming feeder to the supplies can be found in informative Annex A. Examples of specifications for static uninterruptible power supplies can be found in informative Annex B.

This standard is applicable to the design of static uninterruptible electrical power supplies in new nuclear power plants, when design work is initiated after the publication of this standard. It also serves as a reference for upgrading and modernizing existing nuclear power plants.

b) Situation of the current standard in the structure of the SC 45A standard series

IEC 61225 is a second level document specifically addressing the particular topic of requirements for electrical supplies.

For more details on the structure of the SC 45A standard series, see item d) of this introduction.

c) Recommendations and limitations regarding the application of this standard

This standard is to be applied in conjunction with IEC 61513, IEC 60709, IEC 60880, IEC 62138, IEC 62855 and IEC 63046 (to be published).

d) Description of the structure of the IEC SC 45A standard series and relationships with other IEC documents and other bodies documents (IAEA, ISO)

The top-level documents of the IEC SC 45A standard series are IEC 61513 and IEC 63046. IEC 61513 provides general requirements for I&C systems and equipment that are used to perform functions important to safety in NPPs. IEC 63046 provides general requirements for electrical power systems of NPPs; it covers power supply systems including the supply systems of the I&C systems. IEC 61513 and IEC 63046 are to be considered in conjunction and at the same level. IEC 61513 and IEC 63046 structure the IEC SC 45A standard series and shape a complete framework establishing general requirements for instrumentation, control and electrical systems for nuclear power plants.

IEC 61513 and IEC 63046 refer directly to other IEC SC 45A standards for general topics related to categorization of functions and classification of systems, qualification, separation, defence against common cause failure, control room design, electromagnetic

compatibility, cybersecurity, software and hardware aspects for programmable digital systems, coordination of safety and security requirements and management of ageing. The standards referenced directly at this second level should be considered together with IEC 61513 and IEC 63046 as a consistent document set.

At a third level, IEC SC 45A standards not directly referenced by IEC 61513 or by IEC 63046 are standards related to specific equipment, technical methods, or specific activities. Usually these documents, which make reference to second-level documents for general topics, can be used on their own.

A fourth level extending the IEC SC 45 standard series, corresponds to the Technical Reports which are not normative.

The IEC SC 45A standards series consistently implements and details the safety and security principles and basic aspects provided in the relevant IAEA safety standards and in the relevant documents of the IAEA nuclear security series (NSS). In particular this includes the IAEA requirements SSR-2/1, establishing safety requirements related to the design of nuclear power plants (NPPs), the IAEA safety guide SSG-30 dealing with the safety classification of structures, systems and components in NPPs, the IAEA safety guide SSG-39 dealing with the design of instrumentation and control systems for NPPs, the IAEA safety guide SSG-34 dealing with the design of electrical power systems for NPPs and the implementing guide NSS17 for computer security at nuclear facilities. The safety and security terminology and definitions used by SC 45A standards are consistent with those used by the IAEA.

IEC 61513 and IEC 63046 have adopted a presentation format similar to the basic safety publication IEC 61508 with an overall life-cycle framework and a system life-cycle framework. Regarding nuclear safety, IEC 61513 and IEC 63046 provide the interpretation of the general requirements of IEC 61508-1, IEC 61508-2 and IEC 61508-4, for the nuclear application sector. In this framework IEC 60880, IEC 62138 and IEC 62566 correspond to IEC 61508-3 for the nuclear application sector. IEC 61513 and IEC 63046 refer to ISO as well as to IAEA GS-R part 2 and IAEA GS-G-3.1 and IAEA GS-G-3.5 for topics related to quality assurance (QA). At level 2, regarding nuclear security, IEC 62645 is the entry document for the IEC/SC 45A security standards. It builds upon the valid high level principles and main concepts of the generic security standards, in particular ISO/IEC 27001 and ISO/IEC 27002; it adapts them and completes them to fit the nuclear context and coordinates with the IEC 62443 series. At level 2, IEC 60964 is the entry document for the IEC/SC 45A control rooms standards and IEC 62342 is the entry document for the ageing management standards.

NOTE 1 It is assumed that for the design of I&C systems in NPPs that implement conventional safety functions (e.g. to address worker safety, asset protection, chemical hazards, process energy hazards) international or national standards would be applied.

NOTE 2 IEC/SC 45A domain was extended in 2013 to cover electrical systems. In 2014 and 2015 discussions were held in IEC/SC 45A to decide how and where general requirements for the design of electrical systems were to be considered. IEC/SC 45A experts recommended that an independent standard be developed at the same level as IEC 61513 to establish general requirements for electrical systems. Project IEC 63046 is now launched to cover this objective. When IEC 63046 is published, this NOTE 2 of the introduction of IEC/SC 45A standards will be suppressed.

NUCLEAR POWER PLANTS – INSTRUMENTATION, CONTROL AND ELECTRICAL POWER SYSTEMS – REQUIREMENTS FOR STATIC UNINTERRUPTIBLE DC AND AC POWER SUPPLY SYSTEMS

1 Scope

This document specifies the performance and the functional characteristics of the low voltage static uninterruptible power supply (SUPS) systems in a nuclear power plant and, for applicable parts, in general for nuclear facilities. An uninterruptible power supply is an electrical equipment which draws electrical energy from a source, stores it and maintains supply in a specified form by means inside the equipment to output terminals. A static uninterruptible power supply (SUPS) has no rotating parts to perform its functions.

The specific design requirements for the components of the power supply system are covered by IEC standards and standards listed in the normative references and are otherwise outside the scope of this document.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60038, *IEC standard voltages*

IEC 60146-1-1, *Semiconductor converters – General requirements and line commutated converters – Part 1-1: Specification of basic requirements*

IEC 60146-2, *Semiconductor converters – Part 2: Self-commutated semiconductor converters including direct d.c. converters*

IEC 60364-4-41, *Low voltage electrical installations – Part 4.41: Protection for safety – Protection against electric shock*

IEC 60709, *Nuclear power plants – Instrumentation, control and electrical power systems important to safety – Separation*

IEC/IEEE 60780-323, *Nuclear power plants – Electrical equipment important to safety – Qualification*

IEC 60880, *Nuclear power plants – Instrumentation and control systems important to safety – Software aspects for computer-based systems performing category A functions*

IEC 60980, *Recommended practices for seismic qualification of electrical equipment of the safety system for nuclear generating stations*

IEC 61000 (all parts), *Electromagnetic compatibility (EMC)*

IEC 61508 (all parts), *Functional safety of electrical/electronic/programmable electronic safety-related systems*

IEC 61513, *Nuclear power plants – Instrumentation and control important to safety – General requirements for systems*

IEC 62003, *Nuclear power plants – Instrumentation and control important to safety – Requirements for electromagnetic compatibility testing*

IEC 62040 (all parts), *Uninterruptible power systems (UPS)*

IEC 62138, *Nuclear power plants – Instrumentation and control systems important to safety – Software aspects for computer-based systems performing category B or C functions*

IEC 62566, *Nuclear power plants – Instrumentation and control important to safety – Development of HDL-programmed integrated circuits for systems performing category A functions*

IEC 62566-2, *Nuclear power plants – Instrumentation and control important to safety – Development of HDL-programmed integrated circuits – Part 2: HDL-programmed integrated circuits for systems performing category B or C functions* (to be published)

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

NOTE Other terms not defined below are defined in IAEA Safety Guides SSG-34 and SSG-39.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

3.1

anticipated operational occurrence

AOO

deviation of an operational process from normal operation that is expected to occur at least once during the operating lifetime of a facility but which, in view of appropriate design provisions, does not cause any significant damage to items important to safety or lead to accident conditions

[SOURCE: Source IAEA Safety Glossary, 2016 edition]

3.2

battery charger

electrical item used to convert AC into DC to charge batteries and to supply power to DC loads during normal operation

Note 1 to entry: The battery charger provides transformer isolation of the DC output from the AC input and is equipped with regulation and monitoring.

[SOURCE: IEEE 946, 2004]

3.3

common cause failure

CCF

failures of two or more structures, systems and components due to a single specific event or cause

[SOURCE: IAEA Safety Glossary, 2016 edition]