

ÜLDNÕUDED ÄRAVOOLU- JA
KANALISATSIOONITORUSTIKES KASUTATAVATELE
KOMPONENTIDELE

General requirements for components used in drains
and sewers

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 476:2022 sisaldab Euroopa standardi EN 476:2022 ingliskeelset teksti.	This Estonian standard EVS-EN 476:2022 consists of the English text of the European standard EN 476:2022.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation and Accreditation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 27.04.2022.	Date of Availability of the European standard is 27.04.2022.
Standard on kättesaadav Eesti Standardimis-ja Akrediteerimiskeskusest.	The standard is available from the Estonian Centre for Standardisation and Accreditation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 23.040.05, 93.030

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardimis- ja Akrediteerimiskeskusele. Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardimis- ja Akrediteerimiskeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardimis- ja Akrediteerimiskeskusega: Koduleht www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation and Accreditation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation and Accreditation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation and Accreditation:

Homepage www.evs.ee; phone +372 605 5050; e-mail info@evs.ee

EUROPEAN STANDARD

EN 476

NORME EUROPÉENNE

EUROPÄISCHE NORM

April 2022

ICS 93.030; 23.040.05

Supersedes EN 476:2011

English Version

General requirements for components used in drains and sewers

Exigences générales pour les composants utilisés pour les branchements et les collecteurs d'assainissement

Allgemeine Anforderungen an Bauteile für Abwasserleitungen und -kanäle

This European Standard was approved by CEN on 20 March 2022.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents	Page
European foreword.....	4
1 Scope	5
2 Normative references	6
3 Terms and definitions	6
4 Symbols and abbreviations	12
5 Dimensional requirements	13
5.1 General	13
5.2 Dimensions of pipes and fittings	13
5.2.1 Nominal sizes	13
5.2.2 Internal diameters and tolerances	13
5.2.3 Geometrical characteristics of pipes	13
5.2.4 Geometrical characteristics of fittings	14
5.3 Dimensions of manholes and inspection chambers	15
5.3.1 Manholes	15
5.3.2 Inspection chambers	16
5.3.3 Geometrical characteristics of manholes and inspection chambers	16
5.4 Covers and frames	16
5.5 Connection to the piping system and components	17
6 Performance requirements	17
6.1 General	17
6.2 Mechanical requirements of pipes and fittings	17
6.3 Mechanical requirements of shafts of manholes and inspection chambers	18
6.3.1 General	18
6.3.2 Circular sections	18
6.3.3 Other shapes	18
6.3.4 Tapers/cones, reducing and cover slabs	19
6.4 Tightness	19
6.4.1 Test pressure	19
6.4.2 Sealings for joints	20
6.4.3 Joint deflection	21
6.4.4 Joint shear load	21
6.4.5 Restrained joints	22
6.5 Continuity of invert	22
6.6 Temperature resistance	22
6.7 Dimensional stability	22
6.8 Smoothness of bore	23
6.9 Appearance	23
6.10 Chemical and corrosion resistance	23
6.11 Abrasion resistance	23
6.12 Coatings and linings	23
6.13 Durability	23
6.14 Resistance against cleaning operations	23
6.15 Handling	23
6.16 Reaction to fire	23
7 Test methods	23

7.1	Measurement of dimensions	23
7.1.1	Internal diameter	23
7.1.2	External diameter.....	24
7.1.3	Spigots and sockets.....	24
7.1.4	Wall thickness of pipes.....	24
7.1.5	Deviation from straightness of pipes	24
7.1.6	Deviation from squareness of the ends of the pipes	24
7.2	Load bearing capacity tests.....	24
7.2.1	Load bearing capacity tests for pipes	24
7.2.2	Load bearing capacity tests for sections of manholes and shafts.....	25
7.3	Longitudinal bending moment resistance test for pipes	25
7.4	Tightness tests	26
7.4.1	Tightness test of pipes, fittings, manholes and inspection chambers	26
7.4.2	Tightness test of joints.....	27
7.4.3	Test methods for drains and sewers components.....	28
8	Marking, labelling and packaging.....	28
Annex A (informative) Preferred nominal sizes.....		29
Bibliography		30

European foreword

This document (EN 476:2022) has been prepared by Technical Committee CEN/TC 165 “Waste water engineering”, the secretariat of which is held by DIN.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by October 2022, and conflicting national standards shall be withdrawn at the latest by October 2022.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 476:2011.

The specifications of this document are based on the requirements for wastewater systems specified in EN 752 and EN 12056 (all parts). Significant technical differences between this edition and EN 476:2011 are as follows:

- a) the Scope is clarified in the way that this document contains requirements for product standards;
- b) Table 1 (Preferred nominal sizes DN/ID) and Table 2 (Preferred nominal sizes DN/OD), paragraph 5.2.1, are moved to the new Annex A;
- c) the paragraphs under 5.3, Dimensions of manholes and inspection chambers, are completely rewritten, with minimum internal dimension for different cross sections (always in compliance with the national regulations in force at the place of installation);
- d) for reaction to fire, a new 6.16 is added.

This document provides a framework for the development of product standards to be used in drain and sewer systems inside and outside buildings. In Figure 1 the position of this document related to other standards on this subject is given.

This document describes the general requirements to be taken into account in product standards.

Any feedback and questions on this document should be directed to the users' national standards body. A complete listing of these bodies can be found on the CEN website.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.




Figure 1 — Pyramid diagram

1 Scope

This document specifies general requirements to be respected in product standards for components such as pipes, fittings, inspection chambers and manholes with their respective joints intended for use in drains and sewers inside and outside buildings which operate as gravity systems allowing for a maximum pressure of 40 kPa.

It also specifies general requirements for components used in hydraulically and pneumatically pressurized pipes, drains and sewers.

NOTE 1 Where the term “inside buildings” is used in the context of components fixed inside buildings, it also includes pipes and fittings fixed on external surfaces of buildings.

NOTE 2 This document is not a product standard and therefore not intended for the direct evaluation of products.

This document covers components to be used in conveying in a satisfactory manner:

- domestic wastewater;
- rainwater and surface water;
- other wastewater acceptable for discharge into the system.

This document is applicable to components of circular and other cross sections.

This document is equally applicable to components which are factory-made and to those constructed on site, where applicable.

NOTE 3 This document does not apply to components used for trenchless construction according to EN 14457 and for components used for renovation of drains and sewers according to EN 13380.

This document does not supersede the functional requirements of a complete system as defined in EN 752.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 124 (all parts), *Gully tops and manhole tops for vehicular and pedestrian areas*

EN 681-1, *Elastomeric seals - Materials requirements for pipe joint seals used in water and drainage applications - Part 1: Vulcanized rubber*

EN 681-2, *Elastomeric seals - Material requirements for pipe joint seals used in water and drainage applications - Part 2: Thermoplastic elastomers*

EN 681-3, *Elastomeric seals - Material requirements for pipe joint seals used in water and drainage applications - Part 3: Cellular materials of vulcanized rubber*

EN 681-4, *Elastomeric seals - Material requirements for pipe joint seals used in water and drainage applications - Part 4: Cast polyurethane sealing elements*

EN 13501-1, *Fire classification of construction products and building elements - Part 1: Classification using data from reaction to fire tests*

EN 13823, *Reaction to fire tests for building products - Building products excluding floorings exposed to the thermal attack by a single burning item*

EN 16000, *Plastics piping systems - Systems within the building structure - Mounting and fixing of components in the test apparatus to thermal attack by a single burning item*

EN ISO 9967, *Thermoplastics pipes - Determination of creep ratio (ISO 9967)*

EN ISO 9969, *Thermoplastics pipes - Determination of ring stiffness (ISO 9969)*

EN ISO 11925-2, *Reaction to fire tests - Ignitability of products subjected to direct impingement of flame - Part 2: Single-flame source test (ISO 11925-2)*

ISO 48-2, *Rubber, vulcanized or thermoplastic — Determination of hardness — Part 2: Hardness between 10 IRHD and 100 IRHD*

3 Terms and definitions

For the purposes of this document, the following terms and definitions are applicable.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp/ui>
- IEC Electropedia: available at <https://www.electropedia.org/>

3.1 crushing strength

load per unit length a rigid pipe is required to withstand in kN/m