

**JUHTMED JA KAABLID. MADALPINGELISED
TUGEVVOOLUJUHTMED JA -KAABLID NIMIPINGEGA
KUNI 450/750 V (U₀/U). OSA 1: ÜLDNÕUDED**

**Electric cables - Low voltage energy cables of rated
voltages up to and including 450/750 V (U₀/U) -
Part 1: General requirements**

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 50525-1:2011+A1:2022 sisaldab Euroopa standardi EN 50525-1:2011 ja selle muudatuse A1:2022 ingliskeelset teksti.	This Estonian standard EVS-EN 50525-1:2011+A1:2022 consists of the English text of the European standard EN 50525-1:2011 and its amendment A1:2022.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas. Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 06.05.2011, muudatus A1 04.11.2022.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation and Accreditation. Date of Availability of the European standard is 06.05.2011, for A1 04.11.2022.
Muudatusega A1 lisatud või muudetud teksti algus ja lõpp on tekstis tähistatud sümbolitega $\boxed{A_1}$ $\langle A_1 \rangle$.	The start and finish of text introduced or altered by amendment A1 is indicated in the text by tags $\boxed{A_1}$ $\langle A_1 \rangle$.
Standard on kättesaadav Eesti Standardimis- ja Akrediteerimiskeskusest.	The standard is available from the Estonian Centre for Standardisation and Accreditation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 29.060.20

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardimis- ja Akrediteerimiskeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardimis- ja Akrediteerimiskeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autoriõiguse kaitse kohta, võtke palun ühendust Eesti Standardimis- ja Akrediteerimiskeskusega: Koduleht www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation and Accreditation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation and Accreditation.

If you have any questions about standards copyright protection, please contact the Estonian Centre for Standardisation and Accreditation:

Homepage www.evs.ee; phone +372 605 5050; e-mail info@evs.ee

English Version

Electric cables - Low voltage energy cables of rated voltages up to and including 450/750 V (U0/U) - Part 1: General requirements

Câbles électriques - Câbles d'énergie basse tension de tension assignée au plus égale à 450/750 V (U0/U) - Partie 1: Exigences générales

Kabel und Leitungen - Starkstromleitungen mit Nennspannungen bis 450/750 V (U0/U) - Teil 1: Allgemeine Anforderungen

This European Standard was approved by CENELEC on 2011-01-17. Amendment A1 was approved by CENELEC on 2022-10-10. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard and its amendment the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard and its Amendment A1 exist in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Foreword

This European Standard was prepared by the Technical Committee CENELEC TC 20, Electric cables.

The text of the draft was submitted to the formal vote and was approved by CENELEC as EN 50525-1 on 2011-01-17.

This document, which is one of a multipart series, supersedes HD 21.1 S4:2002 and HD 22.1 S4:2002.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN and CENELEC shall not be held responsible for identifying any or all such patent rights.

The following dates were fixed:

- latest date by which the EN has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2012-01-17
- latest date by which the national standards conflicting with the EN have to be withdrawn (dow) 2014-01-17

A1 Amendment A1 European foreword

This document (EN 50525-1:2011/A1:2022) has been prepared by CLC/TC 20 “*Electric cables*”.

The following dates are fixed:

- latest date by which this document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2023-10-10
- latest date by which the national standards conflicting with this document have to be withdrawn (dow) 2025-10-10

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Any feedback and questions on this document should be directed to the users' national committee. A complete listing of these bodies can be found on the CENELEC website. **A1**

Contents

	Page
Introduction	4
1 Scope	5
2 Normative references	5
3 Terms and definitions	6
4 Rated voltage.....	6
5 Requirements for the construction of cables.....	7
5.1 General.....	7
5.2 Conductors	7
5.3 Insulation	7
5.4 Core identification	8
5.5 Assembly of cores	9
5.6 Other components.....	9
5.7 Sheath	12
6 Marking.....	14
6.1 Indication of origin.....	14
6.2 Continuity of marking.....	14
6.3 Use of the name CENELEC	15
6.4 Code designation	15
6.5 Additional voluntary marking.....	15
6.6 Additional requirements.....	15
7 Tests on completed cables	15
7.1 General.....	15
7.2 Electrical requirements.....	15
7.3 Overall dimensions.....	19
7.4 Mechanical strength of flexible cables.....	19
7.5 Assessment of halogens.....	19
A1 7.6 Reaction to fire A1	19
8 Guide to use of the cables	20
Annex A (normative) Mechanical tests – Requirements for flexible cables.....	21
A.1 Two-pulley flexing test.....	21
A.2 Wear resistance test.....	21
A.3 Three-pulley test	21
A.4 Kink test.....	22
A.5 Test for separation of cores	22
Annex B (normative) Assessment of halogens.....	23
B.1 Requirements for extruded material	23
B.2 Requirements for non-extruded materials.....	24
Annex C (normative) Determination of halogens – Elemental test	26
C.1 Equipment.....	26
C.2 Materials.....	26
C.3 Procedure	27
Annex D (normative) Requirements for core identification of multicore cables with more than five cores	28

D.1 Core identification 28

D.2 Marking by inscription..... 28

D.3 Colour coding (pilot and marker system) 28

Annex E (informative) **A1** Structure and content of EN 50525 **A1** 29

A1 Annex ZB (normative) Special national conditions **A1**..... 31

Bibliography 32

Tables

Table 1 – Requirements for electrical tests for cables 17

Table B.1 – Test method, measurement, requirements 23

Table B.2 – Sequential test programme 24

Table E.1 – General structure of EN 50525 29

A1 Table E.2 – References to previous standards HD 21 and HD 22 **A1** 30

This document is a preview generated by EVS

Introduction

Ⓐ This document provides the general part of series EN 50525. The individual product standard parts in Annex-E are for equipment manufacturers, installers and end-users.

The use of these cable standards in a different way than that recommended by EN 50565-1 and EN 50565-2 could result in a lowering of safety and/or in a reduction of the expected life of the cable.

For the relationship with EU Directive (2014/35/EU) see informative Annex ZZ of the individual parts. This part contains only the general requirements. Each separate product standard part refers to this part.

In some countries local regulation(s) may define reaction of fire performances if the product is for permanent installation in works. Performance requirements are those given in EN 50575 for relevant properties. Ⓐ

This document is a preview generated by EVS

1 Scope

This European Standard gives the general requirements for rigid and flexible energy cables of rated voltages U_0/U up to and including 450/750 V [A1] AC [A1] , used in power installations and with domestic and industrial appliances and equipment.

NOTE 1 For some types of flexible cables, the term "cord" is used.

NOTE 2 Rated voltages are given by reference to alternating current [A1] ~~deleted text~~ [A1] systems. Use of the cables in direct current [A1] ~~deleted text~~ [A1] systems is permitted.

NOTE 3 National regulations may prescribe additional performance requirements for cables that are not given in the particular requirements. For example for buildings with high levels of public access, additional fire performance requirements may be applicable,

The test methods for checking conformity with the requirements are given in other standards (see Introduction).

The particular types of cables are specified in EN 50525-2 (series) and EN 50525-3 (series). The individual parts within those two series are collectively referred to hereafter as "the particular specifications".

Only the sizes (conductor class, cross-sectional area), number of cores, other constructional features and rated voltages given in the particular specification apply to the individual cable type.

The code designations of these types of cables are in accordance with HD 361.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE One or more references to the standards below are in respect of a specific sub-division of that standard, for instance a clause, a table, a class or a type. Cross-references to these standards are undated and, at all times, the latest version applies.

[A1] EN 50565-1, *Electric cables - Guide to use for cables with a rated voltage not exceeding 450/750 V (U₀/U) - Part 1: General guidance*

EN 50565-2, *Electric cables - Guide to use for cables with a rated voltage not exceeding 450/750 V (U₀/U) - Part 2: Specific guidance related to EN 50525 cable types*

EN 50575, *Power, control and communication cables - Cables for general applications in construction works subject to reaction to fire requirements*

EN 60754-1, *Test on gases evolved during combustion of materials from cables - Part 1: Determination of the halogen acid gas content*

EN 60754-2, *Test on gases evolved during combustion of materials from cables - Part 2: Determination of acidity (by pH measurement) and conductivity* [A1]

EN 50334, *Marking by inscription for the identification of cores of electric cables*

EN 50363, *Series, Insulating, sheathing and covering materials for low-voltage energy cables*

EN 50395, *Electrical test methods for low voltage energy cables*

EN 50396 *Non electrical test methods for low voltage energy cables*

EN 60228 Conductors of insulated cables (IEC 60228)

EN 60684-2 Flexible insulating sleeving – Part 2: Methods of test (IEC 60684-2)

HD 308 Identification of cores in cables and flexible cords

HD 361 System for cable designation

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.1

type tests (Symbol T)

tests required to be made before supplying a type of cable covered by this standard on a general commercial basis, in order to demonstrate satisfactory performance characteristics to meet the intended application

NOTE These tests are of such a nature that, after they have been made, they need not be repeated unless changes are made in the cable materials, design or type of manufacturing process which might change the performance characteristics.

3.2

sample tests (Symbol S)

tests made on samples of completed cable, or components taken from a completed cable adequate to verify that the finished product meets the design specifications

3.3

routine tests (Symbol R)

tests made on all production cable lengths to demonstrate their integrity

3.4

dummy core

extruded element having the same overall diameter as the insulated core

4 Rated voltage

The rated voltage of a cable is the reference voltage for which the cable is designed.

The rated voltage in an alternating current system, is expressed by the combination of two values U_0/U , expressed in volts, where:

- a) U_0 is the r.m.s. value between any insulated conductor and “earth” (metal covering of the cable or the surrounding medium);
- b) U is the r.m.s. value between any two phase conductors of a multicore cable or of a system of single core cables.

In an alternating current system, the rated voltage of a cable should be at least equal to the nominal voltage of the system for which it is intended. This condition applies to the values of both U_0 and U .

NOTE For information about the maximum permanent permitted operating voltage of the system U_{p0} (AC or DC) refer to EN 50565-1 A_1 .