

INTERNATIONAL STANDARD



**Electric cables – Calculation of the current rating –
Part 1-1: Current rating equations (100 % load factor) and calculation of losses –
General**



THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2023 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Secretariat
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 300 terminological entries in English and French, with equivalent terms in 19 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

Preview generated by EVS



IEC 60287-1-1

Edition 3.0 2023-05
COMMENTED VERSION

INTERNATIONAL STANDARD



**Electric cables – Calculation of the current rating –
Part 1-1: Current rating equations (100 % load factor) and calculation of losses –
General**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.060.20

ISBN 978-2-8322-7059-2

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

| | |
|--|--------------|
| FOREWORD..... | 4 |
| INTRODUCTION..... | 6 |
| 1 General..... | 7 |
| 1 Scope..... | 7 |
| 2 Normative references..... | 7 |
| 3 Terms, definitions and symbols..... | 8 |
| 3.1 Terms and definitions..... | 8 |
| 3.2 Symbols..... | 8 |
| 4 Permissible current rating of cables..... | 12 |
| 4.1 General..... | 12 |
| 4.2 Buried cables where drying out of the soil does not occur or cables in air..... | 12 |
| 4.2.1 AC cables..... | 12 |
| 4.2.2 DC cables up to 5 kV..... | 13 |
| 4.3 Buried cables where partial drying-out of the soil occurs..... | 14 |
| 4.3.1 AC cables..... | 14 |
| 4.3.2 DC cables up to 5 kV..... | 14 |
| 4.4 Buried cables where drying-out of the soil shall be avoided..... | 15 |
| 4.4.1 AC cables..... | 15 |
| 4.4.2 DC cables up to 5 kV..... | 15 |
| 4.5 Cables directly exposed to solar radiation..... | 15 |
| 4.5.1 General..... | 16 |
| 4.5.2 AC cables..... | 16 |
| 5 Calculation of losses..... | 16 |
| 5.1 AC resistance of conductor..... | 16 |
| 5.1.1 General..... | 16 |
| 5.1.2 DC resistance of conductor..... | 17 |
| 5.1.3 Skin effect factor y_S | 17 |
| 5.1.4 Proximity effect factor y_P for two-core cables and for two single-core cables..... | 18 |
| 5.1.5 Proximity effect factor y_P for three-core cables and for three single-core cables..... | 18 |
| 5.1.6 Skin and proximity effects in pipe-type cables..... | 19 |
| 5.2 Dielectric losses (applicable to AC cables only)..... | 19 |
| 5.3 Loss factor for sheath and screen (applicable to power frequency AC cables only)..... | 20 |
| 5.3.1 General..... | 20 |
| 5.3.2 Two single-core cables, and three single-core cables (in trefoil formation), sheaths bonded at both ends of an electrical section..... | 21 |
| 5.3.3 Three single-core cables in flat formation, with regular transposition, sheaths bonded at both ends of an electrical section..... | 22 |
| 5.3.4 Three single-core cables in flat formation, without transposition, sheaths bonded at both ends of an electrical section..... | 22 |
| 5.3.5 Variation of spacing of single-core cables between sheath bonding points..... | 24 |
| 5.3.6 Effect of Milliken conductors..... | 24 |
| 5.3.7 Single-core cables, with sheaths bonded at a single point or cross-bonded..... | 25 |

| | | |
|--|--|----|
| 5.3.8 | Two-core unarmoured cables with common sheath | 28 |
| 5.3.9 | Three-core unarmoured cables with common sheath | 28 |
| 5.3.10 | Two-core and three-core cables with steel tape armour | 30 |
| 5.3.11 | Cables with each core in a separate lead metallic sheath (SL type) and armoured | 30 |
| 5.3.12 | Losses in screen and sheaths of pipe-type cables | 31 |
| 5.4 | Loss factor for armour, reinforcement and steel pipes (applicable to power frequency AC cables only) | 31 |
| 5.4.1 | General..... | 31 |
| 5.4.2 | Non-magnetic armour or reinforcement | 32 |
| 5.4.3 | Magnetic armour or reinforcement..... | 32 |
| 5.4.4 | Losses in steel pipes | 37 |
| | | |
| Annex A (normative) Correction factor for increased lengths of individual cores within multicore cables..... | | 43 |
| Bibliography..... | | 44 |
| List of comments..... | | 45 |
| | | |
| Table 1 – Electrical resistivities and temperature coefficients of metals used | | 38 |
| Table 2 – Skin and proximity effects – Experimental values for the coefficients k_s and k_p | | 39 |
| Table 3 – Values of relative permittivity and loss factors for the insulation of high-voltage and medium-voltage cables at power frequency | | 41 |
| Table 4 – Absorption coefficient of solar radiation for cable surfaces | | 42 |
| Table A.1 – Values of factor C_{fL} for different numbers of cores..... | | 43 |

INTERNATIONAL ELECTROTECHNICAL COMMISSION

ELECTRIC CABLES – CALCULATION OF THE CURRENT RATING –

Part 1-1: Current rating equations (100 % load factor) and calculation of losses – General

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This commented version (CMV) of the official standard IEC 60287-1-1:2023 edition 3.0 allows the user to identify the changes made to the previous IEC 60287-1-1:2006+AMD1:2014 edition 2.1. Furthermore, comments from IEC TC 20 experts are provided to explain the reasons of the most relevant changes, or to clarify any part of the content.

A vertical bar appears in the margin wherever a change has been made. Additions are in green text, deletions are in strikethrough red text. Experts' comments are identified by a blue-background number. Mouse over a number to display a pop-up note with the comment.

This publication contains the CMV and the official standard. The full list of comments is available at the end of the CMV.

IEC 60287-1-1 has been prepared by IEC technical committee 20: Electric cables. It is an International Standard.

This third edition cancels and replaces the second edition published in 2006 and Amendment 1:2014. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) thorough redefinition of symbols used across the IEC 60287 and IEC 60853 series to realign and unify definitions, eliminate inconsistencies and to improve cross-use of the different parts of both IEC 60287 and IEC 60853 series; **1**
- b) introduction of corrective factors on relevant calculated physical characteristics to take into account the effect of multicore lay-lengths; a dedicated annex to highlight correction factors for different number of cores has been introduced (Annex A).

The text of this International Standard is based on the following documents:

| | |
|--------------|------------------|
| Draft | Report on voting |
| 20/2096/FDIS | 20/2103/RVD |

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts in the IEC 60287 series, published under the general title *Electric cables – Calculation of the current rating*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

This part of IEC 60287 contains formulae for the quantities R_C , W_d , λ_1 and λ_2 .

It contains methods for calculating the permissible current rating of cables from details of the permissible temperature rise, conductor resistance, losses and thermal resistivities.

Formulae for the calculation of losses are also given.

The formulae in this document contain quantities which vary with cable design and materials used. The values given in the tables are either internationally agreed, for example, electrical resistivities and resistance temperature coefficients, or are those which are generally accepted in practice, for example, thermal resistivities and permittivities of materials. In this latter category, some of the values given are not characteristic of the quality of new cables but are considered to apply to cables after a long period of use. In order that uniform and comparable results ~~may can~~ be obtained, the current ratings should be calculated with the values given in this document. However, where it is known with certainty that other values are more appropriate to the materials and design, then these may be used, and the corresponding current rating declared in addition, provided that the different values are quoted.

Quantities related to the operating conditions of cables are liable to vary considerably from one country to another. For instance, with respect to the ambient temperature and soil thermal resistivity, the values are governed in various countries by different considerations. Superficial comparisons between the values used in the various countries ~~may can~~ lead to erroneous conclusions if they are not based on common criteria: for example, there ~~may can~~ be different expectations for the life of the cables, and in some countries design is based on maximum values of soil thermal resistivity, whereas in others average values are used. Particularly, in the case of soil thermal resistivity, it is well known that this quantity is very sensitive to soil moisture content and ~~may can~~ vary significantly with time, depending on the soil type, the topographical and meteorological conditions, and the cable loading.

The following procedure for choosing the values for the various parameters should, therefore, be adopted.

Numerical values should preferably be based on results of suitable measurements. Often such results are already included in national specifications as recommended values, so that the calculation ~~may can~~ be based on these values generally used in the country in question; a survey of such values is given in IEC 60287-3-1.

A suggested list of the information required to select the appropriate type of cable is given in IEC 60287-3-1.

ELECTRIC CABLES – CALCULATION OF THE CURRENT RATING –

Part 1-1: Current rating equations (100 % load factor) and calculation of losses – General

~~1~~ **General**

1 Scope

This part of IEC 60287 is applicable to the conditions of steady-state operation of cables at all alternating voltages, and direct voltages up to 5 kV, buried directly in the ground, in ducts, troughs or in steel pipes, both with and without partial drying-out of the soil, as well as cables in air. The term "steady state" is intended to mean a continuous constant current (100 % load factor) just sufficient to produce asymptotically the maximum conductor temperature, the surrounding ambient conditions being assumed constant.

This document provides formulae for current ratings and losses.

The formulae given are essentially literal and designedly leave open the selection of certain important parameters. These ~~may~~ can be divided into three groups:

- parameters related to construction of a cable (for example, thermal resistivity of insulating material) for which representative values have been selected based on published work;
- parameters related to the surrounding conditions, which ~~may~~ can vary widely, the selection of which depends on the country in which the cables are used or ~~are to~~ will be used;
- parameters which result from an agreement between manufacturer and user and which involve a margin for security of service (for example, maximum conductor temperature).

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

~~IEC 60027-3, Letter symbols to be used in electrical technology – Part 3: Logarithmic and related quantities, and their units~~

~~IEC 60028:1925, International standard of resistance for copper~~

~~IEC 60141 (all parts), Tests on oil-filled and gas-pressure cables and their accessories~~

IEC 60228, *Conductors of insulated cables*

IEC 60287-1-3, *Electric cables – Calculation of the current rating – Part 1-3: Current rating equations (100 % load factor) and calculation of losses – Current sharing between parallel single-core cables and calculation of circulating current losses*

IEC 60287-2-1:2023, *Electric cables – Calculation of the current rating – Part 2-1: Thermal resistance – Calculation of the thermal resistance*

~~IEC 60502-1, Power cables with extruded insulation and their accessories for rated voltages from 1 kV ($U_m = 1,2$ kV) up to 30 kV ($U_m = 36$ kV) — Part 1: Cables for rated voltages of 1 kV ($U_m = 1,2$ kV) and 3 kV ($U_m = 3,6$ kV)~~

~~IEC 60502-2, Power cables with extruded insulation and their accessories for rated voltages from 1 kV ($U_m = 1,2$ kV) up to 30 kV ($U_m = 36$ kV) — Part 2: Cables for rated voltages from 6 kV ($U_m = 7,2$ kV) up to 30 kV ($U_m = 36$ kV)~~

~~IEC 60889, Hard drawn aluminium wire for overhead line conductors~~

3 Terms, definitions and symbols

3.1 Terms and definitions

No terms and definitions are listed in this document.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- IEC Electropedia: available at <https://www.electropedia.org/>
- ISO Online browsing platform: available at <https://www.iso.org/obp>

3.2 Symbols

The symbols used in this document and the quantities which they represent are given in the following list.

| | | |
|------------|--|-----------------|
| A_A | cross-sectional area of the armour | mm ² |
| B_1, B_2 | coefficients (see 5.4.3) | Ω/m |
| C | capacitance per core | F/m |
| C_F | coefficient defined in 5.3.6 | |
| C_{fL} | coefficient to take into account the position of the neutral axis of the helically wound core in Annex A | |
| C_{gs} | coefficient used in 5.3.7.1 | |
| C_{LL} | length correction factor for considering laying up of cores | |
| C_{M1} | coefficient defined in 5.3.6 | |
| C_N | coefficient defined in 5.3.6 | |
| C_P | coefficient defined in 5.3.4 | Ω/m |
| C_p | coefficient used in 5.3.7.2 | |
| C_Q | coefficient defined in 5.3.4 | Ω/m |
| C_q | coefficient used in 5.3.7.2 | |
| D_e^* | external diameter of cable | m |
| D_i | diameter over insulation | mm |
| D_p^* | diameter over the individual core of a multicore cable | m |
| D_s | external diameter of metal sheath | mm |
| D_{oc} | diameter of the imaginary coaxial cylinder which just touches the crests of a corrugated sheath | mm |
| D_{it} | diameter of the imaginary cylinder which just touches the inside surface of the troughs of a corrugated sheath | mm |