

Composite hollow core station post insulators with a.c. voltage greater than 1 000 V and d.c. voltage greater than 1 500 V - Definitions, test methods and acceptance criteria

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

<p>See Eesti standard EVS-EN IEC 62772:2023 sisaldab Euroopa standardi EN IEC 62772:2023 ingliskeelset teksti.</p> <p>Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.</p> <p>Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 22.12.2023.</p> <p>Standard on kättesaadav Eesti Standardimis- ja Akrediteerimiskeskusest.</p>	<p>This Estonian standard EVS-EN IEC 62772:2023 consists of the English text of the European standard EN IEC 62772:2023.</p> <p>This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation and Accreditation.</p> <p>Date of Availability of the European standard is 22.12.2023.</p> <p>The standard is available from the Estonian Centre for Standardisation and Accreditation.</p>
--	---

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 29.080.10

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardimis- ja Akrediteerimiskeskusele. Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardimis- ja Akrediteerimiskeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardimis- ja Akrediteerimiskeskusega: Koduleht www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation and Accreditation. No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation and Accreditation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation and Accreditation: Homepage www.evs.ee; phone +372 605 5050; e-mail info@evs.ee

English Version

Composite hollow core station post insulators with a.c. voltage
greater than 1 000 V and d.c. voltage greater than 1 500 V -
Definitions, test methods and acceptance criteria
(IEC 62772:2023)

Isolateurs supports composites creux présentant une
tension alternative supérieure à 1 000 V et une tension
continue supérieure à 1 500 V - Définitions, méthodes
d'essai et critères d'acceptation
(IEC 62772:2023)

Hohlkern-Verbundstützisolatoren für Schaltanlagen mit
einer Wechselspannung über 1 000 V und einer
Gleichspannung über 1 500 V - Begriffe, Prüfverfahren und
Annahmekriterien
(IEC 62772:2023)

This European Standard was approved by CENELEC on 2023-12-20. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

European foreword

The text of document 36/569/FDIS, future edition 2 of IEC 62772, prepared by IEC/TC 36 "Insulators" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 62772:2023.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2024-09-20
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2026-12-20

This document supersedes EN 62772:2016 and all of its amendments and corrigenda (if any).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Any feedback and questions on this document should be directed to the users' national committee. A complete listing of these bodies can be found on the CENELEC website.

Endorsement notice

The text of the International Standard IEC 62772:2023 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standard indicated:

IEC 60068-2-17 NOTE Approved as EN IEC 60068-2-17

IEC 62155 NOTE Approved as EN 62155

ISO 1101 NOTE Approved as EN ISO 1101

IEC 60060-1 NOTE Approved as EN 60060-1

INTERNATIONAL STANDARD

NORME INTERNATIONALE



Composite hollow core station post insulators with a.c. voltage greater than 1 000 V and d.c. voltage greater than 1 500 V – Definitions, test methods and acceptance criteria

Isolateurs supports composites creux présentant une tension alternative supérieure à 1 000 V et une tension continue supérieure à 1 500 V – Définitions, méthodes d'essai et critères d'acceptation



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2023 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Secretariat
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 300 terminological entries in English and French, with equivalent terms in 19 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Recherche de publications IEC -

webstore.iec.ch/advsearchform

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études, ...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et une fois par mois par email.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Découvrez notre puissant moteur de recherche et consultez gratuitement tous les aperçus des publications. Avec un abonnement, vous aurez toujours accès à un contenu à jour adapté à vos besoins.

Electropedia - www.electropedia.org

Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22 300 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 19 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

INTERNATIONAL STANDARD

NORME INTERNATIONALE



Composite hollow core station post insulators with a.c. voltage greater than 1 000 V and d.c. voltage greater than 1 500 V – Definitions, test methods and acceptance criteria

Isolateurs supports composites creux présentant une tension alternative supérieure à 1 000 V et une tension continue supérieure à 1 500 V – Définitions, méthodes d'essai et critères d'acceptation

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 29.080.10

ISBN 978-2-8322-7404-0

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	7
2 Normative references	7
3 Terms and definitions	8
4 Identification and marking.....	12
5 Environmental conditions.....	13
6 Information on transport, storage and installation	13
7 Classification of tests.....	13
7.1 General.....	13
7.2 Design tests.....	13
7.3 Type tests	15
7.4 Sample tests.....	16
7.5 Routine tests.....	16
8 Design tests	16
8.1 General.....	16
8.2 Tests on interfaces and connections of end fittings	16
8.2.1 General	16
8.2.2 Test specimens	17
8.2.3 Reference disruptive- discharge dry power frequency voltage test.....	17
8.2.4 Thermal mechanical pre-stressing test.....	17
8.2.5 Water immersion pre-stressing test.....	17
8.2.6 Verification tests.....	17
8.3 Assembled core load tests	17
8.3.1 Test for the verification of the maximum design cantilever load (MDCL).....	17
8.3.2 Test for the verification of the maximum design torsion load (MDToL)	18
8.3.3 Verification of the specified tension load (STL)	19
8.4 Tests on shed and housing material.....	19
8.4.1 Hardness test	19
8.4.2 Accelerated weathering test.....	20
8.4.3 Tracking and erosion – 1 000 h salt fog AC voltage test.....	20
8.4.4 Flammability test	20
8.4.5 Hydrophobicity transfer test.....	20
8.5 Tests on the tube material	20
8.5.1 General	20
8.5.2 Porosity test (Dye penetration test).....	20
8.5.3 Water diffusion test.....	20
8.6 Water diffusion test on core with housing	20
9 Type tests	20
9.1 Internal pressure test.....	20
9.2 Bending test.....	20
9.3 Specified tension load test, compression and buckling withstand load test.....	20
9.4 Electrical tests	21
9.4.1 General	21
9.4.2 Mounting arrangements for electrical tests.....	21
9.4.3 Dry lightning impulse withstand voltage test.....	21

9.4.4	Dry or wet switching impulse withstand voltage test.....	21
9.4.5	Dry power-frequency withstand voltage test.....	21
9.4.6	Wet power-frequency withstand voltage test.....	21
10	Sample tests	21
11	Routine tests	22
11.1	General.....	22
11.2	Routine seal leak rate test	22
11.2.1	General	22
11.2.2	Test procedure	22
11.2.3	Acceptance criteria	22
12	Documentation	23
Annex A (informative)	Qualification of fillers.....	24
A.1	General.....	24
A.2	Dye penetration test with solid filler	24
A.3	Water diffusion test with solid filler.....	24
A.4	Tests on interfaces and connections of end fittings with filler	24
Annex B (informative)	Load definitions, relationship of loads.....	26
Annex C (informative)	Principle sketch of hollow insulators design assembly.....	29
Bibliography.....		31
Figure A.1	– Example of sample preparation for water diffusion test	25
Figure B.1	– Definitions according to IEC 62231	26
Figure B.2	– Definitions according to IEC 61462	27
Figure B.3	– Comparison of definitions IEC 61462 vs. IEC 62231	28
Figure C.1	– Interface description for insulator with housing made by modular assembly	29
Figure C.2	– Interface description for insulator with housing made by injection moulding and overmold end fitting.....	30
Table 1	– Required design and type tests	14

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**COMPOSITE HOLLOW CORE STATION POST
INSULATORS WITH AC VOLTAGE GREATER THAN
1 000 V AND DC VOLTAGE GREATER THAN 1 500 V –
DEFINITIONS, TEST METHODS AND ACCEPTANCE CRITERIA**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 62772 has been prepared by IEC technical committee 36: Insulators. It is an International Standard.

This second edition cancels and replaces the first edition published in 2016. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) modifications of terms and definitions;
- b) modifications of tests procedures included in IEC TR 62039 and IEC 62217 (Hydrophobicity transfer test; Water diffusion test on the core with housing);
- c) harmonization of Table 1 (Required design and type tests) with other product standards;
- d) update of Annex A (Qualification of fillers);
- e) addition of a new informative Annex B (Load definitions, relationship of loads).

The text of this International Standard is based on the following documents:

Draft	Report on voting
36/569/FDIS	36/587/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

Composite hollow core station post insulators consist of an insulating hollow core (tube), bearing the mechanical load protected by a polymeric housing, the load being transmitted to the core by end fittings. The hollow core is filled entirely with an insulating material. The core is made of resin impregnated fibres.

Composite hollow core station post insulators are typically applied as post insulators in substations. In order to perform the design tests, IEC 62217 is to be applied for materials and interfaces of the insulator. Some tests have been grouped together as "design tests", to be performed only once on insulators which satisfy the same design conditions. For all design tests on composite hollow core station post insulators, the common clauses defined in IEC 62217 are applied. As far as practical, the influence of time on the electrical and mechanical properties of the components (core material, housing, interfaces etc.) and of the complete composite hollow core station post insulator has been considered in specifying the design tests to ensure a satisfactory life-time under normally known stress conditions in service.

This document relates to IEC 61462, *Composite hollow insulators – Pressurized and unpressurized insulators for use in electrical equipment with rated voltage greater than 1 000 V – Definitions, test methods, acceptance criteria and design recommendations*, as well as IEC 62231, *Composite station post insulators for substations with AC voltages greater than 1 000 V up to 245 kV – Definitions, test methods and acceptance criteria*. Tests and requirements described in IEC 62231 can be used despite the intended operating voltage limit for substations.

The use of polymeric housing materials that show hydrophobicity and hydrophobicity transfer mechanism (HTM) is preferred for composite hollow core station post insulators. This is due to the fact that the influence of diameter can be significant for hydrophilic surfaces (see also IEC 60815-3). For instance silicone rubber is recognized as successful countermeasure against severe polluted service conditions. For the time being, the 1 000 h AC tracking and erosion test of IEC 62217 is used to establish a minimum requirement for the tracking and erosion resistance, for both AC and DC.

Composite hollow core station post insulators are used in both AC and DC applications. Before the appropriate standard for DC applications will be issued, the majority of tests listed in this standard can also be applied to DC insulators. In spite of this, a specific tracking and erosion test procedure for DC applications as a design test is still being considered to be developed. Some information about the difference of AC and DC material erosion test can be found in the CIGRE Technical Brochure 611 [8]¹. For the time being, the 1 000 h AC tracking and erosion test of IEC 62217 is used to establish a minimum requirement for the tracking and erosion resistance.

¹ Numbers in square brackets refer to the Bibliography.

COMPOSITE HOLLOW CORE STATION POST INSULATORS WITH AC VOLTAGE GREATER THAN 1 000 V AND DC VOLTAGE GREATER THAN 1 500 V – DEFINITIONS, TEST METHODS AND ACCEPTANCE CRITERIA

1 Scope

This document, which is an International Standard, applies to composite hollow core station post insulators consisting of a load-bearing insulating tube (core) made of resin impregnated fibres, insulating filler material (solid, liquid, gaseous – pressurized or unpressurized), a housing (outside the insulating tube) made of polymeric material (for example silicone or ethylene-propylene) and fixing devices at the ends of the insulating tube. Composite hollow core station post insulators as defined in this standard are intended for general use in substations in both, outdoor and indoor environments, operating with a rated AC voltage greater than 1 000 V and a frequency not greater than 100 Hz or for use in direct current systems with a rated voltage greater than 1 500 V DC.

The object of this document is:

- to define the terms used;
- to specify test methods;
- to specify acceptance criteria.

All the tests in this document, apart from the thermal-mechanical test, are performed at normal ambient temperature. This document does not specify tests that are characteristic of the apparatus of which the composite hollow core station post insulator ultimately may form a part (e.g. disconnect switch, reactor support, HVDC valves).

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60168, *Tests on indoor and outdoor post insulators of ceramic material or glass for systems with nominal voltages greater than 1000 V*

IEC 61109, *Insulators for overhead lines – Composite suspension and tension insulators for AC systems with a nominal voltage greater than 1 000 V – Definitions, test methods and acceptance criteria*

IEC 61462, *Composite hollow insulators – Pressurized and unpressurized insulators for use in electrical equipment with rated voltage greater than 1 000 V – Definitions, test methods, acceptance criteria and design recommendations*

IEC 62217, *Polymeric HV insulators for indoor and outdoor use – General definitions, test methods and acceptance criteria*

IEC 62231:2006, *Composite station post insulators for substations with AC voltages greater than 1 000 V up to 245 kV – Definitions, test methods and acceptance criteria*

IEC TR 62039, *Selection guidelines for polymeric materials for outdoor use under HV stress*