

AKUSTIKA. HOONETE TEHNOSEADMETEST JA HOONES  
TOIMUVAST TEGEVUSEST TULENEVA  
HELIRÕHUTASEME MÕÕTMINE. INSENERTEHNILINE  
MEETOD

Acoustics - Measurement of sound pressure level from  
service equipment or activities in buildings -  
Engineering method (ISO 16032:2024)

## EESTI STANDARDI EESSÕNA

## NATIONAL FOREWORD

<p>See Eesti standard EVS-EN ISO 16032:2024 sisaldab Euroopa standardi EN ISO 16032:2024 ingliskeelset teksti.</p> <p>Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.</p> <p>Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 06.03.2024.</p> <p>Standard on kättesaadav Eesti Standardimis- ja Akrediteerimiskeskusest.</p>	<p>This Estonian standard EVS-EN ISO 16032:2024 consists of the English text of the European standard EN ISO 16032:2024.</p> <p>This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation and Accreditation.</p> <p>Date of Availability of the European standard is 06.03.2024.</p> <p>The standard is available from the Estonian Centre for Standardisation and Accreditation.</p>
--	---

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile [standardiosakond@evs.ee](mailto:standardiosakond@evs.ee).

ICS 17.140.20, 91.120.20, 91.140.01

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardimis- ja Akrediteerimiskeskusele. Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardimis- ja Akrediteerimiskeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardimis- ja Akrediteerimiskeskusega: Koduleht [www.evs.ee](http://www.evs.ee); telefon 605 5050; e-post [info@evs.ee](mailto:info@evs.ee)

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation and Accreditation. No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation and Accreditation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation and Accreditation: Homepage [www.evs.ee](http://www.evs.ee); phone +372 605 5050; e-mail [info@evs.ee](mailto:info@evs.ee)

EUROPEAN STANDARD

EN ISO 16032

NORME EUROPÉENNE

EUROPÄISCHE NORM

March 2024

ICS 17.140.20; 91.120.20; 91.140.01

Supersedes EN ISO 16032:2004

English Version

Acoustics - Measurement of sound pressure level from  
service equipment or activities in buildings - Engineering  
method (ISO 16032:2024)

Acoustique - Mesurage du niveau de pression  
acoustique des équipements techniques ou activités  
dans les bâtiments - Méthode d'expertise (ISO  
16032:2024)

Akustik - Messung des Schalldruckpegels von  
haustechnischen Anlagen oder Aktivitäten in Gebäuden  
- Standardverfahren (ISO 16032:2024)

This European Standard was approved by CEN on 1 March 2024.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION  
COMITÉ EUROPÉEN DE NORMALISATION  
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

## European foreword

This document (EN ISO 16032:2024) has been prepared by Technical Committee ISO/TC 43 "Acoustics" in collaboration with Technical Committee CEN/TC 126 "Acoustic properties of building elements and of buildings" the secretariat of which is held by AFNOR.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by September 2024, and conflicting national standards shall be withdrawn at the latest by September 2024.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN ISO 16032:2004.

Any feedback and questions on this document should be directed to the users' national standards body/national committee. A complete listing of these bodies can be found on the CEN website.

According to the CEN-CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.

## Endorsement notice

The text of ISO 16032:2024 has been approved by CEN as EN ISO 16032:2024 without any modification.

# Contents

Page

<b>Foreword</b> .....	<b>iv</b>
<b>Introduction</b> .....	<b>vi</b>
<b>1 Scope</b> .....	<b>1</b>
<b>2 Normative references</b> .....	<b>1</b>
<b>3 Terms and definitions</b> .....	<b>1</b>
<b>4 Measurement equipment</b> .....	<b>4</b>
<b>5 Test method — General</b> .....	<b>4</b>
<b>6 Measurement procedure</b> .....	<b>5</b>
6.1 General.....	5
6.2 Selection of the corner position for the microphone.....	6
6.3 Selection of the reverberant field positions of the microphone.....	6
6.4 Measurement of sound pressure levels.....	6
6.4.1 Measurement of the equivalent continuous sound pressure level.....	6
6.4.2 Measurement of the maximum sound pressure level.....	7
6.5 Averaging the sound pressure level.....	7
6.6 Determination of the background sound pressure level.....	7
6.7 Standardization or normalization of one-third-octave-band results.....	7
6.8 Calculation of A- and C-weighted values.....	8
6.9 Sound sources present in the room (additional measurements).....	8
<b>7 Measurement of reverberation time</b> .....	<b>8</b>
<b>8 Correction for background noise</b> .....	<b>8</b>
<b>9 Precision</b> .....	<b>9</b>
<b>10 Test report</b> .....	<b>10</b>
<b>Annex A (normative) A-weighting and C-weighting correction values</b> .....	<b>11</b>
<b>Annex B (normative) Operating conditions and operating cycles for measuring the maximum sound pressure level and the equivalent continuous sound pressure level</b> .....	<b>12</b>
<b>Annex C (informative) Form for the expression of results</b> .....	<b>19</b>
<b>Bibliography</b> .....	<b>20</b>

## Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO document should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see [www.iso.org/directives](http://www.iso.org/directives)).

ISO draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). ISO takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, ISO had not received notice of (a) patent(s) which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at [www.iso.org/patents](http://www.iso.org/patents). ISO shall not be held responsible for identifying any or all such patent rights.

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see [www.iso.org/iso/foreword.html](http://www.iso.org/iso/foreword.html).

This document was prepared by Technical Committee ISO/TC 43, *Acoustics*, Subcommittee SC 2, *Building acoustics*, in collaboration with the European Committee for Standardization (CEN) Technical Committee CEN/TC 126, *Acoustic properties of building elements and of buildings*, in accordance with the Agreement on technical cooperation between ISO and CEN (Vienna Agreement).

This second edition cancels and replaces the first edition (ISO 16032:2004), which has been technically revised.

The main changes are as follows:

- terms and definitions have been revised;
- procedure to detect and average spatial and temporal variations of the sound has been revised;
- measurements can be performed to verify sound levels either from a specific service equipment or an activity in the building, with operating conditions described in [Annex B](#) or by national guidelines if such exist for a specific type of service equipment, e.g. lifts;
- title is updated to reflect that also sound from activities in the building can be measured according to this document, e.g. music sound from a restaurant or sports premises in the same building;
- measurements are performed in one-third-octave-bands;
- octave-band levels, without corrections for reverberation times or background noise may be measured or estimated from the one-third-octave-band levels and reported optionally, but they are not used to calculate the *A*-weighted and *C*-weighted sound pressure levels;
- standardization with respect to reverberation times applies to the 50 Hz to 5 000 Hz one-third-octave-bands;
- frequency range used to calculate the *A*-weighted and *C*-weighted sound pressure levels can include one-third-octave bands from 25 Hz to 10 000 Hz but shall always include the bands 50 Hz to 5 000 Hz;
- [Annex C](#) added providing an example form for the expression of results.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at [www.iso.org/members.html](http://www.iso.org/members.html).

This document is a preview generated by EVS

## Introduction

Many countries have building regulations intended to protect people from noise in their homes or workplaces. For the purpose of verification of compliance with such regulations, there is a need for a standardized method for the measurement of sound pressure levels from service equipment or activities in this building. This document specifies a procedure for such measurements, under specific operating conditions and operating cycles.

This document is a preview generated by EVS

# Acoustics — Measurement of sound pressure level from service equipment or activities in buildings — Engineering method

## 1 Scope

This document specifies an engineering method for the measurement of sound pressure levels in rooms from service equipment installed in the building.

This document covers specifically measurements of sound from sanitary installations, mechanical ventilation, heating and cooling service equipment, lifts, rubbish chutes, heating devices, blowers, pumps and other auxiliary service equipment, and motor driven car park doors. It can also be applied to measurements of sounds from other types of equipment or activities within the building, e.g. noise from sport facilities or restaurants.

The measurement of noise from external sound sources generating air-borne or ground-borne noise in the building are not included in this document.

The methods are suitable for rooms with volumes of approximately 300 m<sup>3</sup> or less for instance, in dwellings, hotels, schools, offices and hospitals.

The methods are not intended for measurements in large auditoria or concert halls.

## 2 Normative references

The following documents are referred to in the text in such a way that some or all their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 3382-2, *Acoustics — Measurement of room acoustic parameters — Part 2: Reverberation time in ordinary rooms*

IEC 60942, *Electroacoustics — Sound calibrators*

IEC 61260-1, *Electroacoustics — Octave-band and fractional-octave-band filters*

IEC 61672-1, *Electroacoustics — Sound level meters - Part 1: Specifications*

## 3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <https://www.electropedia.org/>