

High-voltage switchgear and controlgear - Part 200: AC metal-enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV (IEC 62271-200:2021 + IEC 62271-200:2021/AMD1:2024)

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN IEC 62271-200:2021+A1:2024 sisaldab Euroopa standardi EN IEC 62271-200:2021 ja selle muudatuse A1:2024 ingliskeelset teksti.	This Estonian standard EVS-EN IEC 62271-200:2021+A1:2024 consists of the English text of the European standard EN IEC 62271-200:2021 and its amendment A1:2024.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas. Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 30.07.2021, muudatus A1 16.08.2024.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation and Accreditation. Date of Availability of the European standard is 30.07.2021, for A1 16.08.2024.
Muudatusega A1 lisatud või muudetud teksti algus ja lõpp on tekstis tähistatud sümbolitega A1 A1 . Standard on kättesaadav Eesti Standardimis- ja Akrediteerimiskeskusest.	The start and finish of text introduced or altered by amendment A1 is indicated in the text by tags A1 A1 . The standard is available from the Estonian Centre for Standardisation and Accreditation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 29.130.10

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardimis- ja Akrediteerimiskeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardimis- ja Akrediteerimiskeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autoriõiguse kaitse kohta, võtke palun ühendust Eesti Standardimis- ja Akrediteerimiskeskusega:

Koduleht www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation and Accreditation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation and Accreditation.

If you have any questions about standards copyright protection, please contact the Estonian Centre for Standardisation and Accreditation:

Homepage www.evs.ee; phone +372 605 5050; e-mail info@evs.ee

English Version

High-voltage switchgear and controlgear - Part 200: AC metal-
enclosed switchgear and controlgear for rated voltages above 1
kV and up to and including 52 kV
(IEC 62271-200:2021 + IEC 62271-200:2021/AMD1:2024)

Appareillage à haute tension - Partie 200: Appareillage
sous enveloppe métallique pour courant alternatif de
tensions assignées supérieures à 1 kV et inférieures ou
égales à 52 kV
(IEC 62271-200:2021 + IEC 62271-200:2021/AMD1:2024)

Hochspannungs-Schaltgeräte und -Schaltanlagen - Teil
200: Metallgekapselte Wechselstrom-Schaltanlagen für
Bemessungsspannungen über 1 kV bis einschließlich 52 kV
(IEC 62271-200:2021 + IEC 62271-200:2021/AMD1:2024)

This European Standard was approved by CENELEC on 2021-07-01. Amendment A1 was approved by CENELEC on 2024-08-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard and its amendment the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard and its Amendment A1 exist in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

European foreword

The text of document 17C/782/FDIS, future edition 3 of IEC 62271-200, prepared by SC 17C “Assemblies” of IEC/TC 17 “High-voltage switchgear and controlgear” was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 62271-200:2021.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2022-04-01
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2024-07-01

This document supersedes EN 62271-200:2012 and all of its amendments and corrigenda (if any).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Any feedback and questions on this document should be directed to the users' national committee. A complete listing of these bodies can be found on the CENELEC website.

Endorsement notice

The text of the International Standard IEC 62271-200:2021 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

- | | |
|-----------------------|---|
| IEC 62271-214:2019 | NOTE Harmonized as EN IEC 62271-214:2019 (not modified) |
| IEC 60059:1999 | NOTE Harmonized as EN 60059:1999 (not modified) |
| IEC 60243-1:2013 | NOTE Harmonized as EN 60243-1:2013 (not modified) |
| IEC/TR 62271-307:2015 | NOTE Harmonized as CLC IEC/TR 62271-307:2019 (not modified) |
| IEC 60909-0:2016 | NOTE Harmonized as EN 60909-0:2016 (not modified) |

A1 Amendment A1 European foreword

The text of document 17C/933/FDIS, future IEC 62271-200/AMD1, prepared by SC 17C "Assemblies" of IEC/TC 17 "High-voltage switchgear and controlgear" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 62271-200:2021/A1:2024.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2025-05-01
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2027-08-01

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Any feedback and questions on this document should be directed to the users' national committee. A complete listing of these bodies can be found on the CENELEC website.

Endorsement notice

The text of the International Standard IEC 62271-200:2021/AMD1:2024 was approved by CENELEC as a European Standard without any modification. **A1**



IEC 62271-200

Edition 3.1 2024-06
CONSOLIDATED VERSION

INTERNATIONAL STANDARD



**High-voltage switchgear and controlgear –
Part 200: AC metal-enclosed switchgear and controlgear for rated voltages
above 1 kV and up to and including 52 kV**



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2024 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Secretariat
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews, graphical symbols and the glossary. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 500 terminological entries in English and French, with equivalent terms in 25 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

preview generated by EVS



IEC 62271-200

Edition 3.1 2024-06
CONSOLIDATED VERSION

INTERNATIONAL STANDARD



**High-voltage switchgear and controlgear –
Part 200: AC metal-enclosed switchgear and controlgear for rated voltages
above 1 kV and up to and including 52 kV**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.130.10

ISBN 978-2-8322-9349-2

Warning! Make sure that you obtained this publication from an authorized distributor.

This document is a preview generated by EVS

CONTENTS

FOREWORD.....	6
▣ Amendment A1 FOREWORD ▣.....	9
INTRODUCTION.....	11
1 Scope.....	12
2 Normative references	12
3 Terms and definitions	13
3.1 General terms and definitions	14
3.2 Assemblies of switchgear and controlgear	15
3.3 Parts of assemblies	15
3.4 Switching devices	15
3.5 Parts of switchgear and controlgear	15
3.6 Operational characteristics of switchgear and controlgear	18
3.7 Characteristic quantities	21
3.8 Index of definitions	21
4 Normal and special service conditions.....	23
5 Ratings.....	23
5.1 General.....	23
5.2 Rated voltage (U_r).....	23
5.3 Rated insulation level (U_d , U_p , U_s).....	23
5.4 Rated frequency (f_r)	23
5.5 Rated continuous current (I_r)	23
5.6 Rated short-time withstand currents (I_k , I_{ke}).....	24
5.7 Rated peak withstand currents (I_p , I_{pe})	24
5.8 Rated durations of short-circuit (t_k , t_{ke})	24
5.9 Rated supply voltage of auxiliary and control circuits (U_a).....	25
5.10 Rated supply frequency of auxiliary and control circuits.....	25
5.11 Rated pressure of compressed gas supply for controlled pressure systems	25
5.101 Classification of earthing function through main switching device	25
5.102 Rated cable test voltages (U_{ct} (AC), U_{ct} (DC)).....	25
5.103 Ratings of the internal arc classification (IAC).....	26
6 Design and construction	27
6.1 Requirements for liquids in switchgear and controlgear	27
6.2 Requirements for gases in switchgear and controlgear.....	27
6.3 Earthing of switchgear and controlgear	27
6.4 Auxiliary and control equipment and circuits	28
6.5 Dependent power operation.....	28
6.6 Stored energy operation	29
6.7 Independent unlatched operation (independent manual or power operation)	29
6.8 Manually operated actuators.....	29
6.9 Operation of releases	29
6.10 Pressure/level indication	29
6.11 Nameplates.....	29
6.12 Locking devices	31

6.13	Position indication	32
6.14	Degrees of protection provided by enclosures	32
6.15	Creepage distances for outdoor insulators	33
6.16	Gas and vacuum tightness	33
6.17	Tightness for liquid systems	33
6.18	Fire hazard (flammability)	33
6.19	Electromagnetic compatibility (EMC).....	33
6.20	X-ray emission	33
6.21	Corrosion	33
6.22	Filling levels for insulation, switching and/or operation	33
6.101	General requirements for assemblies.....	33
6.102	Metal enclosure.....	34
6.103	High-voltage compartments	36
6.104	Removable parts	40
6.105	Provisions for dielectric tests on cables	41
6.106	Internal arc fault.....	41
7	Type tests	41
7.1	General.....	41
7.2	Dielectric tests	42
7.3	Radio interference voltage (RIV) test	46
7.4	Resistance measurement	46
7.5	Continuous current tests	46
7.6	Short-time withstand current and peak withstand current tests	48
7.7	Verification of the protection	50
7.8	Tightness tests.....	51
7.9	Electromagnetic compatibility tests (EMC)	51
7.10	Additional tests on auxiliary and control circuits	51
7.11	X-radiation test for vacuum interrupters	52
7.101	Verification of making and breaking capacities	52
7.102	Mechanical operation tests	53
7.103	Pressure withstand test for gas-filled compartments.....	55
7.104	Tests to verify the protection of persons against dangerous electrical effects.....	56
7.105	Internal arc test.....	57
8	Routine tests	61
8.1	General.....	61
8.2	Dielectric test on the main circuit	61
8.3	Tests on auxiliary and control circuits	62
8.4	Measurement of the resistance of the main circuit.....	62
8.5	Tightness test	62
8.6	Design and visual checks	62
8.101	Partial discharge measurement	62
8.102	Mechanical operation tests	63
8.103	Pressure tests of gas-filled compartments.....	63
8.104	Tests after erection on site	63
8.105	Measurement of fluid condition after filling on site	64
9	Guide to the selection of switchgear and controlgear (informative)	64
9.1	General.....	64
9.2	Selection of rated values	64

9.3	Cable-interface considerations	64
9.4	Continuous or temporary overload due to changed service conditions	65
9.5	Environmental aspects	65
9.101	Selection of design and construction.....	65
9.102	Ratings related to earthing circuits.....	69
9.103	Internal arc fault.....	69
9.104	Summary of technical requirements, ratings and optional tests	75
10	Information to be given with enquiries, tenders and orders (informative)	77
10.1	General.....	77
10.2	Information with enquiries and orders	77
10.3	Information with tenders	78
11	Transport, storage, installation, operating instructions and maintenance	79
11.1	General.....	79
11.2	Conditions during transport, storage and installation	79
11.3	Installation	79
11.4	Operating instructions	79
11.5	Maintenance	80
12	Safety	80
12.101	Procedures	80
12.102	Internal arc aspects.....	80
13	Influence of the product on the environment	81
Annex A (normative)	Internal arc fault – Method to verify the internal arc classification (IAC)	82
A.1	Room simulation	82
A.2	Indicators (for assessing the thermal effects of the gases)	84
A.3	Tolerances for geometrical dimensions of test arrangements.....	86
A.4	Test parameters.....	86
A.5	Test procedure.....	87
Annex B (normative)	Partial discharge measurement	99
B.1	General.....	99
B.2	Application.....	99
B.3	Test circuits and measuring instruments	99
B.4	Test procedure.....	100
B.5	Maximum permissible partial discharge quantity.....	101
Annex C (informative)	List of notes concerning certain countries	105
Annex D (normative)	Flowchart categorization procedure for LSC for a given functional unit FU1 with connection compartment	106
Annex E (informative)	Pressure coordination chart for gas-filled compartments $\overline{A_1}$	107
Annex ZA (normative)	Normative references to international publications with their corresponding European publications	108
Bibliography	110
Figure 1 – LSC1	68
Figure 2 – LSC2	68
Figure 3 – LSC2	68
Figure 4 – LSC2	68

Figure 5 – LSC2A	68
Figure 6 – LSC2B	68
Figure 7 – LSC2B	69
Figure 8 – A1 No LSC assigned A1	69
Figure 9 – No LSC assigned	69
Figure A.1 – Mounting frame for vertical indicators	90
Figure A.2 – Horizontal indicator	90
Figure A.3 – Position of the indicators	91
Figure A.4 – Room simulation and indicator positioning for accessibility type A, classified rear side, ceiling above 2 000 mm, functional unit of any height	92
Figure A.5 – Room simulation and indicator positioning for accessibility type A, non-accessible rear side, ceiling at 2 000 mm, so functional unit ≤ 1 800 mm high	93
Figure A.6 – Room simulation and indicator positioning for accessibility type B, classified rear side, functional unit ≥ 1 900 mm high	94
Figure A.7 – Room simulation and indicator positioning for accessibility type B, classified rear side, functional unit < 1 900 mm high	95
Figure A.8 – Ceiling height stated from the floor or false floor level where the assembly is actually placed	96
Figure A.9 – Indicator positioning in case of protrusion at < 2 000 mm height, at classified side	97
Figure A.10 – Indicator positioning in case a bottom exhaust duct belonging to the assembly is defined as a walkable integrated part of the false floor	98
Figure B.1 – Partial discharge test circuit (three-phase arrangement)	103
Figure B.2 – Partial-discharge test circuit (system without earthed neutral)	104
Figure D.1 – Flowchart categorization procedure for LSC for a given functional unit FU1 with connection compartment	106
A1 Figure E.1 – Example of pressure coordination chart A1	107
Table 1 – Nameplate information	30
Table 2 – Locations, causes and examples of measures to decrease the probability of internal arc faults	71
Table 3 – Single-phase-to-earth arc fault current depending on the network neutral earthing	73
Table 4 – Summary of technical requirements, ratings and optional tests for assemblies	75
Table A.1 – Parameters for internal arc test according to compartment construction	89
Table B.1 – Test circuits and procedures	102

INTERNATIONAL ELECTROTECHNICAL COMMISSION

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –**Part 200: AC metal-enclosed switchgear and controlgear
for rated voltages above 1 kV and up to and including 52 kV**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 62271-200 has been prepared by subcommittee 17C: Assemblies, of IEC technical committee 17: High-voltage switchgear and controlgear. It is an International Standard.

This third edition cancels and replaces the second edition published in 2011. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) clause numbering aligned with IEC 62271-1:2017, including the adoption of the subclause names of Clause 3;
- b) in Clause 3 specific definitions are added for "in service", "normal operating condition" and "normal use";
- c) internal arc testing on pole-mounted switchgear is taken out of this document, as it is now covered by the specific standard IEC 62271-214:2019;

- d) a more precise description of earthing circuit is given with the inclusion of ratings and test requirements;
- e) number of mechanical tests on interlocks is reduced for type testing; a more precise description of forces to apply during type testing is given (refer to 7.102);
- f) resistance measuring on main circuit is only needed before continuous current tests (as reference for routine tests) and no longer needed after this continuous current test. Rationale for this deletion is that this measured resistance does not mean anything; as the temperature rise test was just finished, a new temperature rise test will not give new information;
- g) IEC 62271-100:2021, IEC 62271-103:2021, IEC 62271-105:2021 and IEC 62271-106:2021 are referred to in the document;
- h) IEC 62271-107:2019 and IEC IEEE 62271-37-013:2015 are also considered in 7.101.2;
- i) a more precise description of LSC category is given with the inclusion of an explanatory flowchart (Annex D);
- j) examples not covered by the IAC test are transferred from Clause 6 to 9.103;
- k) the term "assembly" is defined in Clause 3 and used as synonym for "metal-enclosed switchgear and controlgear" in this document;
- l) "metallic" is replaced by "metal" where applicable;
- m) 6.105 is now covered by 7.7;
- n) a 1 s rule was introduced for Criterion 4 during IAC tests regarding hot gases versus glowing particles as cause of ignition;
- o) a more precise description of internal arc tests for switchgear with protrusions is given in Annex A.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
17C/782/FDIS	17C/792/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/standardsdev/publications.

This document should be read in conjunction with IEC 62271-1:2017, to which it refers and which is applicable unless otherwise specified. In order to simplify the indication of corresponding requirements, the same numbering of clauses and subclauses is used as in IEC 62271-1:2017. Amendments to these clauses and subclauses are given under the same numbering, whilst additional subclauses, are numbered from 101.

The reader's attention is drawn to the fact that Annex C lists all of the "in-some-country" clauses on differing practices of a less permanent nature relating to the subject of this document.

A list of all parts in the IEC 62271 series, published under the general title *High-voltage switchgear and controlgear*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

This document is a preview generated by EVS

A1 Amendment A1 FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

Amendment 1 to IEC 62271-200:2021 has been prepared by subcommittee 17C: Assemblies, of IEC technical committee 17: High-voltage switchgear and controlgear.

The text of this Amendment is based on the following documents:

Draft	Report on voting
17C/933/FDIS	17C/938/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this Amendment is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications/.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised. A1

This document is a preview generated by EVS

INTRODUCTION

High-voltage (IEC 60050-601:1985, 601-01-27) switchgear refers to rated voltages above 1 kV. However, medium-voltage is commonly used for distribution systems with rated voltages above 1 kV and generally applied up to and including 52 kV; refer to IEC 60050-601:1985, 601-01-28 [1]¹.

Although primarily dedicated to three-phase systems, this document can also be applied to single-phase and two-phase systems.

Switchgear and controlgear assemblies having a solid-insulation enclosure are covered by IEC 62271-201.

^{A1} Generally, gas-filled medium-voltage designs have design pressures below 500 kPa, as mentioned for example in the introduction of EN 50187. ^{A1}

¹ Numbers in square brackets refer to the Bibliography.

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 200: AC metal-enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV

1 Scope

This part of IEC 62271 is applicable to prefabricated metal-enclosed switchgear and controlgear assemblies designed for:

- alternating current;
- rated voltages above 1 kV and up to and including 52 kV;
- service frequencies up to and including 60 Hz;
- indoor and outdoor installation.

The assembly can include air-insulated and/or fluid-filled compartments.

For components installed in a metal-enclosed switchgear and controlgear, this document supplements or even replaces in some cases, the requirements as stated by the individual product standards.

The list of components which can be inside the metal-enclosed switchgear and controlgear is not limited to the ones explicitly cited in this document.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050-151, *International Electrotechnical Vocabulary (IEV) – Part 151: Electrical and magnetic devices* (available at <http://www.electropedia.org>)

IEC 60050-441, *International Electrotechnical Vocabulary (IEV) – Part 441: Switchgear, controlgear and fuses* (available at <http://www.electropedia.org>)

IEC 60060-1:2010, *High-voltage test techniques – Part 1: General definitions and test requirements*

IEC 60270:2000, *High-voltage test techniques – Partial discharge measurements*
IEC 60270:2000/AMD1:2015

IEC 60529:1989, *Degrees of protection provided by enclosures (IP Code)*
IEC 60529:1989/AMD1:1999
IEC 60529:1989/AMD2:2013

IEC 62262:2002, *Degrees of protection provided by enclosures for electrical equipment against external mechanical impacts (IK code)*

IEC 62271-1:2017, *High-voltage switchgear and controlgear – Part 1: Common specifications for alternating current switchgear and controlgear*

IEC 62271-100:2021, *High-voltage switchgear and controlgear – Part 100: Alternating-current circuit-breakers*

IEC 62271-102:2018, *High-voltage switchgear and controlgear – Part 102: Alternating current disconnectors and earthing switches*

IEC 62271-103:2021, *High-voltage switchgear and controlgear – Part 103: Switches for rated voltages above 1 kV up to and including 52 kV*

IEC 62271-105:2021, *High-voltage switchgear and controlgear – Part 105: Alternating current switch-fuse combinations for rated voltages above 1 kV up to and including 52 kV*

IEC 62271-106:2021, *High-voltage switchgear and controlgear – Part 106: Alternating current contactors, contactor-based controllers and motor-starters*

IEC 62271-107:2019, *High-voltage switchgear and controlgear – Part 107: Alternating current fused circuit-switchers for rated voltages above 1 kV up to and including 52 kV*

IEC 62271-201:2014, *High-voltage switchgear and controlgear – Part 201: AC solid-insulation enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV*

A1 deleted text **A1**

IEC 62271-213:2021, *High-voltage switchgear and controlgear – Part 213: Voltage detecting and indicating system*

IEC 62271-215:2021, *High-voltage switchgear and controlgear – Part 215: Phase comparator used with VDIS*

IEC IEEE 62271-37-013:2015, *High-voltage switchgear and controlgear – Part 37-013: Alternating-current generator circuit-breakers*

A1 ISO 4126-2, *Safety devices for protection against excessive pressure – Part 2: Bursting disc safety devices* **A1**

3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 62271-1, IEC 60050-151 and IEC 60050-441, and the following apply.

NOTE The classification system for definitions of IEC 62271-1:2017 is followed. Terms and definitions are referenced and prioritized in the following order:

- Clause 3 of this document;
- IEC 62271-1:2017;
- IEC 60050-441;
- IEC 60050-151.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>