

**ÜLE 1 KV NIMIVAHELDUPPINGEGA  
TUGEVVOOLUPAIGALDISTE MAANDAMINE**

**Earthing of power installations exceeding 1 kV a.c.**

## EESTI STANDARDI EESSÕNA

## NATIONAL FOREWORD

See Eesti standard EVS-EN 50522:2022+A1:2024 sisaldab Euroopa standardi EN 50522:2022 ja selle muudatuse A1:2024 ingliskeelset teksti.	This Estonian standard EVS-EN 50522:2022+A1:2024 consists of the English text of the European standard EN 50522:2022 and its amendment A1:2024.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.  Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 04.03.2022, muudatus A1 06.09.2024.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation and Accreditation.  Date of Availability of the European standard is 04.03.2022, for A1 06.09.2024.
Muudatusega A1 lisatud või muudetud teksti algus ja lõpp on tekstis tähistatud sümbolitega $\boxed{A_1}$ $\langle A_1 \rangle$ .  Standard on kättesaadav Eesti Standardimis- ja Akrediteerimiskeskusest.	The start and finish of text introduced or altered by amendment A1 is indicated in the text by tags $\boxed{A_1}$ $\langle A_1 \rangle$ .  The standard is available from the Estonian Centre for Standardisation and Accreditation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile [standardiosakond@evs.ee](mailto:standardiosakond@evs.ee).

ICS 29.120.50

**Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardimis- ja Akrediteerimiskeskusele**

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardimis- ja Akrediteerimiskeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autoriõiguse kaitse kohta, võtke palun ühendust Eesti Standardimis- ja Akrediteerimiskeskusega: Koduleht [www.evs.ee](http://www.evs.ee); telefon 605 5050; e-post [info@evs.ee](mailto:info@evs.ee)

**The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation and Accreditation**

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation and Accreditation.

If you have any questions about standards copyright protection, please contact the Estonian Centre for Standardisation and Accreditation:

Homepage [www.evs.ee](http://www.evs.ee); phone +372 605 5050; e-mail [info@evs.ee](mailto:info@evs.ee)

English Version

## Earthing of power installations exceeding 1 kV a.c.

Prises de terre des installations électriques de puissance en  
courant alternatif de tension supérieure à 1 kV

Erdung von Starkstromanlagen mit  
Nennwechselfspannungen über 1 kV

This European Standard was approved by CENELEC on 2022-01-10. Amendment A1 was approved by CENELEC on 2024-07-02. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard and its amendment the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard and its Amendment A1 exist in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.



European Committee for Electrotechnical Standardization  
Comité Européen de Normalisation Electrotechnique  
Europäisches Komitee für Elektrotechnische Normung

**CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels**

# Contents

Page

European foreword.....	5
Amendment A1 European foreword  .....	6
1 Scope .....	7
2 Normative references .....	8
3 Terms and definitions .....	9
4 Fundamental requirements.....	16
4.1 General requirements.....	16
4.2 Electrical requirements .....	16
4.2.1 Methods of neutral earthing .....	16
4.2.2 Short-circuit current.....	16
4.3 Safety criteria .....	16
4.4 Functional requirements.....	17
5 Design of earthing systems.....	17
5.1 General.....	17
5.2 Dimensioning with respect to corrosion and mechanical strength .....	17
5.2.1 Earth electrodes.....	17
5.2.2 Earthing conductors.....	17
5.2.3 Bonding conductors.....	17
5.3 Dimensioning with respect to thermal strength .....	18
5.3.1 General.....	18
5.3.2 Current rating calculation .....	18
5.4 Dimensioning with regard to touch voltages.....	20
5.4.1 Permissible values .....	20
5.4.2 Measures for the observance of permissible touch voltages.....	21
5.4.3 Design procedure .....	22
6 Measures to avoid transferred potential .....	24
6.1 Transferred potential from high voltage systems to low voltage systems .....	24
6.1.1 High and low voltage earthing systems .....	24
6.1.2 LV supply only within HV substations .....	24
6.1.3 LV supply leaving or coming to HV substations .....	24
6.1.4 LV in the proximity of HV substation.....	24
6.2 Transferred potentials to telecommunication and other systems .....	25
7 Construction of earthing systems .....	26
7.1 Installation of earth electrodes and earthing conductors .....	26
7.2 Lightning and transients.....	26
7.3 Measures for earthing on equipment and installations.....	26
8 Measurements.....	27
9 Maintainability .....	27
9.1 Inspections.....	27
9.2 Measurements.....	27
10 Inspection and documentation of earthing systems .....	27
Annex A (normative) Methods of calculating permissible touch voltages.....	28
A.1 Method of calculating permissible touch voltages $U_{Tp}$ .....	28
A.2 Method of calculating prospective permissible touch voltages $U_{vTp}$ .....	29

A.3	Method of calculating permissible step voltages .....	30
Annex B (normative)	Calculation of Permissible touch voltage $U_{Tp}$ , Prospective permissible touch voltage $U_{vTp}$ .....	31
B.1	General .....	31
B.2	Calculation of permissible touch voltage .....	31
B.3	Calculation of the permissible touch voltage $U_{Tp}$ curve values of Figure 8 .....	31
B.4	Calculation of prospective permissible touch voltage.....	34
Annex C (normative)	Type and minimum dimensions of earth electrode materials ensuring mechanical strength and corrosion resistance .....	36
Annex D (normative)	Current rating calculation of earthing conductors and earth electrodes ....	38
Annex E (normative)	Description of the recognized specified measures M .....	43
Annex F (normative)	Measures on earthing systems to reduce the effects of high frequency interference .....	46
Annex G (normative)	Detailed measures for earthing of equipment and installations.....	47
G.1	Fences around substation installations.....	47
G.2	Pipes .....	48
G.3	Traction rails .....	48
G.4	Pole mounted transforming and/or switching installations.....	48
G.5	Secondary circuits of instrument transformers.....	49
Annex H (normative)	Measuring touch voltages.....	50
Annex I (informative)	Reduction factors related to earth wires of overhead lines and metal sheaths of underground cables.....	51
I.1	General .....	51
I.2	Typical values of reduction factors of overhead lines and cables (50 Hz).....	52
I.3	Influence of the resistances to earth on current in cable sheath.....	53
Annex J (informative)	Basis for the design of earthing systems .....	54
J.1	Soil resistivity .....	54
J.2	Resistance to earth .....	54
Annex K (informative)	Installing the earth electrodes and earthing conductors .....	60
K.1	Installation of earth electrodes .....	60
K.1.1	Horizontal earth electrodes .....	60
K.1.2	Vertical or inclined driven rods.....	60
K.1.3	Jointing the earth electrodes .....	60
K.2	Installation of earthing conductors .....	60
K.2.1	General .....	60
K.2.2	Installing the earthing conductors .....	60
K.2.3	Jointing the earthing conductors .....	61
Annex L (informative)	Measurements for and on earthing systems.....	62
L.1	Soil resistivity measurement and analysis.....	62
L.1.1	Introduction.....	62

<b>L.1.2</b>	<b>Soil resistivity measurement</b> .....	<b>62</b>
<b>L.1.2.1</b>	<b>General</b> .....	<b>62</b>
<b>L.1.2.2</b>	<b>Wenner Method</b> .....	<b>62</b>
<b>L.1.2.3</b>	<b>Guidance on appropriate Wenner spacings</b> .....	<b>63</b>
<b>L.1.2.4</b>	<b>Sources of error</b> .....	<b>63</b>
<b>L.1.2.5</b>	<b>Seasonal variations</b> .....	<b>63</b>
<b>L.1.3</b>	<b>Soil resistivity analysis</b> .....	<b>63</b>
<b>L.1.3.1</b>	<b>General</b> .....	<b>63</b>
<b>L.1.3.2</b>	<b>Uniform soil model</b> .....	<b>63</b>
<b>L.1.3.3</b>	<b>Two-layer soil model</b> .....	<b>64</b>
<b>L.1.3.4</b>	<b>Multi-layer soil model</b> .....	<b>64</b>
<b>L.2</b>	<b>Measurement of resistances to earth and impedances to earth</b> .....	<b>64</b>
<b>L.3</b>	<b>Determination of the earth potential rise</b> .....	<b>66</b>
<b>L.4</b>	<b>Measurements of touch voltage and prospective touch voltage</b> .....	<b>67</b>
<b>L.5</b>	<b>Elimination of interference and disturbance voltages for earthing measurements</b> .....	<b>71</b>
<b>Annex M (informative)</b>	<b>The use of reinforcing bars in concrete for earthing purpose</b> .....	<b>72</b>
<b>Annex N (informative)</b>	<b>Global Earthing System</b> .....	<b>73</b>
<b>Annex O (normative)</b>	<b>Special national conditions</b> .....	<b>74</b>
<b>Annex P (informative)</b>	<b>A-deviations</b> .....	<b>75</b>
<b>Bibliography</b>	.....	<b>78</b>

## European foreword

This document (EN 50522:2022) has been prepared by CLC/TC 99X "Power installations exceeding 1 kV AC (1,5 kV DC)".

The following dates are fixed:

- latest date by which this document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2023-01-10
- latest date by which the national standards conflicting with this document have to be withdrawn (dow) 2025-01-10

This document will supersede EN 50522:2010 and all of its amendments and corrigenda (if any).

EN 50522:2022 includes the following significant technical changes with respect to EN 50522:2010:

- Text sections in italic which were indicating that the section is a copy of an IEC 61936-1 text replaced by reference note to IEC 61936-1 due to copyright reasons.
- Clause 3 is updated regarding touch voltages.
- Improved figures in Clause 3 for distribution of earth fault currents.
- The process of designing earthing system is clarified in 5.4 and Figure 9.
- Rearranged Annex A and B including prospective permissible touch voltage and permissible step voltage.
- Introduction of stainless steel in Annex C and Annex D.
- More details and figures regarding fences in Annex G.
- Enlarged table of reduction factors and application on cables in Annex I.
- New figures in Annex J (J.4 and J.5).
- Details on soil resistivity measurements and touch voltage measurements including flow chart in Annex L.
- Clause 10 was Annex M in previous version.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Any feedback and questions on this document should be directed to the users' national committee. A complete listing of these bodies can be found on the CENELEC website.

## **A1** Amendment A1 European foreword

This document (EN 50522:2022/A1:2024) has been prepared by CLC/TC 99X “Power installations exceeding 1 kV a.c. (1,5 kV d.c.)”.

The following dates are fixed:

- latest date by which this document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2025-07-02
- latest date by which the national standards conflicting with this document have to be withdrawn (dow) 2027-07-02

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Any feedback and questions on this document should be directed to the users' national committee. A complete listing of these bodies can be found on the CENELEC website. **A1**

## 1 Scope

This document is applicable to specify the requirements for the design and erection of earthing systems of electrical installations, in systems with nominal voltage above 1 kV AC and nominal frequency up to and including 60 Hz, so as to provide safety and proper functioning for the use intended.

NOTE 1 The technical and procedural principles of this document can be applied when third parties' installations and facilities are planned and/or erected in the vicinity of HV electrical power installations.

For the purpose of interpreting this document, an electrical power installation is considered to be one of the following:

- a) substation, including substation for railway power supply;
- b) electrical power installations on mast, pole and tower;  
switchgear and/or transformers located outside a closed electrical operating area;
- c) one (or more) power station(s) located on a single site;  
the electrical power installation includes generators and transformers with all associated switchgear and all electrical auxiliary systems. Connections between generating stations located on different sites are excluded;
- d) the electrical system of a factory, industrial plant or other industrial, agricultural, commercial or public premises;
- e) electrical power installations on offshore facilities for the purpose of generation, transmission, distribution and/or storage of electricity;
- f) transition towers/poles between overhead lines and underground lines.

The electrical power installation includes, among others, the following equipment:

- rotating electrical machines;
- switchgear;
- transformers and reactors;
- converters;
- cables;
- wiring systems;
- batteries;
- capacitors;
- earthing systems;
- buildings and fences which are part of a closed electrical operating area;
- associated protection, control and auxiliary systems;
- large air core reactor.

NOTE 2 In general, a standard for an item of equipment takes precedence over this document.

This document does not apply to the design and erection of earthing systems of any of the following:

- overhead and underground lines between separate installations;
- electrified railway tracks and rolling stock;
- mining equipment and installations;
- fluorescent lamp installations;
- installations on ships according to IEC 60092 (all parts) and offshore units according to IEC 61892 (all parts), which are used in the offshore petroleum industry for drilling, processing and storage purposes;
- electrostatic equipment (e.g. electrostatic precipitators, spray-painting units);
- test sites;
- medical equipment, e.g. medical X-ray equipment.

NOTE 3 The standard EN 50341 series, Overhead lines exceeding AC 1 kV, specifies requirements for the design and erection of earthing systems in overhead lines.

NOTE 4 The scope of this document does not include the requirements for carrying out live working on electrical power installations.

NOTE 5 The scope of this document considers safety requirements for HV installations and its influences on LV installations. For electrical installation up to 1 kV, the standard HD 60364 series applies.

## 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 60909 (series), *Short-circuit currents in three-phase a.c. systems* (IEC 60909 series)

EN IEC 62561-2, *Lightning protection system components (LPSC) - Part 2: Requirements for conductors and earth electrodes* (IEC 62561-2)

HD 60364-1, *Low-voltage electrical installations - Part 1: Fundamental principles, assessment of general characteristics, definitions* (IEC 60364-1)

IEC 60479-1:2018, *Effects of current on human beings and livestock – Part 1: General aspects*

**[A1]** IEC 61936-1:2021, *Power installations exceeding 1 kV AC and 1,5 kV DC - Part 1: AC* **[A1]**