

Insulation coordination for equipment within low-voltage supply systems - Part 1: Principles, requirements and tests (IEC 60664-1:2020 + IEC 60664-1:2020/AMD1:2025)

EESTI STANDARDI EESSÕNA**NATIONAL FOREWORD**

| | |
|---|---|
| See Eesti standard EVS-EN IEC 60664-1:2020+A1:2025 sisaldab Euroopa standardi EN IEC 60664-1:2020 ja selle muudatuse A1:2025 ja paranduse AC:2020 ingliskeelset teksti. | This Estonian standard EVS-EN IEC 60664-1:2020+A1:2025 consists of the English text of the European standard EN IEC 60664-1:2020 and its amendment A1:2025 and its corrigendum AC:2020. |
| Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas. Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 24.07.2020, muudatus A1 20.06.2025. | This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation and Accreditation. Date of Availability of the European standard is 24.07.2020, for A1 20.06.2025. |
| Muudatusega A1 lisatud või muudetud teksti algus ja lõpp on tekstis tähistatud sümbolitega A1 A1 . Parandusega AC lisatud või muudetud teksti algus ja lõpp on tekstis tähistatud sümbolitega AC AC . Standard on kättesaadav Eesti Standardimis- ja Akrediteerimiskeskusest. | The start and finish of text introduced or altered by amendment A1 is indicated in the text by tags A1 A1 . The start and finish of text introduced or altered by corrigendum AC is indicated in the text by tags AC AC . The standard is available from the Estonian Centre for Standardisation and Accreditation. |

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 29.080.30

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardimis- ja Akrediteerimiskeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardimis- ja Akrediteerimiskeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autoriõiguse kaitse kohta, võtke palun ühendust Eesti Standardimis- ja Akrediteerimiskeskusega: Koduleht www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation and Accreditation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation and Accreditation.

If you have any questions about standards copyright protection, please contact the Estonian Centre for Standardisation and Accreditation:

Homepage www.evs.ee; phone +372 605 5050; e-mail info@evs.ee

English Version

**Insulation coordination for equipment within low-voltage supply
systems - Part 1: Principles, requirements and tests
(IEC 60664-1:2020 + IEC 60664-1:2020/AMD1:2025)**

Coordination de l'isolement des matériels dans les réseaux
d'énergie électrique à basse tension - Partie 1: Principes,
exigences et essais
(IEC 60664-1:2020 + IEC 60664-1:2020/AMD1:2025)

Isolationskoordination für elektrische Betriebsmittel in
Niederspannungsanlagen - Teil 1: Grundsätze,
Anforderungen und Prüfungen
(IEC 60664-1:2020 + IEC 60664-1:2020/AMD1:2025)

This European Standard was approved by CENELEC on 2020-06-30. Amendment A1 was approved by CENELEC on 2025-06-10. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard and its amendment the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard and its Amendment A1 exist in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

European foreword

The text of document 109/183/FDIS, future edition 3 of IEC 60664-1, prepared by IEC/TC 109 "Insulation co-ordination for low-voltage equipment" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 60664-1:2020.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2021-03-30
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2023-06-30

This document supersedes EN 60664-1:2007 and all of its amendments and corrigenda (if any).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard IEC 60664-1:2020 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

| | | |
|---------------------|------|--|
| IEC 60038:2009 | NOTE | Harmonized as EN 60038:2011 (modified) |
| IEC 60216 (series) | NOTE | Harmonized as EN 60216 (series) |
| IEC 60068 (series) | NOTE | Harmonized as EN 60068 (series) |
| IEC 60068-1:2013 | NOTE | Harmonized as EN 60068-1:2014 (not modified) |
| IEC 60085:2007 | NOTE | Harmonized as EN 60085:2008 (not modified) |
| IEC 60112:2003 | NOTE | Harmonized as EN 60112:2003 (not modified) |
| IEC 60364-4-44:2007 | NOTE | Harmonized as HD 60364-4-442:2012 (modified) |
| IEC 60529 | NOTE | Harmonized as EN 60529 |
| IEC 60664-3:2016 | NOTE | Harmonized as EN 60664-3:2017 (not modified) |
| IEC 60664-4:2005 | NOTE | Harmonized as EN 60664-4:2006 (not modified) |
| IEC 61000-4-5:2014 | NOTE | Harmonized as EN 61000-4-5:2014 (not modified) |

A1 Amendment A1 European foreword

The text of document 109/235/FDIS, future edition 3 of IEC 60664-1/AMD1, prepared by TC 109 "Insulation co-ordination for low-voltage equipment" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 60664-1:2020/A1:2025.

The following dates are fixed:

- latest date by which the document has to be implemented at national (dop) 2026-06-30 level by publication of an identical national standard or by endorsement
- latest date by which the national standards conflicting with the (dow) 2028-06-30 document have to be withdrawn

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Any feedback and questions on this document should be directed to the users' national committee. A complete listing of these bodies can be found on the CENELEC website.

Endorsement notice

The text of the International Standard IEC 60664-1:2020/AMD1:2025 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standard indicated:

IEC 61643 (series) NOTE Approved as EN IEC 61643 (series)

IEC 60364-1 NOTE Approved as HD 60364-1





IEC 60664-1

Edition 3.1 2025-05
CONSOLIDATED VERSION

INTERNATIONAL STANDARD

BASIC SAFETY PUBLICATION

HORIZONTAL PUBLICATION

**Insulation coordination for equipment within low-voltage supply systems –
Part 1: Principles, requirements and tests**



THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2025 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Secretariat
3, rue de Varembeé
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search -

webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews, graphical symbols and the glossary. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 500 terminological entries in English and French, with equivalent terms in 25 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

| | |
|---|----|
| FOREWORD..... | 7 |
| ▣ Amendment A1 FOREWORD ▣..... | 9 |
| 1 Scope..... | 11 |
| 2 Normative references..... | 12 |
| 3 Terms, definitions and abbreviated terms..... | 12 |
| 3.1 Terms and definitions..... | 12 |
| 3.2 Abbreviated terms..... | 19 |
| 4 Basic technical characteristics for insulation coordination..... | 19 |
| 4.1 General..... | 19 |
| 4.2 Voltages..... | 20 |
| 4.2.1 General aspects..... | 20 |
| 4.2.2 Transient overvoltages..... | 20 |
| 4.2.3 Temporary overvoltages..... | 22 |
| 4.2.4 Recurring peak voltage..... | 22 |
| 4.2.5 Steady-state working voltage..... | 22 |
| 4.2.6 Steady-state peak voltage..... | 23 |
| 4.3 Overvoltage categories..... | 23 |
| 4.3.1 General..... | 23 |
| 4.3.2 Equipment energized directly from the mains supply..... | 23 |
| 4.3.3 Systems and equipment not energized directly from the mains supply..... | 23 |
| ▣ 4.3.4 Equipment requiring specific measures ▣..... | 24 |
| 4.4 Frequency..... | 24 |
| 4.4.1 General..... | 24 |
| 4.4.2 Solid insulation..... | 24 |
| 4.5 Pollution..... | 24 |
| 4.5.1 General..... | 24 |
| 4.5.2 Degrees of pollution in the micro-environment..... | 25 |
| 4.5.3 Conditions of conductive pollution..... | 25 |
| 4.6 Insulating material..... | 25 |
| 4.6.1 Solid insulation..... | 25 |
| 4.6.2 Stresses..... | 26 |
| 4.6.3 Comparative tracking index (CTI)..... | 27 |
| 4.7 Environmental aspects..... | 27 |
| 4.7.1 General..... | 27 |
| 4.7.2 Altitude..... | 28 |
| 4.7.3 Temperature..... | 28 |
| 4.7.4 Vibrations..... | 28 |
| 4.7.5 Humidity..... | 28 |
| 4.8 Duration of voltage stress..... | 28 |
| 4.9 Electrical field distribution..... | 28 |
| 5 Design for insulation coordination..... | 29 |
| 5.1 General..... | 29 |
| 5.1.1 Means of insulation coordination..... | 29 |
| 5.1.2 Frequency above 30 kHz..... | 29 |
| 5.1.3 Reduced distances due to coating or potting..... | 29 |

| | | |
|-----------------------|--|----|
| 5.1.4 | Equipment which are not connected to public low-voltage systems..... | 29 |
| 5.2 | Dimensioning of clearances..... | 29 |
| 5.2.1 | General | 29 |
| 5.2.2 | Dimensioning criteria for clearances | 30 |
| 5.2.3 | Other factors involving clearances | 30 |
| 5.2.4 | Dimensioning of clearances of functional insulation | 31 |
| 5.2.5 | Dimensioning of clearances of basic insulation, supplementary insulation and reinforced insulation..... | 31 |
| 5.3 | Dimensioning of creepage distances..... | 32 |
| 5.3.1 | General | 32 |
| 5.3.2 | Dimensioning criteria of creepage distances | 33 |
| 5.3.3 | Other factors involving creepage distances | 34 |
| 5.3.4 | Dimensioning of creepage distances of functional insulation | 35 |
| 5.3.5 | Dimensioning of creepage distances of basic insulation, supplementary insulation and reinforced insulation..... | 36 |
| 5.4 | Requirements for design of solid insulation | 36 |
| 5.4.1 | General | 36 |
| 5.4.2 | Voltage stress..... | 36 |
| 5.4.3 | Withstand of voltage stresses..... | 36 |
| 5.4.4 | Withstand on environmental stresses..... | 38 |
| 6 | Tests and measurements | 39 |
| 6.1 | General..... | 39 |
| 6.2 | Verification of clearances | 39 |
| 6.2.1 | General | 39 |
| 6.2.2 | Test voltages | 40 |
| 6.3 | Verification of creepage distances | 42 |
| 6.4 | Verification of solid insulation | 42 |
| 6.4.1 | General | 42 |
| 6.4.2 | Selection of tests | 42 |
| 6.4.3 | Conditioning | 43 |
| 6.4.4 | Impulse voltage test | 44 |
| 6.4.5 | AC power frequency voltage test | 44 |
| 6.4.6 | Partial discharge test | 45 |
| 6.4.7 | DC voltage test | 47 |
| 6.4.8 | High-frequency voltage test..... | 47 |
| 6.5 | Performing dielectric tests on complete equipment..... | 47 |
| 6.5.1 | General | 47 |
| 6.5.2 | Parts to be tested..... | 48 |
| 6.5.3 | Preparation of equipment circuits | 48 |
| 6.5.4 | Test voltage values | 48 |
| 6.5.5 | Test criteria | 48 |
| 6.6 | Other tests | 49 |
| 6.6.1 | Test for purposes other than insulation coordination | 49 |
| 6.6.2 | Sampling and routine tests | 49 |
| 6.6.3 | Measurement accuracy of test parameters..... | 49 |
| 6.7 | Measurement of the attenuation of the transient overvoltages | 49 |
| 6.8 | Measurement of clearances and creepage distances..... | 49 |
| Annex A (informative) | Basic data on withstand characteristics of clearances | 55 |

| | |
|--|----|
| Annex B (informative) Nominal voltages of mains supply for different modes of overvoltage control | 60 |
| Annex C (normative) Partial discharge test methods | 62 |
| C.1 Test circuits | 62 |
| C.1.1 General | 62 |
| C.1.2 Test circuit for earthed test specimen (Figure C.1)..... | 62 |
| C.1.3 Test circuit for unearthed test specimen (Figure C.2) | 63 |
| C.1.4 Selection criteria | 63 |
| C.1.5 Measuring impedance | 63 |
| C.1.6 Coupling capacitor C_k | 63 |
| C.1.7 Filter | 63 |
| C.2 Test parameters | 63 |
| C.2.1 General | 63 |
| C.2.2 Requirements for the test voltage | 64 |
| C.2.3 Climatic conditions | 64 |
| C.3 Requirements for measuring instruments | 64 |
| C.3.1 General | 64 |
| C.3.2 Classification of PD meters | 64 |
| C.3.3 Bandwidth of the test circuit | 65 |
| C.4 Calibration | 65 |
| C.4.1 Calibration of discharge magnitude before the noise level measurement | 65 |
| C.4.2 Verification of the noise level..... | 66 |
| C.4.3 Calibration for the PD test | 67 |
| C.4.4 Calibration pulse generator | 67 |
| Annex D (informative) Additional information on partial discharge test methods | 68 |
| D.1 Measurement of partial discharge (PD), PD inception and extinction voltage | 68 |
| D.2 Description of PD test circuits (Figure D.1) | 68 |
| D.3 Precautions for reduction of noise..... | 69 |
| D.3.1 General | 69 |
| D.3.2 Sources in the non-energized test circuit | 69 |
| D.3.3 Sources in the energized test circuit | 69 |
| D.3.4 Measures for reduction of noise..... | 69 |
| D.4 Application of multiplying factors for test voltages | 69 |
| D.4.1 General | 69 |
| D.4.2 Example 1 (circuit connected to mains supply)..... | 70 |
| D.4.3 Example 2 (internal circuit with maximum recurring peak voltage U_{rp})..... | 70 |
| Annex E (informative) Comparison of creepage distances specified in Table F.5 and clearances in Table A.1 | 71 |
| Annex F (normative) Tables | 72 |
| Annex G (informative) Determination of clearance distances according to 5.2 | 81 |
| Annex H (informative) Determination of creepage distances according to 5.3 | 84 |
| A1 Annex I (informative) Electrochemical migration of creepage distances in DC applications | 86 |
| I.1 The phenomenon of electrochemical migration | 86 |
| I.2 Effect of electrochemical migration on creepage distances in DC applications A1 | 87 |
| Annex ZA (normative) Normative references to international publications with their corresponding European publications | 88 |

| | |
|---|----|
| Bibliography | 89 |
| Figure 1 – Recurring peak voltage | 22 |
| Figure 2 – Determination of the width (W) and height (H) of a rib | 35 |
| Figure 3 – Test voltages | 46 |
| Figure 4 – Across the groove | 50 |
| Figure 5 – Contour of the groove | 51 |
| Figure 6 – Contour of the groove with angle | 51 |
| Figure 7 – Contour of rib | 51 |
| Figure 8 – Uncemented joint with grooves less than X | 52 |
| Figure 9 – Uncemented joint with grooves equal to or more than X | 52 |
| Figure 10 – Uncemented joint with a groove on one side less than X | 53 |
| Figure 11 – Creepage distance and clearance through an uncemented joint | 53 |
| Figure 12 – Creepage distance and clearance to a head of screw more than X | 53 |
| Figure 13 – Creepage distance and clearance to a head of screw less than X | 54 |
| Figure 14 – Creepage distance and clearance with conductive floating part | 54 |
| Figure A.1 – Withstand voltage at 2 000 m above sea level | 57 |
| Figure A.2 – Experimental data measured at approximately sea level and their low limits for inhomogeneous field | 58 |
| Figure A.3 – Experimental data measured at approximately sea level and their low limits for homogeneous field | 59 |
| Figure C.1 – Earthed test specimen | 62 |
| Figure C.2 – Unearthed test specimen | 63 |
| Figure C.3 – Calibration for earthed test specimen | 66 |
| Figure C.4 – Calibration for unearthed test specimen | 66 |
| Figure D.1 – Partial discharge test circuits | 68 |
| Figure E.1 – Comparison between creepage distances specified in Table F.5 and clearances in Table A.1 | 71 |
| Figure G.1 – Determination of clearance distances according to 5.2 (1 of 2) | 82 |
| Figure H.1 – Determination of creepage distances according to 5.3 (1 of 2) | 84 |
| Table 1 – Dimensioning of grooves | 50 |
| Table A.1 – Withstand voltages for an altitude of 2 000 m above sea level (1 of 2) | 55 |
| Table A.2 – Altitude correction factors for clearance correction | 56 |
| Table B.1 – Inherent control or equivalent protective control | 60 |
| Table B.2 – Cases where protective control is necessary and control is provided by surge protective device having a ratio of voltage protection level to rated voltage not smaller than that specified in IEC 61643 (all parts) | 61 |
| Table F.1 – Rated impulse withstand voltage for equipment energized directly from the mains supply | 72 |
| Table F.2 – Clearances to withstand transient overvoltages | 73 |
| Table F.3 – Single-phase three-wire or two-wire AC or DC systems | 74 |
| Table F.4 – Three-phase four-wire or three-wire AC systems | 75 |
| Table F.5 – Creepage distances to avoid failure due to tracking (1 of 2) | 76 |
| Table F.6 – A_1 Test voltages for verifying clearances at different altitudes A_1 | 78 |

Table F.7 – Severities for conditioning of solid insulation78

Table F.8 – Dimensioning of clearances to withstand steady-state peak voltages,
temporary overvoltages or recurring peak voltages ^b79

Table F.9 – Additional information concerning the dimensioning of clearances to avoid
partial discharge79

Table F.10 – Altitude correction factors for clearance correction80

This document is a preview generated by EVS

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**INSULATION COORDINATION FOR EQUIPMENT
WITHIN LOW-VOLTAGE SUPPLY SYSTEMS –****Part 1: Principles, requirements and tests**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60664-1 has been prepared by IEC technical committee 109: Insulation co-ordination for low-voltage equipment.

This third edition cancels and replaces the second edition published in 2007. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) update of the Scope, Clauses 2 and 3,
- b) new structure for Clauses 4 and 5,
- c) addition of 1 500 V DC into tables in Annex B and F,
- d) update of distances altitude correction in a new Table F.10,
- e) addition of Annex G with a flowchart for clearances,
- f) addition of Annex H with a flowchart for creepage distances.

It has the status of a basic safety publication in accordance with IEC Guide 104.

The text of this International Standard is based on the following documents:

| FDIS | Report on voting |
|--------------|------------------|
| 109/183/FDIS | 109/186/RVD |

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 60664 series, published under the general title *Insulation coordination for equipment within low-voltage supply systems*, can be found on the IEC website.

Future standards in this series will carry the new general title as cited above. Titles of existing standards in this series will be updated at the time of the next edition.

In this document, the following print type is used:

- **Terms defined in Clause 3: in bold type.**

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

A1 Amendment A1 FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). [IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch> [and/or] www.iso.org/patents. IEC shall not be held responsible for identifying any or all such patent rights.

Amendment 1 to IEC 60664:2020 has been prepared by IEC technical committee 109: Insulation co-ordination for low-voltage equipment.

The text of this Amendment is based on the following documents:

| Draft | Report on voting |
|--------------|------------------|
| 109/235/FDIS | 109/240/RVD |

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this Amendment is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications/.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.



This document is a preview generated by EVS

INSULATION COORDINATION FOR EQUIPMENT WITHIN LOW-VOLTAGE SUPPLY SYSTEMS –

Part 1: Principles, requirements and tests

1 Scope

A1 This part of IEC 60664 deals with **insulation coordination** for **electrical equipment** having a **rated voltage** up to AC 1 000 V or DC 1 500 V connected to **low-voltage supply systems**.

NOTE 1 Throughout this document, the term equipment is used with the meaning of **electrical equipment**. **A1**

This document applies to frequencies up to 30 kHz.

NOTE **A1** 2 **A1** Requirements for **insulation coordination** for equipment within **low-voltage supply systems** with rated frequencies above 30 kHz are given in IEC 60664-4.

NOTE **A1** 3 **A1** Higher voltages can exist in internal circuits of the equipment.

It applies to equipment for use up to 2 000 m above sea level and provides guidance for use at higher altitudes (See 5.2.3.4).

It provides requirements for technical committees to determine **clearances**, **creepage distances** and criteria for **solid insulation**. It includes methods of electrical testing with respect to **insulation coordination**.

The minimum **clearances** specified in this document do not apply where ionized gases are present. Special requirements for such situations can be specified at the discretion of the relevant technical committee.

This document does not deal with distances:

- through liquid insulation;
- through gases other than air;
- through compressed air.

This basic safety publication focusing on safety essential requirements is primarily intended for use by technical committees in the preparation of standards in accordance with the principles laid down in IEC Guide 104 and ISO/IEC Guide 51.

One of the responsibilities of a technical committee is, wherever applicable, to make use of basic safety publications in the preparation of its publications.

However, in case of missing specified values for **clearances**, **creepage distances** and requirements for **solid insulation** in the relevant product standards, or even missing standards, this document applies.

A1 NOTE 4 Further explanations and examples with regard to the use of this document are provided in IEC TR 60664-2-1. **A1**

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60068-2-2, *Environmental testing – Part 2-2: Tests – Tests B: Dry heat*

IEC 60068-2-14:2009, *Environmental testing – Part 2-14: Tests – Test N: Change of temperature*

IEC 60068-2-78, *Environmental testing – Part 2-78: Tests – Test Cab: Damp heat, steady state*

IEC 60270, *High-voltage test techniques – Partial discharge measurements*

IEC 61140:2016, *Protection against electric shock – Common aspects for installation and equipment*

IEC 61180:2016, *High-voltage test techniques for low-voltage equipment – Definitions, test and procedure requirements, test equipment*

3 Terms, definitions and abbreviated terms

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

3.1 Terms and definitions

3.1.1

low-voltage supply system

all installations and plant provided for the purpose of generating, transmitting and distributing electricity

[SOURCE: IEC 60050-601:1985, 601-01-01, modified – The term "electric power system" has been replaced with "low-voltage supply system".]

3.1.2

mains supply

AC or DC power distribution system (external to the equipment) that supplies operating power to the equipment

Note 1 to entry: **Mains supply** includes public or private utilities and, unless otherwise specified in this document, equivalent sources such as motor-driven generators and uninterruptible power supplies.

3.1.3

insulation coordination

mutual correlation of insulation characteristics of electrical equipment taking into account the expected **micro-environment** and other influencing stresses

Note 1 to entry: Expected voltage stresses are characterized in terms of the characteristics defined in 3.1.7 to 3.1.16.