

**Industrial communication networks - Fieldbus
specifications - Part 3-12: Data-link layer service
definition - Type 12 elements**

This document is a preview generated by EVS

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 61158-3-12:2014 sisaldab Euroopa standardi EN 61158-3-12:2014 inglisekeelset teksti.	This Estonian standard EVS-EN 61158-3-12:2014 consists of the English text of the European standard EN 61158-3-12:2014.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 17.10.2014.	Date of Availability of the European standard is 17.10.2014.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 25.040.40, 35.100.20, 35.110

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:
Aru 10, 10317 Tallinn, Eesti; www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:
Aru 10, 10317 Tallinn, Estonia; www.evs.ee; phone 605 5050; e-mail info@evs.ee

English Version

Industrial communication networks - Fieldbus specifications -
Part 3-12: Data-link layer service definition - Type 12 elements
(IEC 61158-3-12:2014)

Réseaux de communication industriels - Spécifications des
bus de terrain - Partie 3-12: Définition des services de la
couche liaison de données - Éléments de type 12
(CEI 61158-3-12:2014)

Industrielle Kommunikationsnetze - Feldbusse - Teil 3-12:
Dienstfestlegungen des Data Link Layer
(Sicherheitsschicht) - Typ 12-Elemente
(IEC 61158-3-12:2014)

This European Standard was approved by CENELEC on 2014-09-17. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Foreword

The text of document 65C/759/FDIS, future edition 3 of IEC 61158-3-12, prepared by SC 65C "Industrial networks" of IEC/TC 65 "Industrial-process measurement, control and automation" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 61158-3-12:2014.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2015-06-17
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2017-09-17

This document supersedes EN 61158-3-12:2012.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association.

Endorsement notice

The text of the International Standard IEC 61158-3-12:2014 was approved by CENELEC as a European Standard without any modification.

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 When an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
ISO/IEC 7498-1	-	Information technology - Open Systems Interconnection - Basic Reference Model: The Basic Model	-	-
ISO/IEC 7498-3	-	Information technology - Open Systems Interconnection - Basic Reference Model: Naming and addressing	-	-
ISO/IEC 8802-3	-	Information technology - Telecommunications and information exchange between systems - Local and metropolitan area networks - Specific requirements - Part 3: Carrier sense multiple access with collision detection (CSMA/CD) access method and physical layer specifications	-	-
ISO/IEC 10731	-	Information technology - Open Systems Interconnection - Basic Reference Model - Conventions for the definition of OSI services	-	-
IEEE 802.1D	-	IEEE Standard for local and metropolitan area networks - Media Access Control (MAC) Bridges	-	-

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	7
1.1 General.....	7
1.2 Specifications.....	7
1.3 Conformance.....	7
2 Normative references.....	8
3 Terms, definitions, symbols, abbreviations and conventions.....	8
3.1 Reference model terms and definitions.....	8
3.2 Service convention terms and definitions.....	9
3.3 Data-link service terms and definitions.....	10
3.4 Symbols and abbreviations.....	13
3.5 Common conventions.....	14
4 Data-link layer services and concepts.....	15
4.1 Operating principle.....	15
4.2 Topology.....	16
4.3 Data-link layer overview.....	16
4.4 Error detection overview.....	17
4.5 Parameter and process data handling introduction.....	17
4.6 Node reference model.....	18
4.7 Operation overview.....	19
4.8 Addressing.....	20
4.9 Slave classification.....	22
4.10 Structure of the communication layer in the slave.....	23
5 Communication services.....	24
5.1 Overview.....	24
5.2 Read services.....	24
5.3 Write services.....	27
5.4 Combined read/write services.....	29
5.5 Network services.....	33
5.6 Mailbox.....	34
6 Local interactions.....	38
6.1 Read local.....	38
6.2 Write local.....	39
6.3 Event local.....	40

Figure 1 – Mapping of logical data in an Ethernet frame consisting of a single Type 12 DLPDU	17
Figure 2 – Type 12 data-link reference model	18
Figure 3 – Type 12 segments in open mode.....	19
Figure 4 – Type 12 segment in direct mode	19
Figure 5 – Addressing mode overview	20
Figure 6 – Fieldbus memory management unit overview	22
Figure 7 – Layering of communication.....	23
Figure 8 – Flow of Type 12 service primitives	24
Figure 9 – Successful mailbox write sequence.....	35
Figure 10 – Successful mailbox read sequence.....	35
Table 1 – Auto-increment physical read (APRD)	25
Table 2 – Configured-address physical read (FPRD).....	25
Table 3 – Broadcast read (BRD)	26
Table 4 – Logical read (LRD)	27
Table 5 – Auto-increment physical write (APWR)	27
Table 6 – Configured-address physical write (FPWR)	28
Table 7 – Broadcast write (BWR).....	28
Table 8 – Logical write (LWR).....	29
Table 9 – Auto-increment physical read/write (APRW)	30
Table 10 – Configured-address physical read/write (FPRW).....	30
Table 11 – Broadcast read/write (BRW)	31
Table 12 – Logical read/write (LRW)	31
Table 13 – Auto-increment physical read / multiple write (ARMW).....	32
Table 14 – Configured-address physical read / multiple write (FRMW).....	32
Table 15 – Provide network variable (PNV).....	33
Table 16 – Mailbox write	36
Table 17 – Mailbox read update	37
Table 18 – Mailbox read	38
Table 19 – Read local	39
Table 20 – Write local	39
Table 21 – Event local	40

INTRODUCTION

This part of IEC 61158 is one of a series produced to facilitate the interconnection of automation system components. It is related to other standards in the set as defined by the “three-layer” fieldbus reference model described in IEC 61158-1.

Throughout the set of fieldbus standards, the term “service” refers to the abstract capability provided by one layer of the OSI Basic Reference Model to the layer immediately above. Thus, the data-link layer service defined in this standard is a conceptual architectural service, independent of administrative and implementation divisions.

This document is a preview generated by EVS

INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

Part 3-12: Data-link layer service definition – Type 12 elements

1 Scope

1.1 General

This part of IEC 61158 provides common elements for basic time-critical messaging communications between devices in an automation environment. The term “time-critical” is used to represent the presence of a time-window, within which one or more specified actions are required to be completed with some defined level of certainty. Failure to complete specified actions within the time window risks failure of the applications requesting the actions, with attendant risk to equipment, plant and possibly human life.

This standard defines in an abstract way the externally visible service provided by the Type 12 fieldbus data-link layer in terms of

- a) the primitive actions and events of the service;
- b) the parameters associated with each primitive action and event, and the form which they take;
- c) the interrelationship between these actions and events, and their valid sequences.

The purpose of this standard is to define the services provided to

- the Type 12 fieldbus application layer at the boundary between the application and data-link layers of the fieldbus reference model;
- systems management at the boundary between the data-link layer and systems management of the fieldbus reference model.

1.2 Specifications

The principal objective of this standard is to specify the characteristics of conceptual data-link layer services suitable for time-critical communications, and thus supplement the OSI Basic Reference Model in guiding the development of data-link protocols for time-critical communications. A secondary objective is to provide migration paths from previously-existing industrial communications protocols.

This specification may be used as the basis for formal DL-Programming-Interfaces. Nevertheless, it is not a formal programming interface, and any such interface will need to address implementation issues not covered by this specification, including

- a) the sizes and octet ordering of various multi-octet service parameters, and
- b) the correlation of paired request and confirm, or indication and response, primitives.

1.3 Conformance

This standard does not specify individual implementations or products, nor does it constrain the implementations of data-link entities within industrial automation systems.

There is no conformance of equipment to this data-link layer service definition standard. Instead, conformance is achieved through implementation of the corresponding data-link protocol that fulfils the Type 12 data-link layer services defined in this standard.